

TIC



UNITED STATES
NUCLEAR REGULATORY COMMISSION 8005070693 A
WASHINGTON, D. C. 20555

APR 24 1980

Docket Nos. 50-~~973~~ 508
and 50-~~377~~ 509

Mr. D. L. Renberger
Assistant Director of Technology
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352

Dear Mr. Renberger:

SUBJECT: APPLICATION OF ASME CODE CASE N-242 FOR THE WASHINGTON PUBLIC POWER
SUPPLY SYSTEM (WPPSS) NUCLEAR PROJECTS 3 & 5

In your letter of April 11, 1980, you requested authorization to use ASME Code Case N-242, dated April 12, 1979, "Materials Certification, Section III, Division 1, Classes 1, 2, 3, MC and CS Construction", to the materials being used in the fabrication of the diesel generator units for WPPSS Nuclear Projects 3 & 5. We conclude that Code Case N-242 is acceptable subject to the following additional condition:

You should identify the components and supports requiring the use of paragraphs 1.0 through 4.0 of the code case in the Final Safety Analysis Report.

Therefore, Code Case N-242 may be applied to the materials being used in the fabrication of the diesel generator units for WPPSS Nuclear Projects 3 & 5 utilizing the above additional condition.

Sincerely,

Olan D. Parr
Olan D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management

cc: See next page

Mr. N. O. Strand
Managing Director
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

APR 24 1980

cc: Nicholas S. Reynolds, Esq.
DeBevoise & Liberman
1200 Seventeenth St., N. W.
Washington, D. C. 20036

Richard Q. Quigley, Esq.
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352

Nicholas D. Lewis, Chairman
Energy Facility Site Evaluation Council
820 East Fifth Avenue
Olympia, Washington 98504

Resident Inspector/WPPSS NPS
c/o U. S. NRC
P. O. Box 69
Richland, Washington 99352