



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

April 25, 1980

Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Region II
 101 Marietta Street, N.W., Suite 3100
 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
 Units 1 and 2
 Dockets Nos. 50-416/417
 File 0272/15525/15526
 PRD-80/11, Status Report,
 Rosemount Model 510 DU
 Trip/Calibration Units
 and Model 1152 Pressure
 Transmitters
 AECM-80/86

On March 27, 1980, Mississippi Power & Light Company (MP&L) notified Mr. F. Cantrell of your office of Potentially Reportable Deficiencies (PRD) at the Grand Gulf Nuclear Station (GGNS) construction site. These deficiencies concern Rosemount Model 510 DU trip/calibration units and Model 1152 pressure transmitters and are described in the attached status report.

General Electric identified this matter as a reportable condition per 10 CFR 21 and provided a written report to Mr. R. Engelken, Region V of the NRC, on these deficiencies in the letter dated March 21, 1980. General Electric informed Mississippi Power & Light of this finding in the letter dated March 26, 1980. Upon receipt of this information, MP&L made the above referenced notification to Mr. Cantrell, assigning this matter the serial number PRD-80/11.

Our preliminary investigation reveals that the deficiency pertaining to Model 510 DU trip/calibration unit has been previously reported by MP&L. This matter was determined to be a reportable condition per 10 CFR 50.55(e) and was so reported in our letter to you, AECM-80/31, dated January 30, 1980.


B019
 SE
 1/1

MISSISSIPPI POWER & LIGHT COMPANY

Mr. J. P. O'Reilly, Director
AECM-80/86
Page Two

We are currently investigating the deficiency pertaining to the Model 1152 pressure transmitter and expect to provide our final report on this matter by June 24, 1980.

Yours truly,



L. F. Dale
Nuclear Project Manager

JGC/JDR:cjb

Attachment

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Victor Stello, Jr., Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555