NRC FORM 366 (7-77)

80 051 80549 S

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	MNPIN1
01	License Number (3)	00-00000-00
01	License Type (4)	41111
01	CAT (5)	
CON'T 01	Report Source (6)	L
01	Docket Number (7)	05000282
01	Event Date (8)	041080
01	Report Date (9)	050980

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During surveillance test, one overpower delta T setpoint was found to trip about
03 70% above the desired setpoint. Redundant channels were operable. This is the first
04 occurrence of a failure of this magnitude and type. Tech Spec Table 3.5-2 applies.
05 No effect on public health and safety.
06
07
08

Line	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
09	IA	E	G	INSTRU	S	Z

(17) LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
80	—	014	/	03	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
C	D	Z	Z	0000	N	Y	N	F180

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Bistable was immediately replaced with a calibrated spare. The failed Foxboro
11 bistable Model 63U Custom was found to have an intermittent capacitor. The capacitor
12 was replaced and the bistable placed in spare parts storage.
13
14

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	E	100	N/A	B	Surveillance testing

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
17	000	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
18	000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
19	Z	NA

PUBLICITY

Line	Issued (44)	Description (45)
20	N	NA

NRC USE ONLY

NAME OF PREPARER A. A. Hunstad PHONE: 612-388-4767

GPO 917-926