

LICENSEE EVENT REPORT

8005130560  
5

CONTROL BLOCK: \_\_\_\_\_(1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(01) M N P I N 2 (2) 0 0 - 0 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) \_\_\_\_\_ (5)

CON'T

(01) REPORT SOURCE L (6) 0 5 0 0 0 0 3 0 6 (7) 0 4 1 1 8 0 (8) 0 5 0 9 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

(02) While performing maintenance in the area, a workman accidentally tripped the over-  
(03) speed trip valve for No. 22 Turbine-Driven Auxiliary Feedwater Pump. The valve was  
(04) immediately "reset" but over the next several hours was found tripped (and was reset)  
(05) three times. Related events are RO's 79-29, 77-38, 77-21 and 77-15. Tech Spec  
(06) 3.4.A.2.b applies. No effect on public health and safety since redundant pump was  
(07) operable.

(08) \_\_\_\_\_  
(09) SYSTEM CODE C H (11) CAUSE CODE A (12) CAUSE SUBCODE B (13) COMPONENT CODE V A L V O P (14) COMP. SUBCODE J (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER 8 0 (21) (22) \_\_\_\_\_ SEQUENTIAL REPORT NO. 0 1 3 (24) OCCURRENCE CODE / (27) 0 3 (28) REPORT TYPE L (30) REVISION NO. 0 (32)  
ACTION TAKEN H (18) FUTURE ACTION F (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NRPD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER G 1 5 3 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

(10) The valve reset operation is complex and was not well understood by many operators.  
(11) Training of involved people has been completed. A Design Change is being expedited  
(12) which will give the control room the trip status and annunciation of a change in trip  
(13) status of the valve. The 4-hour inspection is continuing. Gimpel Machine Works  
(14) trip throttle valve.

(15) FACILITY STATUS E (28) % POWER 1 0 0 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Operator Observation (32)

(16) ACTIVITY CONTENT Z (33) RELEASED OF RELEASE Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)

(17) PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)

(18) PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)

(19) LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)

(20) PUBLICITY ISSUED N (44) DESCRIPTION NA (45)

NAME OF PREPARER A. A. Hunstad

PHONE: 612-388-4767