

8005190745

PDR
LPDR
TIC
NSIC
CENTRAL FILES

The Light company

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

March 31, 1980
ST-HL-AE-439
SFN: V-0540

Director, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76102


Dear Sir:

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Updated Response to IE Bulletin No. 79-28

Attached to this letter is an update of the responses from vendors to the South Texas Project concerning their use of NAMCO stem-mounted limit switches. According to information received to date, corrective action has been necessary for only one vendor. Houston Lighting & Power will continue to send updates of vendor responses as stated in our letter to you dated February 1, 1980.

If there are any questions, please contact Mr. S. S. Rodgers at (713) 676-7953.

Very truly yours,



E. A. Turner
Vice President
Power Plant Construction
& Technical Services

PLW/mak

Attachment

3 1980

cc: Director, NRC Office of Inspection and Enforcement
Division of Reactor Operations Inspection
M. D. Schwarz (Baker & Botts)
R. Gordon Gooch (Baker & Botts)
J. R. Newman (Lowenstein, Newman, Reis, Axelrad & Toll)
D. G. Barker
C. L. McNeese
H. R. Dean
G. B. Painter
R. L. Waldrop
A. J. Granger
R. A. Frazar

I&E Bulletin 79-28 Response Update
 NAMCO Limit Switches
 3/31/80

<u>Vendor</u>	<u>Advisory Letter Sent</u>	<u>Response Received</u>	<u>Remarks</u>
Fisher Controls	12-20-79	1-15-80	Corrective action implemented as recommended by NAMCO
WKM	12-20-79	2-27-80	No corrective action required
Kerotest	1-08-80		
Anchor Darling	1-08-80		
Dresser Industries	1-08-80		
Anderson Greenwood	1-08-80		
Cooper Energy Systems	1-07-80		
Bingham-Willamette	1-07-80		
Hills McCanna	1-07-80 & 2-13-80		
Pacific Valves	2-13-80	3-07-80	No corrective action required
Xomox	2-13-80		
Westinghouse (Ametek)	1-15-80	1-30-80	No corrective action required