(7-77)

LICENSEE EVENT REPORT

LER 80-16/3L 8005200625

S

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
0 1	LICENSEE CODE (2)	V T V Y S 1
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 7 1
	EVENT DATE (8)	0 4 1 5 8 0
	REPORT DATE (9)	0 5 1 5 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a review of surveillance data, it was discovered that the quarterly calibration
0 3 of the Main Steam Line Radiation Monitors required by Technical Specifications Table
0 4 4.2.2 was not performed as scheduled in December 1979. Since the weekly instrument
0 5 checks and March 1980 calibration revealed no abnormalities, it is concluded that there
0 6 were no consequences to the health & safety of the public. There have been no previous
0 7 occurrences of this type.
0 8

0 9	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
	Z Z	A	C	Z Z Z Z Z Z	Z	Z

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 1 6	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
H	Z	Z	Z	0 0 0 0	N	N	Z	Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The calibration was overlooked when the weekly check was performed. The calibration
1 1 was successfully completed as scheduled in March 1980. Applicable personnel have
1 2 reviewed the appropriate procedures. The departmental surveillance schedule has been
1 3 revised to highlight calibrations and checks when both are scheduled.
1 4

1 5	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
	E	1 0 0	N/A	A	Review of Surveillance Records

1 6	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
	0 0 0	Z	N/A

PERSONNEL INJURIES

1 8	NUMBER (40)	DESCRIPTION (41)
	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE (42)	DESCRIPTION
	Z	N/A

PUBLICITY

2 0	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
	N	N/A	

NAME OF PREPARER W. P. Murphy PHONE: (802) 257-7711