



Wisconsin Electric POWER COMPANY
231 WEST MICHIGAN, MILWAUKEE, WISCONSIN 53201

ASB

June 2, 1980


Mr. J. G. Keppler, Regional Director
Office of Inspection and Enforcement,
Region III
U. S. NUCLEAR REGULATORY COMMISSION
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

DOCKET NO. 50-266
POINT BEACH NUCLEAR PLANT UNIT 1
LICENSEE EVENT REPORT NO. 80-005/03L-0

Enclosed is Licensee Event Report No. 80-005/03L-0
(a 30-day report) with an attachment which provides a description
of an event which may be in violation of Technical Specification
15.6.2.2.f, "A fire brigade of at least five members shall be
maintained on site at all times".

Very truly yours,


C. W. Fay, Director
Nuclear Power Department

Enclosure

A002
5/11

JUN 5 1980

80 06110/49:5