



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

PDR
LPDR
TIC
NSIC
CENTRAL FILES

May 29, 1980

In Reply Refer To:

RIV


Docket No. 50-382/IE Information Notice No. 80-23

Louisiana Power and Light Co.
ATTN: Mr. D. L. Aswell
Vice President of Power Production
142 Delaronde Street
New Orleans, Louisiana 70174

Gentlemen:

This IE Information Notice is forwarded for information. No written response to this Information Notice is required. If you have any questions related to this matter, please contact this office.

Sincerely,


Karl V. Seyfrit
Director

Enclosures:

1. IE Information Notice
No. 80-23
2. List of Recently Issued
IE Information Notices

8007010 020

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D. C. 20555

SSINS No.: 6835
Accession No.:
8005050061

Dupe

IE Information Notice No. 80-23
Date: May 29, 1980
Page 1 of 1

LOSS OF SUCTION TO EMERGENCY FEEDWATER PUMPS

Description of Circumstances:

On April 7, 1980, Arkansas Nuclear One, Unit 2, suffered a loss of offsite power due to tornado damage to 500 kV transmission towers. The unit tripped from 98% power; the diesel generators started and supplied vital loads; natural circulation in the reactor coolant system was established; and the emergency feedwater (EFW) pumps supplied feedwater to the steam generators.

The suction of the EFW pumps was aligned to the Condensate Storage Tanks (CST) and to the Startup and Blowdown Demineralizer effluent in parallel. Approximately 15 minutes after the unit tripped, both EFW pumps lost suction. Prompt operator action was taken to isolate the EFW pump suction from the Startup and Blowdown Demineralizer and to vent the EFW pumps. EFW flow was re-established within one minute.

Investigation revealed that the EFW pump suction loss was caused by flashing in the main feedwater train forcing hot water through the Startup and Blowdown Demineralizers to the EFW pump suction where it flashed to steam. The steam caused cavitation of the EFW pumps, and the pressure in the EFW suction header prevented flow from the CST.

The licensee has submitted Licensee Event Report No. 50-368/80-18/03L-0, dated May 5, 1980, describing this event. Action to prevent recurrence included revising the EFW system operating procedure and the Plant Startup Procedure to require shutting the EFW suction valve from the Startup and Blowdown Demineralizers during plant startup at about 5% full power after the steam generator feedwater source has been shifted to a main feedwater pump. In addition, the EFW suction valve from the Startup and Blowdown Demineralizers will be verified closed once per shift during Mode 1 operation.

This IE Information Notice is provided as an early notification of a possibly significant matter that is still under review by the NRC staff. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If NRC evaluations so indicate, further licensee actions may be requested or required.

No written response to this IE Information Notice is required. If you have any questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

LISTING OF RECENTLY ISSUED
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-17	Potential Hazards Associated With Interchangeable Parts On Radiographic Equipment	5/5/80	All radiography Licenses
80-18	Possible Weapons Smuggling Pouch	5/5/80	All power reactor facilities with an Operating License (OL), fuel fabrication and processing facilities and Materials Priority I licensees (processors and distributors)
80-19	NIOSH Recall of Ricirculating-Mode (Closed Circuit) Self-Contained Breathing Apparatus (Rebreathers)	5/6/80	All holders of a power reactor Operating License (OL), Research Reactor License, Fuel Cycle Facility License and Priority I Material License
80-20	Loss of Decay Heat Removal Capability at Davis-Besse Unit 1 While in a Refueling Mode	5/8/80	All light water reactor facilities holding power reactor Operating Licenses (OLs) or Construction Permits (CPs)
80-21	Anchorage and Support of Safety-Related Electrical Equipment	5/16/80	All power reactor facilities with an Operating License (OL) or Construction Permit (CP)
80-22	Breakdown In Contamination Control Programs	5/28/80	All power reactor Operating Licenses (OLs) and near term Construction Permits (CPs)

Enclosure