SNUPPS

Standardized Nuclear Unit Power Plant System

5 Choke Cherry Ruid Rockville, Maryland 2L Pist (301) 869-8010

January 26, 1981

SLNRC 81-004 FILE: 0278.10

NRC/IE Bulletin 79-03A: Longitudinal

Weld Defects in ASME SA-312, Type 304 Stainless Steel Pipe

Mr. Boyce Grier Director, Region I Office of Inspection and Enforcement U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Docket Nos. STN 50-482, STN 50-483, STN 50-486

Ref: a) SLNRC 80-52 dtd. 11/26/80: Subj. as Above

b) SLNRC 80-38 dtd. 8/20/80:

Dear Mr. Grier:

The reference letters provided interim responses to IE Bulletin 79-03A concerning the use or potential use of fusion-welded SA-312 Type 304 stainless steel pipe in Callaway 1 and Wolf Creek units. These responses indicated that fusion welded materials of the type described in the subject builetin have not been used in piping systems or components furnished by the Lead A/E in which the design hoop stresses equal or exceed 85 percent of ASME allowable. Data concerning the use of these materials in nonpiping components furnished by the NSSS supplier and in replacement piping purchased directly by the Wolf Creek constructor were under examination at the time of the most recent, Ref. a) update. Since that time, we have completed our investigation and are able to report that none of these additional materials are either in use or scheduled for use in systems or components in which design hoop stresses equal or exceed the 85 percent code criteria.

If you have further questions in this matter, please contact the undersigned.

Very truly yours,

OA Manager

SJS:dck:5a29

cc: Mr. J. A. Keppler, Director, Region III USNRC

Mr. W. Wescott, Region III, USNRC

Mr. Karl Seyfrit, Director, Region IV, USNRC

Mr. Victor Stello, Jr., Director, Office of Inspection and Enforcement, USNRC, Washington, D.C.

T. Vanuel, Wolf Creek Resident Inspector, USNRC

W Hancon Callaway Resident Inspector, USNRC