

NPDES NONCOMPLIANCE NOTIFICATION
Possible Noncompliance With Daily Average/Maximum Limitation
August 20, 1979

Plant: Palisades

Permit No MI 0001457

Outfall Description: Cooling Tower Blowdown
Prior to Dilution

Outfall No: 800173

Parameter: Sulfate

Parameter No: 00945

1. Date of Incident: July 31, 1979
2. Identification of specific effluent limitation exceeded: Weekly Sampling for Sulfate
3. Description of Incident: The weekly sampling and analysis for sulfate in the cooling tower blowdown was not performed during July 1979.
4. Apparent Cause: Technician error.
5. If not immediately corrected, the anticipated time the condition is expected to continue: NA
6. Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence: An analysis for sulfate was performed on a composite sample representing the blowdown effluent. This value was reported on the MOR. A schedule of required sampling will be reviewed with appropriate persons to insure all sampling and analysis will be performed.
7. Additional Comments: NA
8. Signed: Ronald L Fobes

Ronald L Fobes

2021 263

7908280668