

NRC DISTRIBUTION FOR PART 50 DOCK MATERIAL
(TEMPORARY FORM)

CONTROL NO: 5426

FILE: _____

FROM: Duke Power Company Charlotte, NC A C Thies		DATE OF DOC 5-9-75	DATE REC'D 5-16-75	LTR XXX	TWX	RPT	OTHER
TO: Mr Giambusso		ORIG 3 signed	CC	OTHER	SENT AEC PDR <u>XX</u>		SENT LOCAL PDR <u>XX</u>
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 3	DOCKET NO: <u>50-269/270/287</u>		

DESCRIPTION: Ltr notaxized 5-9-75....trans the follow:

ENCLOSURES: Amt to OL/Change to Tech Specs: Consisting of revisions to the tech specs with regard to the regulating control rod posttions....
(40 cys encl rec'd)

PLANT NAME: Oconee 1-3

FOR ACTION/INFORMATION 5-16-75 ehf

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies	ACKNOWLEDGED DO NOT REMOVE PROJECT MANAGER
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies	
FARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	STAS W/ Copies	
KNIEL (L) W/ Copies	PURPLE (L) W/6Copies	YOUNGBLOOD (E) W/ Copies	LICENSING W/ Copies	

INTERNAL DISTRIBUTION

<u>REG ENR</u> NRC PDR OGC, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE REG OPR FILE & REGION (2) MPIC STEELE	TECH REVIEW SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO J. COLLINS LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR <u>M. AV</u> HARLESS	LIC ASST. R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. MAIGRET (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L)	A/T IND. BRAITMAN SALTZMAN MELTZ PLANS MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON
--	---	--	--	--

EXTERNAL DISTRIBUTION

- 1 - LOCAL PDR Walhalla, SC
- 1 - TIC (ABERNATHY) (1)(2)(10)
- 1 - NSIC (BUCHANAN)
- 1 - ASLB
- 1 - Newton Anderson
- 1 - ACRS ~~OLD~~ /SENT TO L.A. Sheppard
- 1 - NATIONAL LABS
- 1 - W. PENNINGTON, Rm E-201 GT
- 1 - CONSULTANTS
NEWMARK/BLUME/AGBABIAN
- 1 - PDR-SAN/LA/NY
- 1 - BROOKHAVEN NAT LAB
- 1 - G. ULRIKSON, ORNL
- 1 - AGMED (RUTH GUSSMAN)
Rm B-127 GT
- 1 - J. D. RUNKLES, Rm E-201 GT

8911270 747 P

REGULATORY DOCKET FILE COPY

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

May 9, 1975

Mr. Angelo Giambusso, Director
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Mr. Giambusso:

In response to the March 31, 1975 letter from Mr. Karl R. Goller, Duke Power Company submits the following proposed Technical Specification changes for the Oconee Nuclear Station.

The proposed revisions apply to Specifications 3.1.3.5, 3.5.2.3, and 3.5.2.5. The revision to Specification 3.1.3.5 incorporates an additional restriction on the regulating control rod positions prior to criticality to assure that the ejected rod worth does not exceed the 1.0% $\Delta k/k$ limit at hot zero power. The revision to Specification 3.5.2.3 deletes the specification on inserted control rod worths but at the same time specifies the manner in which the inserted control rod worths are to be maintained within acceptable limits. Finally, the revision to Specification 3.5.2.5 modifies the rod withdrawal limits for Oconee Units 2 and 3 after the control rod interchange.

The present specification on control rod withdrawal limits is intended to address only the LOCA-limited power peaking criterion. The shutdown margin and ejected rod worth criteria are independently specified by Specifications 3.5.2.1 and 3.5.2.3, respectively, and must be met in addition to the rod withdrawal limit specifications. Therefore, the present specifications are adequate, when used in conjunction with each other, as intended, to assure safe operation. However, in order to provide for a more direct application of the Technical Specifications, revised rod withdrawal limits have been proposed which will assure, by use of the rod withdrawal limits alone, compliance with the three subject criteria (LOCA-limited power peaking, shutdown margin, and ejected rod worth). In the case of Oconee 1, the current specification on the rod withdrawal limit continues to be adequate, since the ejected rod worth is predicted to be less than 1.0% $\Delta k/k$ following the rod interchange,



Mr. Angelo Giambusso

Page 2

May 9, 1975


for the rod withdrawal limits specified. (An analysis of the Oconee 1, Cycle 2 ejected rod worth has been submitted to the NRC in a letter of April 14, 1975, from Mr. A. C. Thies to Mr. Norman C. Moseley, with a copy sent to Mr. Angelo Giambusso.) For Oconee 2 and 3, revised rod withdrawal limits have been proposed since the hot zero power ejected rod worths after the control rod interchange have been predicted to exceed $1\% \Delta k/k$ for certain control positions allowed by the present Specification 3.5.2.5.

The proposed revision makes the specification on ejected rod worth redundant in that the rod position limits will now assure that the worth of a single inserted rod will not exceed the values verified to be acceptable in the safety analysis of the hypothetical rod ejection accident. It should be noted that Technical Specification 3.5.2.5c on rod position limits allows the rod position limits to be exceeded for a period of up to two hours on the basis that the LOCA has a very low probability of occurrence. We consider the probability of the rod ejection accident to be the same order as that of the LOCA; therefore, the same flexibility in the rod position limits should be allowed for the ejected rod worth criterion.

Attached are replacement pages 3.1-8, 3.1-9, 3.5-7, 3.5-8, 3.5-10, 3.5-11, 3.5-14, 3.5-14a, 3.5-15, 3.5-16, 3.5-16a, 3.5-17, 3.5-19, and 3.5-20 of the Oconee Nuclear Station Technical Specifications. The revisions are identified by vertical lines in the margin of the replacement pages.

To enable implementation of this revision prior to the Oconee Units 2 and 3 control rod interchange, it is requested that approval for this proposed revision be given as soon as possible.

Very truly yours,




A. C. Thies

ACT:vr
Attachments


Mr. Angelo Giambusso
Page 3
May 9, 1975

A. C. THIES, being duly sworn, states that he is Senior Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Atomic Energy Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.




A. C. Thies
A. C. Thies, Senior Vice President

ATTEST:


John C. Goodman, Jr.
Assistant Secretary

Subscribed and sworn to before me this 9th day of May, 1975.


Edna B. Farmer
Notary Public

My Commission Expires:

October 24, 1977