

JUN 19 1973

10/17
Note to File:

TELECON WITH CANADY, COTTON, MILLER OF DUKE POWER - JUNE 15, 1973

The purpose of the telecon was to review the status of commitments made by Duke during the Unit 2/3 OL review. According to Duke the status is as follows:

1. Reports covering vibration tests performed on pipes and components during plant operation in Oconee Unit 1 will be completed for AEC review by August 1, 1973.
2. The plan for using seismic data acquired at the plant is being developed now and will be available prior to Unit 2 operation.
3. Analysis of structural capability of the steam generator subcompartment will be made available to the AEC the week of the 25th of June.

I. A. Peltier
I. A. Peltier, Project Manager
Pressurized Water Reactors
Branch No. 4
Directorate of Licensing

cc: ASchwencer
RCDeYoung

11/20/73
8001130 064

A