

**Florida
Power**
CORPORATION

March 24, 1980

File: 3-0-3-a-3

Mr. Robert W. Reid
Chief
Operating Reactors Branch #4
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Commitments - During March 18, 1980 Meeting

Dear Mr. Reid:

During Florida Power Corporation's meeting with you, Tuesday, March 18, 1980, you requested a letter committing to compliance with three (3) specific items. The purpose of this letter is to formally transmit to you our commitment to those three (3) items, stated in Attachment 1, discussed during the meeting.

Details as to how Florida Power Corporation will satisfy the attached commitments were provided by letter to Mr. Harold R. Denton, dated March 12, 1980, from Mr. J. A. Hancock.

Should you have any questions concerning this matter, please contact this office.

Very truly yours,

FLORIDA POWER CORPORATION

R. M. Bright
Acting Manager
Nuclear Support Services


Attachment

RMBhewR01(D1)

8003240391


STATE OF FLORIDA
COUNTY OF PINELLAS

R. M. Bright states that he is the Acting Manager, Nuclear Support Services, of Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information and belief.



R. M. Bright

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 24th day of March, 1980.



Notary Public

Notary Public, State of Florida at Large,
My Commission Expires: August 8, 1983

CameronNotary 3(D12)

ATTCHMENT 1

1. Actions which will allow the operator to cope with various combinations of loss of instrumentation and control functions. This includes changes in (A) equipment and control systems to give clear indications of functions which are lost or unreliable; and (B) procedures and training to assure positive and safe manual response by the operator in the event that competent instruments are unavailable.

Response:

Florida Power Corporation commits to accomplish this item prior to the restart of Crystal River Unit 3.

2. Verification of the effects of various combinations of loss of instrumentation and control functions by design review analysis and by test.

Response:

Florida Power Corporation commits to accomplish this item prior to the restart of Crystal River Unit 3.

3. Correction of electrical deficiencies which may allow the power operated relief valve and pressurizer spray valve to open on non-nuclear instrumentation power failures, such as, the event which occurred at Crystal River Unit 3 on February 26, 1980.

Response:

Florida Power Corporation commits to accomplish this item prior to the start of Crystal River Unit 3.