

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M D C C N 2 2 0 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 \_\_\_\_\_ 5  
7 8 9 14 15 25 26 30 57 CAT 58  
 LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE      CAT 58

CON'T  
01 REPORT SOURCE L 6 0 5 0 0 0 3 1 3 7 0 5 1 2 8 0 8 0 6 0 2 8 0 9  
7 8 60 61 68 69 74 75 80  
 DOCKET NUMBER      EVENT DATE      REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING STEADY STATE OPERATION, AT 1305 IT WAS DISCOVERED THAT THE PLANT  
03 COMPUTER HAD FAILED. THE COMPUTER WAS DECLARED INOPERABLE PER T.S. 3.3.3.2.  
04 THE EXCORE NUCLEAR INSTRUMENTATION SYSTEM REMAINED OPERABLE DURING THE  
05 EVENT. THE COMPUTER WAS RETURNED TO SERVICE AT 1345. THIS IS NOT A REPETITIVE  
06 EVENT.  
07 \_\_\_\_\_  
08 \_\_\_\_\_

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
R B X Z Z Z Z Z Z Z Z  
9 10 11 12 13 18 19 20  
 SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
8 0 0 2 8 0 3 L 0  
21 22 23 24 26 27 28 29 30 31 32  
 LER/RO REPORT NUMBER      EVENT YEAR      SHUTDOWN METHOD      HOURS      ATTACHMENT SUBMITTED      NPRD-4 FORM SUB.      PRIME COMP SUPPLIER      COMPONENT MANUFACTURER  
X Z Z 0 0 0 0 0 0 0 N Z Z 9 9 9 9  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 DURING MAINTENANCE OF THE COMPUTER CRT UPON CONNECTING THE TEST EQUIPMENT A  
11 NOISE SPIKE WAS GENERATED TO THE I/O POWER SUPPLY. THIS WAS SENSED BY THE  
12 COMPUTER AS AN I/O POWER FAILURE WHICH RESULTED IN A COMPUTER SHUTDOWN. RESTART  
13 OF THE COMPUTER WAS CONDUCTED BY THE BOOTSTRAP METHOD. NO FURTHER CORRECTIVE  
14 ACTION IS REQUIRED.

FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
15 E 1 0 0 0 NA A OPERATOR OBSERVATION  
7 8 9 10 12 13 44 45 46 80

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
16 Z Z NA NA  
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
17 0 0 0 Z NA  
7 8 9 11 12 13 80

PERSONNEL INJURIES NUMBER DESCRIPTION 41  
18 0 0 0 NA  
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
19 Z NA  
7 8 9 10 80

PUBLICITY ISSUED DESCRIPTION 45 NRC USE ONLY  
20 N NA  
7 8 9 10 68 69 80

NAME OF PREPARER J. S. LAGIEWSKI/L. S. HINKLE PHONE: (301)269-4747/4749

8008050045

GPO W 7-926