DOCKET NO. 50-269

DUKE POWER COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The Nuclear Regulatory Commission (the Commission) is considering the issuance of an amendment to Facility Operating License No. DPR-38, issued to Duke Power Company (the licensee) for operation of the Oconee Nuclear Station, Unit No. 1 (the facility), located in Oconee County, South Carolina.

The amendment would increase the flux/flow trip setpoint of the Reactor Protective System from 1.055 to 1.07. This increase results from the elimination of the reactor internals vent valve flow penalty which the Commission has determined to no longer be required.

Prior to issuance of the proposed license amendment, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

By August 16, 1976 the licensee may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendment to the subject facility operating license. Petitions for leave to intervene must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action.

Such petitions must be filed in accordance with the provisions of this

FEDERAL REGISTER Notice and Section 2.714, and must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555 and to Mr. Troy B. Conner, Conner & Knotts, 1747 Pennsylvania Avenue, NW., Washington, D.C. 20006, the attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or licensing board designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate order issued regarding the disposition of the petitions.

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendment dated June 11, 1976 which is available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D.C., and at the Oconee County Library, 201 South Spring Street, Walhalla, South Carolina.

Dated at Bethesda, Maryland, this 9th day of July 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Chief

Operating Reactors Branch #1 Division of Operating Reactors



NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

July 9, 1976

Docket No. 50-2-2009

Duke Power

ATTN:

William O. Parker, Jr.

President

Am Production

Box 2178

A22 Sound

North Carolina 28242

Gentlemme-

The Community of the Enclosed "Notice of Proposed Issuance of Register publication. This notice relates to your request dated revise to your request dated revise to your set of the Reactor Protective System.

Sincerely,

A. Schwencer, Chief Operating Reactors Branch #1 Division of Operating Reactors

Enclosure: Federal Register Notice

cc w/enclosure: See next page

dupe acceding

cc: Mr. William L. Porter

Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. Troy B. Conner Conner & Knotts 1747 Pennsylvania Avenue, NW Washington, D. C. 20006

Oconee Public Library 201 South Spring Street Walhalla, South Carolina 29691

DOCKET NO. 50-269

DUKE POWER COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The Nuclear Regulatory Commission (the Commission) is considering the issuance of an amendment to Facility Operating License No. DPR-38, issued to Duke Power Company (the licensee) for operation of the Oconee Nuclear Station, Unit No. 1 (the facility), located in Oconee County, South Carolina.

The amendment would increase the flux/flow trip setpoint of the Reactor Protective System from 1.055 to 1.07. This increase results from the elimination of the reactor internals vent valve flow penalty which the Commission has determined to no longer be required.

Prior to issuance of the proposed license amendment, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

By August 16, 1976 the licensee may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendment to the subject facility operating license. Petitions for leave to intervene must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action.

Such petitions must be filed in accordance with the provisions of this

dupe of edine

FEDERAL REGISTER Notice and Section 2.714, and must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555 and to Mr. Troy B. Conner, Conner & Knotts, 1747 Pennsylvania Avenue, NW., Washington, D.C. 20006, the attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or licensing board designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate order issued regarding the disposition of the petitions.

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.