NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S C N E E I (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 6 9 (7) | 0 6 0 4 7 8 (8) | 0 7 0 3 7 0 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1340 on June 4, 1978, breaker PCB-17 and -18 tripped without apparent cause
03 | The breaker trips took startup transformer, CT1, out of service. Since the
04 | backup transformer was available on manual and both Keowee units were capable
05 | of supplying emergency power, no loss of emergency power sources was exper-
06 | ienced. Thus, public health and safety were not endangered.
07 |
08 |

09 | SYSTEM CODE C B (11) | CAUSE CODE X (12) | CAUSE SUBCODE X (13) | COMPONENT CODE C K T B R K (14) | COMP. SUBCODE A (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 — SEQUENTIAL REPORT NO. 0 1 5 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER 1 0 0 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | No cause or appropriate corrective action has bee. determined. The breakers
11 | and related circuitry were checked but no abnormalities were identified.
12 |
13 |
14 |

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

17 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES

18 | NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (42)

19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY

20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER K. R. Wilson PHONE: (704) 373-8197

7912110611