

08/07/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-270

REC: OREILLY J P
NRC

ORG: ~~OREILLY~~ **Pagke, W.O.**
DUKE FWR

DOC DATE: 07/28/78
DATE RCVD: 08/04/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED
LTR 1 ENCL 1

SUBJECT:
FORWARDING LICENSEE EVENT REPT (RO 50-270/78-009) ON 06/27/78 CONCERNING
CONTROL ROD 6 GROUP 4 WAS FOUND TO HAVE A SHORT IN THE CRD STARTOR WHICH
WOULD PRECLUDE NORMAL POWERED MOVEMENT. . . SHORT PROBABLY CAUSED BY
POSITION. . . W/ATT.

PLANT NAME: OCONEE - UNIT 2

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: OL

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

1. M. CUNNINGHAM - ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ORB#4 BC**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
NIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL:

LFDR'S
WALHALLA, SC**W/ENCL
TIC, LIZ CARTER**W/ENCL
NSIC**W/ENCL
ACRS CAT 3**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+2P+1P

CONTROL NBR: ~~782180027~~

THE END

8001130/40

AP/4
S R

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

July 28, 1978

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE AREA 704
373-4083


Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

RE: Oconee Unit 2
Docket No. 50-270

Dear Mr. O'Reilly:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station
Technical Specifications, please find attached Reportable Occurrence
Report RO-270/78-9.

Very truly yours,



William O. Parker, Jr.

Attachment

cc: Director, Office of Management Information
and Program Control

~~782160027~~

402
5/1