

JUN 9 1972

Docket No. 50-270  
50-287

I. A. Peltier, FWR Branch #4, L  
THRU: D. Thompson, Chief, OSB, L

REVIEW OF RESPONSE TO QUESTIONS FOR THE OCONEE NUCLEAR STATION UNITS 2 & 3

I have reviewed the responses to our questions, submitted by Duke Power as Revision 20 to the FSAR for Oconee 2 & 3, dated May 25, 1972. The responses are satisfactory except as noted below.

- 12.1 The answer to this question is unclear. If the term "checkout phase" refers to that time commencing with fuel loading, the response is unsatisfactory. One SRO will be required for each unit.
- 12.4 The applicant should state his intention to pursue obtaining written agreements with all of the offsite organizations listed in section 12.3.2.3(c).
- 12.6 Answer unsatisfactory. If the Shift Supervisor is to assume responsibility for the protection of the general public in the first critical hours following an emergency, then the action levels presented in 12.3.2.7.2(b) must be more conservative.
- 12.7 Answer unsatisfactory. During the period of initial operation of each unit, the General Office Review Committee should meet no less frequently than once per calendar quarter.
- 12.8 Answer unsatisfactory. (A meeting to discuss minimum shift staffing is to be held on June 15).

*104*  
C. R. Van Niel  
Operational Safety Branch, L

cc: D. F. Knuth, L  
A. Schwencer, L

POOR ORIGINAL

OFFICE ▶	L:OSB <i>CR</i>	L:OSB <i>DT</i>				
SURNAME ▶	CRVan Niel:cl	DThompson				
DATE ▶	6/8/72	6/8/72				

8001130145 A