



ATOMIC POWER COMPANY •

Box 450, RFD 2  
Wiscasset, Maine 04578

June 4, 1980

United States Nuclear Regulatory Commission  
Directorate of Regulatory Operations  
Region I  
613 Park Avenue  
King of Prussia, Pennsylvania 19406

Reference: License No. DPR-36 (Docket No. 50-309)

Dear Sir:

Subject: Maine Yankee Reportable Occurrence #80-014/01T-0

Pursuant to the requirements of Technical Specifications 5.9.1.6.i, the Maine Yankee Atomic Power Company hereby submits the following report.

Preliminary results from the vessel wall irradiated surveillance capsule indicates a considerably higher  $RT_{NDT}$  shift than originally predicted. These results are from the Charpy V-notch impact data only as the dosimetry data will not be completed for approximately 30 days.

As a conservative measure Maine Yankee is presently revising the appropriate heat up and cooldown curves to reflect the preliminary findings and will operate using the revised curves until all data is available. Final revision of these curves will be made after the analysis is complete.

Based on the telephone conversation between Mr. T. Martin and Mr. D. E. Moody on June 4, 1980, it is understood that the 14 day follow-up report has been waived to allow time for the dosimetry data to be received. The follow-up report will be forwarded when all data is received and an evaluation made. This is expected to be complete in approximately 30 days.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

*Edwin C. Wood*

Edwin C. Wood  
Plant Manager

A002  
5/10

ECW/ds

80061103345