

50-269

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO: Norman C. Moseley

FROM: Duke Power Co.
Charlotte, N.C. 28242
William O. Parker, Jr.

DATE OF DOCUMENT

1-20-77

DATE RECEIVED

2-2-77

☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 signed org.

DESCRIPTION

Ltr. Trans The Fo
Ltr. Trans The Following:

(1 page)

ENCLOSURE

Licensee Event Report (RO-50-269)
77-1 on 1-4-77 concerning exhaust fan discharge
valve LPR-19 found inoperable in the Reactor
Building penetration room due to dirty auxilli-
ary contact on magnetic contactor "M" of the
Motor Control Center (MCC) which energized
valve LPR-19.....(1 encl rec'd)
(1 page)

PLANT NAME: OCONEE UNIT # 1

DO NOT REMOVE
ACKNOWLEDGEDNOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

JCM 2-4-77

☒ BRANCH CHIEF: SCHWENCER

W/3 CYS FOR ACTION

☒ LIC. ASST.: SHEPPARD

W/1 CYS

☒ ACRS 16 CYS HOLDING/SENT Cat "B" on 2-4-77

INTERNAL DISTRIBUTION

☒ REG FILE
☒ NRC PDR
☒ I & E (2)
☒ MIPC
☒ SCHROEDER/IPPOLITO
☒ HOUSTON
☒ NOVAK/CHECK
☒ GRIMES
☒ CASE
☒ BUTLER
☒ HANAUER
☒ TEDESCO/MACCARY
☒ EISENHUT
☒ BAER
☒ SHAO
☒ VOLLMER/BUNCH
☒ KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

☒ LPDR: Wabhalia, SC
☒ TIC:
☒ NSIC:

CONTROL NUMBER

1217
7912 100 5355

DUKE POWER COMPANY
Regulatory Docket File
POWER BUILDING
122 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 20, 1977

Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 1
Docket No. 50-269

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report RO-269/77-1.

Very truly yours,

W. O. Parker, Jr.

William O. Parker, Jr. *By [Signature]*

LJB:ge
Attachment

cc: Director, Office of Management Information
and Program Control

