

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO:
Mr. Norman C. Moseley

FROM:
Duke Power Company
Charlotte, NC
William O. Parker, Jr.

DATE OF DOCUMENT

7/13/77

DATE RECEIVED

8/1/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

DESCRIPTION

ENCLOSURE

Licensee Event Report #RO 50-269/77-20 on 6/28/77 concerning 125 VDC switching station battery charger failure; associated battery subsequently determined inoperable.

DO NOT REMOVE

PLANT NAME:

Oconee Nuclear Station
VT 8/2/77

(1-P)(2-P)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

BRANCH CHIEF:
W/ 3 CYS FOR ACTION
LIC ASST.:

INTERNAL DISTRIBUTION

REG FILE
REC PDR
I & E (2)
MIPC
SCHROEDER/IPPOLITO
HOUSTON
NOVAK/CHECK
GRIMES
KNIGHT
BUTLER
HANAUER
TEDESCO
EISENHUT
BAER
SHAO
VOLLMEYER/BUINCH
KREGER/ J. COLLINS
ROSA

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR:
TIC:
NSIC:
ACRS (16) SENT AS CAT. B

7/9/77 12100569

772140276

5

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

July 13, 1977

TELEPHONE AREA 704
373-4083

Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 1
Docket No. 50-269

Regulatory

ENR-573

par

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report RO-269/77-20. This report is submitted one day late as discussed in conversations with your staff.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr. *By [Signature]*

MST/rr

Attachment

cc: Director, Office of Management Information
and Program Control

772140275