

February 8, 1978

DISTRIBUTION

- Dockets
- NRC PDRs
- LOCAL PDR
- ORB#1 Reading
- VStello
- KRGoller
- JCGough
- ASchwencer
- DNeighbors
- SMSheppard
- DEisenhut
- OIUE&3(
- OELD
- BJones
- TBAbernathy
- JRBuchanan
- ACRS(16)

Docket Nos. 50-269
50-270
and 50-287

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President - Steam Production
Post Office Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

This confirms our telephoned authorization given today, February 8, 1978, for a change in Technical Specifications for the Oconee Nuclear Station as requested by your telecopy on February 8, 1978. Facility Operating License Nos. DPR-38, DPR-47 and DPR-55 are amended on this date by making the following Technical Specification change:

The following sentence to be added to Section 3.3.5 to read:

"In the case of Reactor Building Spray valve 3BS2, 72 consecutive hours are allowed to return the valve to operable status on a one time basis only; this 72 hour allowance shall expire on February 10, 1978."

Copies of the license amendments, our evaluation and Federal Register Notice for this Technical Specification change will be sent to you when completed.

Sincerely,

Original signed by ASchwencer

for/ Karl R. Goller, Assistant Director
for Operating Reactors
Division of Operating Reactors

cc: See next page

POOR ORIGINAL

OFFICE →	DOR:ORB#1 N	DOR:ORB#1b	DOR:ORB#1c		
SURNAME →	DNeighbors: 1b	ASchwencer	KRGoller		CPI
DATE →	2/3/78	2/8/78	2/8/78		dr

February 8, 1978

cc: Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

J. Micheal McGarry, III, Esquire
DeBevoise & Liberman
700 Shoreham Building
806-15th Street, NW.,
Washington, D.C. 20005

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691

Honorable James M. Phinney
County Supervisor of Oconee County
Walhalla, South Carolina 29621

Chief, Energy Systems
Analysis Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, S. W.
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N. E.
Atlanta, Georgia 30308

Chrys Baggett
State Clearinghouse
Division of Policy Development
116 West Jones Street
Raleigh, N.C. 27603