

DOCKET NO: 50-270

UNIT: Oconee Unit 2

DATE: 05-15-78

NARRATIVE SUMMARY

MONTH: April, 1978

Oconee 2 began the month of April at near rated power. On 4/6 the unit was removed from service because of valve packing leakage on the RC system. After a complete cooldown and inspection, valves 2RC-2 AND 2RC-3 were repacked. During heatup another leak was noted during a leak check of the Reactor Building. The leak was coming from an O-ring seal on the middle heater bundle of the pressurizer which required a cooldown and draining for repair. The unit was returned to service on 4/25 and after necessary holds reached near rated power level on 4/28 and continued through the month's end.

7912170588

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2.
2. Scheduled next refueling shutdown: December 3, 1978.
3. Scheduled restart following refueling: January 21, 1979.
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes.
If yes, what will these be? Amendment to incorporate technical specifications for Oconee Nuclear Station Unit 2 Cycle 4.

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? _____.
If no, when is review scheduled? _____.
5. Scheduled date(s) for submitting proposed licensing action and supporting information: October 15, 1978.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures). _____

_____.
7. Number of fuel assemblies (a) in the core: 177.
(b) in the spent fuel pool: 141.
8. Present licensed fuel pool capacity: see Oconee Unit #1.
Size of requested or planned increase: see Oconee Unit #1.
9. Projected date of last refueling which can be accommodated by present licensed capacity: 3/3/80.

DUKE POWER COMPANY

Date: May 15, 1978.

Name of Contact: J. A. Reavis.

~~7012170~~ 588