

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
NuScale Subcommittee Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, July 9, 2019

Work Order No.: NRC-0434

Pages 1-152

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

NUSCALE SUBCOMMITTEE

+ + + + +

TUESDAY

JULY 9, 2019

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B10, 11545 Rockville Pike, at 1:00 p.m., Joy Rempe,
Chair, presiding.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

COMMITTEE MEMBERS:

- JOY L. REMPE, Member
- CHARLES H. BROWN, JR. Member
- DENNIS BLEY, Member
- MICHAEL L. CORRADINI, Member
- VESNA B. DIMITRIJEVIC, Member
- WALTER L. KIRCHNER, Member
- JOSE MARCH-LEUBA, Member
- PETER RICCARDELLA, Member
- GORDON R. SKILLMAN, Member
- MATTHEW SUNSERI, Member

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

- CHRISTOPHER BROWN
- MICHAEL SNODDERLY

1 ALSO PRESENT:

2 CLINTON ASHLEY, NRO

3 PETER BAMFORD, NRR

4 TOM BERGMAN, NuScale

5 KEVIN COYNE, NRO

6 RAUL HERNANDEZ, NRO

7 NADJA JOERGENSEN, NuScale

8 REBECCA KARAS, NRO

9 CHRIS MAXWELL, NuScale

10 RYAN NOLAN, NRO

11 OMID TABATABAI, NRO

12 DINESH TANEJA, NRR

13 ANDREA VEIL, ACRS

14 ROBERT VETTORI, NRO

15 SCOTT WEBER, NuScale*

16 ROBERT WEISMAN, OGC

17

18 *Present via telephone

19

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A G E N D A

Opening Remarks 5

Overview of Chapter 20, "Mitigating Strategies
for Beyond Design-Basis External Events,"
NuScale Design Certification Application

 NuScale 9

 NRO Staff 76

Public Comments 135

Discussion 141

Adjourn 152

P R O C E E D I N G S

1:05 p.m.

1
2
3 CHAIR REMPE: This meeting will now come
4 to order. This is a meeting of the Advisory Committee
5 on Reactor Safeguards NuScale Subcommittee. I'm Joy
6 Rempe, Chair of the NuScale Subcommittee.

7 Members in attendance today include Vesna
8 Dimitrijevic, Dennis Bley, Jose March-Leuba, Charlie
9 Brown, Walt Kirchner, Pete Riccardella, Mike
10 Corradini, Dick Skillman. We also have our
11 consultant, Steven Schultz here with us today.

12 The purpose of today's meeting is for the
13 Subcommittee to receive a briefing on staff
14 evaluations of Chapter 20, mitigating strategies for
15 beyond design basis external events in the NuScale
16 design certification application. Today, we have
17 members of the staff and NuScale to brief the
18 Subcommittee.

19 Before I continue with our standard ACRS
20 subcommittee opening remarks, I want to make some
21 comments here. The ACRS review of this topic's going
22 to be a bit different than we originally planned. A
23 couple of weeks ago, NuScale notified our designated
24 federal officials that they'd like to present this
25 material at the July full committee meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the DFOs checked with the staff, and
2 they'll also be presenting tomorrow. So there's the
3 potential that we may complete our review of this
4 topic and write a letter this week.

5 And in fact, I have prepared a very draft
6 letter with some background information regarding this
7 topic, essentially what topics are addressed by
8 NuScale in the Chapter 20. And how their strategies
9 for beyond design basis events differ from other
10 applications we reviewed and the staff review
11 findings, and some preliminary thoughts that we may
12 want to discuss today. But I'm going to need your
13 help on this.

14 So at the end of this meeting, I'd like to
15 request your thoughts on two items. First, shall we
16 try and write a letter on this topic this month? And
17 we can recommend and at the beginning of the full
18 committee meeting that the letter would be completed
19 in September.

20 And then if we do decide to go forward
21 with the letter this month or even in September, I'd
22 like your input for my draft letter on what should be
23 included in this topic. And it would help if you'd
24 send it tonight sometime, okay.

25 So let's go back to the standard

1 information that I'm supposed to say at the beginning
2 of Subcommittee meetings. The ACRS was established by
3 statute and it's governed by the Federal Advisory
4 Committee Act, or FACA. That means that the committee
5 can only speak through its published letter reports.
6 And we hold meetings to gather information to support
7 our deliberations.

8 Interested parties who wish to provide
9 comments can contact our office requesting time. And
10 that said, we also set aside ten minutes for comments
11 from members of the public attending or listening to
12 our meetings. And written comments are also welcome.
13 The meeting agenda for today was published on the
14 NRC's public meeting notice website, as well as our
15 ACRS meeting website.

16 And on the agenda for this meeting, as
17 well as on the meeting, the ACRS website, instructions
18 on how the public can participate. It's my
19 understanding, unless Kathy tells me differently, that
20 there's been no requests for making a public statement
21 from the public at this meeting.

22 And we may close this meeting after the
23 open portion to discuss proprietary material, and
24 presenters can defer questions that should not be
25 answered in the public session to that time. And if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we start asking things we shouldn't, please speak up
2 and tell us to hold off, okay.

3 A transcript of the meeting is being kept
4 and will be made available on our website. And
5 therefore we do request that participants in this
6 meeting use the microphones located throughout the
7 meeting room in addressing the Subcommittee, and the
8 participants should first identify themselves and
9 speak with sufficient clarity and volume that they can
10 be readily heard.

11 We have a bridge line established for the
12 public to listen to this meeting, and to minimize
13 disturbance, the public line will be kept in a listen-
14 in only mode. And to avoid disturbance, I request
15 that attendees, especially members, put their
16 electronic devices, such as cellphones, in the off or
17 noise-free mode.

18 And now we're going to begin with the
19 meeting. Does the NRC staff have any introductory
20 remarks that they wish to make?

21 MR. COYNE: Kevin Coyne, NRO. We can make
22 it just part of the staff presentation after the
23 break.

24 CHAIR REMPE: Okay, so then I'm going to
25 ask NuScale to begin today's presentations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. JOERGENSEN: Thank you. We're here
2 today to present NuScale SR Chapter 20, which is the
3 mitigation of beyond design basis events. With me
4 here I have Chris Maxwell, Senior Reactor Operator,
5 and myself, Nadja Joergensen. I'm a Licensing
6 Specialist.

7 MR. MAXWELL: Good afternoon. The new
8 rule, 10 CFR 50.155, is separated into a requirements
9 section for mitigational strategies for beyond design
10 basis external events, which is covered under
11 paragraph B1, and into requirements specific for spent
12 fuel pool level indication, which is addressed by
13 paragraph E. And we're going to start today's
14 discussion with the mitigation strategies.

15 The new rule is written to consider a
16 damaged state that results in an extended loss of AC
17 power and ELAP concurrent with a loss of normal access
18 to the ultimate heat sink, or for a passive design
19 such as NuScale's, a loss of normal access to the
20 normal heat sink.

21 The objective of the rule is to establish
22 sufficient coping capabilities to prevent fuel damage
23 in both the reactors and the spent fuel pool, and to
24 maintain the containment function by using installed
25 plant equipment and supplemental mitigating equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As such, the three key safety functions of
2 core cooling, containment, and spent fuel pool cooling
3 are required to be established and maintained
4 indefinitely, or until sufficient site functional
5 capabilities can be maintained without the need for
6 mitigational strategies.

7 That phrase indefinitely or until
8 sufficient site functional capabilities can be
9 maintained without the need for mitigation strategies
10 is described to mean that the licensee needs to plan
11 for obtaining sufficient resources to maintain the
12 three key safety functions until an alternate means of
13 heat removal is established.

14 Additionally, the new rule allows for new
15 reactors to establish different approaches from those
16 of operating reactors, including using only installed
17 plant equipment for both the initial and the long-term
18 response. Therefore it follows that the phrase
19 alternate means of removing heat may be provided by
20 installed plant equipment.

21 To evaluate the NuScale power plant coping
22 capability, it's necessary to establish what a minimum
23 installed coping duration is. NuScale considers a
24 coping period of 14 days using only installed plant
25 equipment to be sufficient time to establish the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 alternate means of removing heat.

2 The basis for this duration is the
3 operating experience of the Fukushima event, where,
4 without the benefit of a pre-planned strategy or a
5 hardened pool makeup line, the access to the site
6 limited by the earthquake and tsunami, personnel were
7 able to begin injecting to the spent fuel pool after
8 nine days using offsite resources and injecting the
9 spent fuel pool using installed plant equipment at 14
10 days.

11 Beyond that point, beyond the minimum
12 installed equipment coping period, the continued use
13 of installed plant equipment, as well as ad hoc
14 resources and repairs to plant equipment, can be used
15 to continue coping indefinitely.

16 MEMBER BLEY: Can I ask you a question?

17 MR. MAXWELL: Yes, sir.

18 MEMBER BLEY: Much of the arguments I've
19 read in the FSAR show how your built-in capabilities
20 are adequate for most of these requirements. So it
21 doesn't look like you're recommending to a future COL
22 applicant that they participate in SAFER because it
23 doesn't sound like you think it'd be necessary.

24 Are you providing those standard hook-ups
25 that say for uses, so if you need to get equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from, you might get it from another nearby plant, so
2 it would be easy to hook it up?

3 MR. MAXWELL: Yes, sir, we are. What we
4 have, beyond what we'll be talking about today, we
5 have the standard equipment you would see as far as we
6 backup diesel generators, two of them independent from
7 one another that can provide power to our battery
8 chargers and our highly reliable DC power system and
9 to our instrumentation.

10 We have temporary or temporary connections
11 to those same busses provided by the diesel generators
12 for an offsite generator that's --

13 MEMBER BLEY: And that's the connections
14 I was asking about. Are they going to be the standard
15 ones that are --

16 MR. MAXWELL: Yeah, they're --

17 MEMBER BLEY: All the other plants are
18 using now?

19 MR. MAXWELL: That's correct. We can
20 bring a portable, the design includes connections for
21 portable generators.

22 MEMBER BLEY: Okay.

23 MR. MAXWELL: It also includes a hardened
24 vent, seismically qualified, assured makeup line to
25 the ultimate heat sink for, a gravity feed to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spent fuel pool. While all those capabilities are
2 provided to meet the requirements, they're not
3 required.

4 MR. SCHULTZ: So excuse me, so what does
5 that mean in terms of what Dr. Bley was discussing in
6 terms of the guidance that you anticipate providing to
7 the COL applicant?

8 MR. MAXWELL: Well, there's -- the COL and
9 the operator are going to have requirements to perform
10 task analysis on their systems and develop procedures
11 associated with it. There won't be a requirement
12 specifically for procedures for mitigating beyond
13 design basis event, because no operator actions are
14 required specifically to mitigate the event.

15 You still, you know, I like to think of
16 this as two separate items. There is the responding
17 to the event itself, the ELAP and the current loss of
18 access to the ultimate, to the normal heat sink, and
19 the plant response to that through installed safety-
20 related plant equipment.

21 Then there's what the operators are going
22 to be doing. And the benefit of the plant responding
23 to the strategy or to the event and maintaining the
24 three key safety functions is that the operators have
25 been freed up to use the exiting procedures to try to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 restart their backup diesel generators or to hook up
2 a temporary generator if necessary to respond to the
3 initiating event itself, rather than to be focused on
4 establishing and maintaining the three key safety
5 functions.

6 So they will use their processes as
7 required for operations to develop their procedures
8 for hooking up that equipment and repowering the
9 busses. Items like starting the backup diesel
10 generators is not unique to mitigating a beyond design
11 basis event. It's a procedure that will exist, a
12 standard operating procedure or an abnormal procedure
13 that will exist for the plant that it would use in the
14 situation.

15 MR. SCHULTZ: But let's presume that there
16 is a fleet of these facilities. Then you would
17 anticipate that there'd be some common direction given
18 so that the fleet of NuScale facilities are going to
19 be following the same process and procedure. And if
20 there is, if there is a safer type of an approach, or
21 a common approach taken, that in fact it is a common
22 approach.

23 MR. MAXWELL: Yes, sir, and --

24 MR. SCHULTZ: For the NuScale industry,
25 whatever you want to call that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAXWELL: Right, and again, I'm back
2 to the separation of whatever the initiating event is,
3 it's a loss of all power, all AC power, they're safe.
4 There will be a procedure to respond to the loss of
5 all AC power. So it's not specific to a mitigating
6 beyond design basis event, it's specific to the
7 initiator.

8 So there will be a procedure that is an
9 abnormal procedure to respond to that that directs the
10 action, such as starting up backup diesel generators
11 or getting our auxiliary AC power source available to
12 provide site power.

13 If it's a seismic event, there'll be an
14 abnormal procedure to respond to seismic events. If
15 it's flooding, you would expect a abnormal procedure
16 to respond to a flooding event. So again, the
17 operators are freed up to address those initiating
18 events and respond to them and to restore power,
19 rather than to focus on the key safety functions.

20 And there's not a need for specific
21 procedures dedicated to that. There's not a, in the
22 days of old were called FLEX procedures. There's not
23 a need for that because the installed plant equipment
24 responds to establish and maintain the three key
25 safety functions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULTZ: Okay, thank you.

2 MR. MAXWELL: Sure. So now I'd like to
3 discuss the evaluation of the NuScale design coping
4 capability and to describe those capabilities.

5 As you're aware, the NuScale power plant
6 design was informed by the Fukushima accident and
7 sought to provide coping during an ELAP without AC or
8 DC electrical power, without a need for inventory
9 addition or supplemental onsite equipment, without the
10 use of offsite resources, and without any operator
11 actions and therefore any required operator
12 monitoring.

13 In short, the design provides extended
14 coping by establishing and maintaining three key
15 safety functions by the automatic response of
16 installed plant equipment alone. As I just alluded
17 to, the strategy provides a significant advantage of
18 permitting the plant staff to focus on addressing the
19 initiating events, rather than focusing on deploying
20 supplemental equipment or procedures, to maintain just
21 the three key safety functions.

22 To evaluate the power plant's baseline
23 coping capability, it's necessary to establish some
24 coping criteria as well as the initial conditions,
25 assumptions, and the boundary conditions. For this,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NuScale used existing industry guidance as previously
2 endorsed by the NRC.

3 And they include that plant equipment that
4 is designed to be robust with respect to design basis
5 external events is assumed to be fully available,
6 while plant equipment that's not robust is assumed to
7 be unavailable.

8 The procedures and equipment relied upon
9 should ensure the satisfactory performance of
10 necessary fuel cooling and containment functions are
11 maintained and that the fuel in, both the modules and
12 the spent fuel pool is required to remain covered at
13 all times.

14 CHAIR REMPE: So I'd like to stop you for
15 a minute. You keep referring to the insights from
16 Daiichi. And if you read some of the operator
17 interviews, they make the comment because they didn't
18 have instrumentation due to the loss of power, it was
19 like flying an airplane blind.

20 And now you're talking about monitoring
21 the plant, that things are going as planned, and you
22 actually have in Rev. 1 of this technical report you
23 submitted saying that the ECCS components, including
24 instrumentation, are environmentally qualified for the
25 moisture chemistry and radioactivity of expected

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 environments, and it goes on about that.

2 And if I look at the table you provided,
3 you do have the water level, so I have a question
4 about the radioactivity levels. Are you going to do
5 fluence? Again, we, and I can say radar-based water
6 levels since they're here because we've established
7 now that's in the open literature. But I'm not sure
8 of the details of it.

9 But some of them actually if you have some
10 types of monitors, they tried to do this in the past,
11 they suffer from darkening from fluence levels. And
12 I'm not sure if that's going to be in your design or
13 not, but that's something I'm concerned about.

14 And then if I were an operator I'd, since
15 you're kind of putting the water back and forth
16 between the reactor vessel and the containment, I
17 really would like to know what the containment water
18 level is to make sure things are going as planned, and
19 that's not one of the key components that's in the
20 table about the containment. You just have other
21 components in the containment.

22 So I'm curious on why you didn't include
23 the containment water level too as a key component.
24 Because I think I would want to know as much as
25 possible of what's going on, especially if you had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some sort of event where you went back and got re-
2 critical again and you're going to flood up your
3 containment. It seems like that.

4 So I have questions about why didn't you
5 include the water level for the containment, and then
6 the radioactivity levels and how you're going to
7 qualify it. Because again, this is kind of going out
8 to the future, and it's going to be I guess an ITAAC
9 or something about this first of a kind application
10 for water level measurements.

11 And I want to know if it's going to be
12 looking at not just the heat, the neutron flux, but
13 also the total fluence. Are you going to go for,
14 sometimes I see 30 days or something like that? Or
15 how long are you going to qualify this for, and is
16 that going to be specified somewhere?

17 MR. MAXWELL: I'll ask if Brian Gardes is
18 on the line from NuScale. I don't have Brian now, but
19 I will.

20 CHAIR REMPE: They were supposed to be
21 open, but.

22 MEMBER CORRADINI: Can the NuScale folks
23 in Corvalis speak up that your line's open?

24 (Off mic comments.)

25 MR. MAXWELL: Okay, thank you. So as,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we're going to see if Brian can speak to the level
2 instrument specifically. The discussions on the
3 technical report about instrumentation are just some
4 discussions of the instrumentations that would be
5 available to the operators. Containment level will be
6 available for 72 hours to the operators.

7 CHAIR REMPE: It's not in the list of the
8 critical, like there's a table it's going to take me
9 a while to bring it up. But there's a table for
10 what's in the reactor vessel versus what's in the
11 containment. And the containment does not have water
12 level on that table.

13 MR. MAXWELL: Understood, and so what I
14 want to say is that none of those indications are
15 necessary, because installed plant equipment alone,
16 without operator action, without operator monitoring,
17 establishes and maintains the three key safety
18 functions.

19 MEMBER MARCH-LEUBA: ECCS valves open on
20 high water level in the containment.

21 MR. MAXWELL: Not in this event they do
22 not.

23 MEMBER MARCH-LEUBA: Well, then you have
24 to consider, this is available.

25 MR. MAXWELL: ECCS at 24 hours in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 event, the next slide here talks about our boundary
2 conditions. For an ELAP condition, there's a box
3 that's established and some assumptions that are made
4 about the plant response.

5 MEMBER MARCH-LEUBA: But to be able to say
6 with a straight face that you do not rely on AC or DC
7 power, you have to run every combination of AC power
8 on, AC power off, the other way around, DC power going
9 to five holes. You have to run all those
10 combinations.

11 MR. MAXWELL: Absolutely.

12 MEMBER MARCH-LEUBA: And you're relying on
13 DC power to open the ECCS valves.

14 MR. MAXWELL: In 20 -- actually, the
15 module protection system in this event, at 24 hours
16 into the event, de-energizes the --

17 (Simultaneous speaking.)

18 MEMBER MARCH-LEUBA: If you lose AC power.

19 MR. MAXWELL: This event is a loss of AC
20 power.

21 MEMBER MARCH-LEUBA: You rely, for
22 successful completion, you are relying on losing AC
23 power. What if you keep --

24 MR. MAXWELL: I keep AC power?

25 MEMBER MARCH-LEUBA: Yeah.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAXWELL: The event is a loss of AC
2 power. It is the defining --

3 MEMBER CORRADINI: Yeah, I think what, I
4 want to make sure you guys are communicating. I think
5 what Chris is saying is they have a set of going in
6 state assumptions that they have to follow. Am I
7 understanding this correctly?

8 MR. MAXWELL: Yes, sir, that's exactly
9 correct. The event itself is defined as an extended
10 loss of AC power concurrent with loss of normal access
11 to the normal heat sink.

12 And then there's a set of boundary
13 conditions that were established, again, established
14 in industry guidance and endorsed by the NRC, that are
15 the baseline assumptions. Then you start your
16 evaluation of our coping capability with those
17 assumptions.

18 CHAIR REMPE: So I'm going to go back to
19 Section 5.3.2, and it has here, The key safety
20 function of containments is established and maintained
21 for greater than 50 days without operator action.
22 However, the parameters listed in table 5.2 or 5-2,
23 are available to assure the control room operators
24 that the safety-related systems have performed as
25 designed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it has the CIV positions and the wide
2 range containment pressure and the spent fuel pool
3 level. There is nothing in here about containment
4 water level.

5 MR. MAXWELL: I understand that, and what
6 I'm trying to convey is none of those indications are
7 necessary to establish and maintain. However, just
8 for the containment, just addressing the containment
9 function, containment water level is not a key
10 parameter.

11 When that list was developed, it said if
12 I'm just looking at of the three key safety functions,
13 if I'm just evaluating the containment function, what
14 I need to know is a containment pressure. If I'm an
15 operator and I'm, which of course this is not going to
16 happen that the operators just sit back and observe.

17 But if that's what they were doing, then
18 what they would have observed is at the 24-hour mark,
19 when the ECCS valves open, that's when you would reach
20 the peak pressure in containment. So containment
21 pressure is one aspect of containment integrity that
22 they would want to monitor.

23 Early within the first minute, there's a
24 containment isolation. So containment isolation valve
25 position is a key parameter for them to verify that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the safety-related components have performed as
2 designed.

3 CHAIR REMPE: So your point is just that
4 you don't worry about overpressure of the containment,
5 but if I were also trying to worry about the reactor
6 going re-critical, that's not a concern. It's just,
7 okay, you've still got the water level in the reactor
8 vessel and yeah, something's going on with the water
9 going back and forth, but you're not going to worry
10 about trying to flood up the containment or something
11 like that if the reactor --

12 MR. MAXWELL: We will not flood up the
13 containment. Within the boundaries of this event, the
14 containment isolates, all safety-related components
15 operate as designed. There's, of the inventory
16 necessary to maintain core cooling is preserved within
17 the containment.

18 CHAIR REMPE: And you don't worry about
19 any sort of re-criticality occurring for this event.
20 But what if it did occur, you just, that's not part of
21 the scope and you don't have to worry about it.

22 MR. MAXWELL: That's right, the boundary
23 conditions, one of the boundary conditions is that
24 there's no current ATWS, no anticipated transient
25 without scram. All rods insert.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Okay.

2 MEMBER MARCH-LEUBA: A single rod fails?

3 MR. MAXWELL: That's correct. But you
4 remember the scope here, we're talking about a beyond
5 design basis event. So we're in a, like other events
6 where you're not required to stack failures, like a
7 control room evacuation doesn't assume a concurrent
8 LOCA or an ATWS. Similarly, and in the operating
9 fleet and our assumptions is that there isn't a
10 concurrent ATWS with the extended loss of AC power.

11 MEMBER MARCH-LEUBA: It's not an ATWS,
12 it's one rod has too much friction can come in after
13 the earthquake.

14 MR. MAXWELL: We assume all rods insert in
15 this event. The assumption of boundary condition.

16 MEMBER MARCH-LEUBA: Yeah, and I can
17 assume, you can assume a lot of things.

18 MEMBER CORRADINI: But I think what, I'm
19 not taking sides, I just want to make sure we're
20 communicating. Is that they've been given a set of
21 assumed, going in statuses of the various systems,
22 which they then must analyze. Am I understanding this
23 correctly?

24 MR. MAXWELL: Yes, sir.

25 MEMBER RICCARDELLA: And are those the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 same assumptions that the operating fleet uses?

2 MR. MAXWELL: Yeah. We extracted these
3 directly from the existing fleet guidance.

4 CHAIR REMPE: So I'll give you that one
5 for a while I guess. But then what about the fact
6 here for the core cooling parameters when they have 50
7 days and they have the table, the parameters in table
8 5-1, and they have water level as a parameter here?

9 So somehow or other you're going to give
10 us confidence that you don't have any sort of issues
11 for the entire fluence, not just at the radiation
12 levels, as it indicated in the other quote I read
13 earlier. But you're going to also do the fluence on
14 the RPV water level sensors to make sure they're
15 qualified?

16 MR. MAXWELL: I believe I don't have that
17 table in front of me, but if you look, I believe it's
18 broken into two sections, and the first is the
19 verification portion, where the instruments that are
20 used to verify that those conditions have been
21 established.

22 And then the extended duration, what
23 indication the operators could use to verify that the
24 key safety function core cooling is maintained. I'd
25 also say that that's an old revision of the technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 report as well.

2 CHAIR REMPE: I'm actually looking at Rev.
3 1 and there isn't this, it only has parameters for
4 assuring the functions established and the function.
5 So there's just two columns in the table I'm looking
6 at. Do I need to go back to Rev. 0 to see what you're
7 talking?

8 MR. MAXWELL: No, that serves the same
9 purpose. As far as establishing the function, if I
10 heard you correctly, that that's the header for that
11 column, is that when the function is established, the
12 instrumentation exists. Or the power for the
13 instrumentation's assured.

14 CHAIR REMPE: But this has to be for 50
15 days, according to the text.

16 MR. MAXWELL: It's established within 24
17 hours. The Emergency Core Cooling System actuation at
18 24 hours is the last action, automatic action that
19 occurs during this event. Operators can observe the
20 actuation of ECCS, and with ECCS in service, the
21 natural circulation provided, then that safety
22 function is assured for 50 days.

23 CHAIR REMPE: Well, the introductory
24 sentence says, The key safety function for coolant is
25 established and maintained for greater than 50 days

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 without operator action. And so you're trying to tell
2 me then that they only need it for the 24 hours, not
3 the full 50 days.

4 MR. MAXWELL: The indication, that's
5 correct. Once the ECCS valves open, there's no
6 plausible mechanism for those valves to reposition
7 closed. They're in their safety position, the natural
8 circulation's established. The containment's
9 isolated, so the inventory is contained within the
10 containment vessel.

11 And operators observe the operation of
12 ECCS. Their continued observance isn't required to
13 assure that the system continues to function.

14 CHAIR REMPE: So okay, we don't have any
15 water level in the containment, we just have it in the
16 reactor vessel. But we're just going to, the
17 operators will say, okay, the valve opened and I don't
18 care anymore for 50 days, I don't need any
19 instrumentation is the position you're taking?

20 MR. MAXWELL: I would only characterize
21 that the operators don't care anymore. I would say
22 that when the safety systems actuate and are in
23 service, then within the boundary conditions
24 established event, that the safety function is
25 maintained for a minimum of 50 days.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: I just, as a, I think an
2 operator would want to know what's going on through
3 that 50 days is especially after, again, I know it was
4 a big BWR, but knowing how an operator feels when they
5 don't have any instrumentation, I think you would want
6 to have confidence that it would last.

7 MEMBER BROWN: But the loss of ultimate
8 heat sink is not, you all stated in your Chapter 20
9 that that's not plausible, therefore that's really not
10 part of this particular evaluation that you all are
11 doing. The only thing that plays here is the
12 extended loss of AC power.

13 MR. MAXWELL: The actual, it's a loss of
14 access to the ultimate heat sink that the --

15 MEMBER BROWN: Well, but you're sitting in
16 the ultimate ==

17 MR. MAXWELL: That's right.

18 MEMBER BROWN: You're sitting in the
19 ultimate heat sink. So you haven't, theoretically you
20 can't lose access, and you say that. There is no, the
21 loss of it as defined in the reference is not
22 plausible, no other heat sink is credited for
23 maintaining the key safety functions. So I'm just
24 trying to separate the variables here.

25 MR. MAXWELL: Right.

1 MEMBER BROWN: We keep arguing about this
2 and these two primary initiating conditions. One of
3 them is not relevant for this because you're always
4 sitting in the ultimate heat sink. The only thing
5 that plays is the extended loss of AC power, and that
6 plays into whatever other things have to happen, the
7 valves closing and all the other type things that
8 you're talking about.

9 MR. MAXWELL: That's correct, and for the
10 passive designs, they defined it as an extended loss
11 of AC power with loss of normal access to the normal
12 heat sink. So we don't have the main condensers
13 available.

14 MEMBER BROWN: Your normal sink's the pool
15 of the water, isn't it?

16 MR. MAXWELL: No, sir, normally it's the
17 main condenser.

18 MEMBER SKILLMAN: It's no steam dump. No
19 steam dump.

20 MEMBER RICCARDELLA: Or load. So that's
21 their normal.

22 MEMBER BROWN: I've never thought of that
23 as the heat sink because you're sitting in the thing,
24 and.

25 MEMBER BLEY: Yeah, but that's where the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat's going.

2 PARTICIPANT: But only --

3 MEMBER BROWN: Well, the containment's
4 not, is still evacuated in this circumstance, isn't
5 it?

6 MR. MAXWELL: It is until 24 hours into
7 the event. At 24 hours into the event, it's when the
8 ports open.

9 MEMBER BROWN: Okay, all right, I got
10 that.

11 MEMBER RICCARDELLA: What happens at 24
12 hours in?

13 MR. MAXWELL: At 24 hours, the module
14 protection system de-energizes the trip solenoids for
15 the emergency core cooling system, allows those valves
16 to open, and initiates ECCS.

17 MEMBER RICCARDELLA: And that floats to
18 containment.

19 MR. MAXWELL: It's DC powered.

20 MEMBER RICCARDELLA: So, oh, you're on DC,
21 okay, got it.

22 MEMBER CORRADINI: Just if we all wait two
23 slides, he has a time window that I think will help
24 us.

25 MEMBER BROWN: Well, I guess what I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 getting confused with, Mike, was the loss of the
2 ultimate heat sink. The point is the containment is
3 evacuated initially for the 24 hour period before it's
4 flooded, and then becomes now you have access, you
5 have access to the heat sink back effectively, once
6 you've flooded it into 24 hours, correct?

7 MEMBER MARCH-LEUBA: So you have
8 additional access. You always have the DHRS.

9 MR. MAXWELL: That's right.

10 MEMBER MARCH-LEUBA: And just satisfy on
11 the record, the special with the level, whether the
12 ECCS valves open or they don't, you will still survive
13 the event perfectly. Actually, if you don't lose DC
14 power, the event will be even better than you describe
15 here, because you will have the DHRS cooling your
16 decay heat nicely.

17 Opening the ECCS valves is just an
18 additional step to have is because you lost DC power.
19 But you would, it would be a success branch if you
20 kept the DC power on. Outsourced.

21 MR. MAXWELL: It is a, we load-shed the
22 ECCS solenoids off of the batteries at 24 hours --

23 MEMBER MARCH-LEUBA: I understand. But if
24 you lost all AC power except the one that fuels the
25 batteries, nothing bad will happen in this event. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could run that one and it would be a success. But,
2 because you will keep cooling on DHRS high pressure.

3 MEMBER KIRCHNER: He's saying the DHRS
4 system would successfully take you to a safe --

5 MR. MAXWELL: It's complicated because the
6 power that powers the chargers is the same power, so
7 the logic --

8 MEMBER MARCH-LEUBA: Yeah, but if you
9 claim that you'll rely on it --

10 MR. MAXWELL: Right.

11 MEMBER MARCH-LEUBA: The rule is, I don't
12 know what rule is for Mike, but for me is you can live
13 with it or without it.

14 MR. MAXWELL: Absolutely.

15 MEMBER MARCH-LEUBA: If we have every
16 possible combination. And indeed, you do.

17 MR. MAXWELL: If we had AC power available
18 on busses, it would not impact this event in a
19 negative way, negative manner. We would still have
20 all of our safety-related systems, module protection
21 system, the containment isolation system, reactor trip
22 system, and DHRS actuation.

23 MEMBER MARCH-LEUBA: What I'm trying to
24 say is you do not rely on ECCS actuating 24 hours
25 before the successful operation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAXWELL: We do not, that's correct.

2 MEMBER MARCH-LEUBA: If they kept close,
3 you would still survive perfectly.

4 MR. MAXWELL: We still have DHRS that
5 provides the core cooling initially.

6 MEMBER MARCH-LEUBA: It's redundant and
7 sufficiently -- so our discussion about the ECCS
8 actuation in this particular transient.

9 MEMBER DIMITRIJEVIC: For how long can
10 DHRS operate for, you know? How long can DHS remove
11 the heat successfully?

12 MR. MAXWELL: I have to, I don't know the
13 answer to that question off the top of my head.

14 MEMBER MARCH-LEUBA: DHRS has a capacity
15 of roughly six percent power?

16 MEMBER DIMITRIJEVIC: I know, but you need
17 the, you know, the nature of its inflation and all.

18 MEMBER CORRADINI: Under this stylized
19 accident, though, they have a slide later to show --

20 MEMBER SKILLMAN: It shows it, it's coming
21 up.

22 MEMBER DIMITRIJEVIC: My other question is
23 for your ultimate heat sink you need eventually
24 outside cooling, right. What provided, what provides
25 the cooling for your pool? No, no, no, but that pool

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 needs to be cooler.

2 MR. MAXWELL: We don't, no boiling,
3 boiling of the ultimate heat sink provides the
4 sufficient cooling for the modules. It eventually,
5 and we have slides that will show this. But
6 eventually we would add inventory, maintain inventory.
7 But --

8 (Simultaneous speaking.)

9 MR. MAXWELL: -- temperature control.

10 MEMBER BROWN: To the reactor pool.

11 MR. MAXWELL: That's correct. Ultimate
12 heat sink.

13 MEMBER DIMITRIJEVIC: Well, okay, so you
14 eventually, and what's that eventually when you need
15 to provide inventory to the ultimate heat sink?

16 MR. MAXWELL: Our analysis, we talk about
17 with 50 days, is based on 45 feet, a 45-foot elevation
18 in the pool. And that's just where the long-term
19 cooling calculation evaluation stopped, at 45 feet.
20 It didn't, it's not because there's a --

21 MEMBER DIMITRIJEVIC: Twelve units put in
22 decay heat, right?

23 MR. MAXWELL: With all 12 units, right.
24 We didn't evaluate beyond that point, so it's not
25 significant in that something happens in the ability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to cool core, to remove containment heat. It's just
2 that we went out to 45 feet, and that's where the
3 calculation stopped.

4 MEMBER MARCH-LEUBA: Those units, were the
5 DHRS, what elevation is DHRS?

6 MR. MAXWELL: The top of the DHRS passive
7 condenser is just above 45 feet.

8 MEMBER MARCH-LEUBA: Top 45 feet is the
9 DHRS.

10 MR. MAXWELL: It's 45 feet just below the
11 top of the passive condenser.

12 MEMBER MARCH-LEUBA: It will work another
13 foot.

14 MR. MAXWELL: Still mostly submerged.

15 MEMBER SKILLMAN: Chris, may I ask you to
16 go back one slide please?

17 MR. MAXWELL: Yes, sir. Figure out how,
18 yeah, thank you.

19 MEMBER SKILLMAN: Thank you. Let's see,
20 operator action monitoring. Would you speak more to
21 that please?

22 MR. MAXWELL: Again, just to --

23 MEMBER SKILLMAN: This is without AC or
24 DC. Go ahead.

25 MR. MAXWELL: Yes, sir, just within the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confines of the scope of this event, the, with the
2 design relying only on --

3 MEMBER SKILLMAN: Oh, these are the game
4 rules for the way this rolls out.

5 MR. MAXWELL: That's correct.

6 MEMBER SKILLMAN: Okay, go ahead.

7 MR. MAXWELL: With that, because it's the
8 automatic response of the installed plant equipment
9 that establishes and maintains the key safety
10 functions, no operator actions are necessary to do so.
11 With the need for monitoring is predicated on the need
12 for operator action. If I don't have any required
13 operator action, then I don't have a requirement for
14 monitoring.

15 As an operator myself, of course I want
16 to, I'm going to monitor, I'm going to, you know,
17 observe the actuation of all the safety-related
18 equipment. But back inside those boundary conditions,
19 that safety-related equipment performs as designed.
20 So that's the discussion about with no operator
21 action, therefore no monitoring's required.

22 MEMBER SKILLMAN: And I don't want to be
23 preachy, but just let me make a point or two. I can
24 buy and defend loss of AC and DC. I can defend no
25 inventory. I can defend no supplemental equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I can defend no operator resources. I cannot defend
2 a responsible SRO in charge of the watch for 12 plants
3 not fighting to the death for at least source range
4 instrumentation.

5 And I base that having been involved in an
6 NBDE like this. The thing we wanted more than
7 anything else at TMI2 was primary instrumentation for
8 neutron count. And we had several instances where we
9 lost it. And there was more excitement, and what I
10 mean by that is the emotion of fright, than anything
11 else.

12 We began to understand we didn't have
13 pressurizer level. We knew the pumps were vibrating.
14 From the radiation levels we knew we had lost a lot of
15 fuel or clad. But the thing that we were driven by
16 was neutron count rate. I would think that maybe that
17 one issue should be revisited.

18 If you were in charge of 12 reactors and
19 you've had this event, I think the one thing you would
20 be saying is I know a shutdown, I'm fairly confident
21 it's, I'm fairly confident it's shut down. And I
22 really think it's shut down, but I would really like
23 to have something that confirms it's shut down, 12
24 times.

25 So I would just offer I think that's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 blind spot that NuScale should think about, for a lot
2 of reasons. I mean, this whole design is predicated
3 on the robustness of the passive competencies to
4 protect the cores.

5 But the one parameter that seals the deal
6 in the operator's mind and in the NRC inspector's mind
7 is that we've got a count rate that we believe is
8 accurate. And the neutron count rate has dropped and
9 is not increasing.

10 Thank you for the monologue.

11 MEMBER BLEY: I was, just before you did
12 that, Dick, I wanted to go back to where Joy was. And
13 I just wanted to urge you to think about this, because
14 you are an operator. I mean, you meet the
15 requirements, I don't disagree with that. The
16 analysis looks right. But if you're an operator and
17 you can't see what's going on, and there's lots of
18 examples where this has happened.

19 It's not just Fukushima and TMI. There's
20 lots of other examples. When operators can't see
21 what's going on, they get nervous. They start trying
22 to find ways to see what's going on, and they operate,
23 right. They do, you don't, you know somebody did an
24 analysis and it said you're okay. But am I really
25 okay? I should be okay, am I really okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the idea that with a little pre-
2 planning you could see some of the parameters that are
3 crucial to keeping you from doing wrong. Now, the
4 chapter on human factors engineering says we look at
5 errors of commission. The PRA says we look at errors
6 of commission, but you hardly looked at errors of
7 commission at all.

8 So what are the bad things somebody could
9 do if you get in this spot and they get nervous, and
10 they start wanting to do something? That didn't show
11 up in the PRA, it probably should have. So just to
12 think about, not that there's anything wrong with this
13 analysis for this purpose. I'm done.

14 MR. BERGMAN: Can I just say what I did--

15 PARTICIPANT: Are you going to identify
16 yourself?

17 MR. BERGMAN: Yeah, Tom Bergman.

18 PARTICIPANT: Get close to the mic.

19 MR. BERGMAN: Tom Bergman, NuScale. So I
20 appreciate what you said, yes. The purpose of our
21 application and the purpose of this presentation is to
22 demonstrate that we meet the NRC's regulation. It
23 isn't to say what we or operators will do that goes
24 beyond that regulation. So of course our operators
25 care, of course they will try to maintain as many

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instruments as they can.

2 But in terms of this regulation, thank you
3 for noting, the question is have we met the
4 regulation. If you think the regulation isn't
5 appropriate, those questions need to go to the NRC
6 staff, because we think we've made the case we've met
7 the NRC's regulation.

8 CHAIR REMPE: Again, I, it extends beyond
9 Chapter 20. But even if you're going to do the water
10 level, I'm curious on how we're going to have it
11 qualified in the reactor vessel if you are going to
12 rely as it -- it's a key parameter they're monitoring,
13 so maybe it doesn't fall under Chapter 20, it's just
14 it's there by the way.

15 But I am not sure that the qualification
16 for the water level will consider something for those
17 conditions that are considered in Chapter 20 is what
18 I was trying to get to.

19 The other thing is is that at some point,
20 and I know you slides on it later, but saying that you
21 don't have operator action and this thing about the
22 batteries is a thing I'd like to see you discuss today
23 while you're up here too, because it does seem to
24 imply that your battery runs out after, it could run
25 out after 72 hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so I know you're going to be
2 discussing that, but there is some action required to
3 replace a battery apparently, okay.

4 MR. MAXWELL: I will address that in spent
5 fuel pool level indication portion.

6 MEMBER BROWN: Can I ask one, this is a
7 question just to clarify for myself -- somebody
8 answering something? I'm sorry, I didn't mean to
9 interrupt.

10 CHAIR REMPE: Go ahead, speak up.

11 MR. WEBER: I just wanted to go over
12 information on -- sorry, this is Scott Weber in the
13 PRA group at NuScale. And I just wanted to add a
14 little bit of information about like containment water
15 levels from the other instruments that we've been
16 talking about. Because we're talking very
17 specifically in the context of Chapter 20.

18 But obviously for all these dissertations,
19 anything that NuScale has determined to be a close
20 monitoring variable is also subject to equipment
21 qualification and to equipment operability
22 requirements.

23 And so just because something is not
24 necessarily on, you know, a list of the key functions
25 with specific respect to this event, that does not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mean that it doesn't have equipment qualification
2 requirements, which are generally, you know, for every
3 two hours or beyond some, or up to 30 days or 100 days
4 in that table; and then you have the subpart to that,
5 which I don't have in front of me immediately.

6 But the equipment qualification program is
7 the -- subject to the same conditions that you would
8 see in the type of events where it is an extended loss
9 of power but it's not a core damage event. It's a
10 primary source for cooling activity. That's all
11 reflected in the equipment qualification program, and
12 so all these instruments are going to be shown
13 expected to be qualified.

14 And additionally there will be
15 survivability requirements that use a beyond design
16 basis core damage event. So we just want to make sure
17 that that is understood. And that's it, and if
18 there's more questions?

19 CHAIR REMPE: So the thing was is this a
20 first-of-a-kind application, and it's my understanding
21 when the water level sensors were reviewed, it was not
22 clearly stated that they're going to this first-of-a-
23 kind technology. For example, if you'd used a DP
24 cell, you might not have been worried about a
25 radiation level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But because the details of this sensor are
2 not well known, it may require some differences in how
3 it's qualified. And I have not seen anything, this
4 is, what you put in Chapter, in the technical report,
5 in Rev. 1 of it, where you said we're going to at
6 least do radiation levels, but then the next question
7 is well, what about fluence.

8 And so I'm not sure I've seen that
9 anywhere in what I've looked at. But it would be good
10 to give me some sort of reference where I can see that
11 you're thinking about all the variables that might
12 impact this first-of-a-kind sensor.

13 Go ahead, Charlie.

14 MEMBER BROWN: I just wanted, and when I
15 read this, I guess I didn't glom onto this. I presume
16 this analysis is assuming you've got 12 modules
17 operating.

18 MR. MAXWELL: Yes, sir.

19 MEMBER BROWN: In that circumstance. You
20 switch between DNPM, as opposed to each NuScale NPM.
21 I got lost in the transition, so you've answered my
22 question.

23 MR. MAXWELL: So the next slide will help
24 a little bit with that. And this is the boundary
25 condition. So again, this is tracking from existing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 industry guidance. Boundary conditions for the event
2 are that the beyond design basis event occurs,
3 impacting all modules at the site.

4 All modules are initially operating at
5 power unless the site has a procedural direction to
6 shut down for the impending event. Each module will
7 successfully shut down when required. All rods are
8 inserted, there is no anticipated transient without
9 scram.

10 Onsite staff is at site administrative
11 minimum shift staffing levels. No independent
12 concurrent events, for example, no security threat.
13 All personnel onsite are available to support the site
14 response. And spent fuel and dry storage is outside
15 the scope of this event.

16 MEMBER CORRADINI: I think you're going to
17 discuss this but just to, in anticipation. But what
18 makes you guys unique, I thought you wrote somewhere
19 in chapter is you're, you have a higher probability of
20 something in transition to refueling, and that's going
21 to be a particular mode that you're going to analyze
22 specifically for this.

23 MR. MAXWELL: And we did, and we took, we
24 considered a --

25 MEMBER CORRADINI: If you're going to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it later, you can wait.

2 MR. MAXWELL: I don't, we don't have a
3 slide specific to that, so I'll just describe it
4 briefly. Here is that what we did is we considered a
5 module that was in transition, so it had been cooled
6 down. In order to achieve the state of transition you
7 cool down the module, you pull it up, and you open the
8 ECCS valves.

9 So I've got a module now that's on the
10 reactor building crane. It's been moved over to the
11 containment tool, and we've lifted it to its highest
12 point to be set into the pool, into the refueling
13 pool. And that's at that moment that that's when the
14 ELAP occurs.

15 And we did an evaluation, and it was also
16 if we provided adequate core cooling for beyond 50
17 days. It was still, it was not bounding compared to
18 the other modules.

19 Additionally, while we did look at that,
20 we also looked at, well, in transition, you know,
21 you'd say that the initial condition's better off than
22 compared to an operating module that you're already
23 cooled down and flooded.

24 And so we're looking now specifically at
25 the amount of time that you spend at that elevation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where there's less cooling, depth of cooling to the
2 ultimate heat sink. And something along the lines of
3 .02% of an operating cycle that the module will spin
4 in that state.

5 MEMBER RICCARDELLA: Crane stops working
6 so it's sitting there for 50 days or something.

7 MR. MAXWELL: That's correct. And you
8 know, we've kind of jumped into what the operators
9 will be doing. And of course there's design features
10 that allow manual operation to lower the module with
11 the crane, that's correct, manually. But the analysis
12 shows that it wouldn't be required.

13 MEMBER MARCH-LEUBA: But wouldn't the
14 limiting one when would be if you put in the refueling
15 machine sits there at that unlimited position, and
16 it's not DHRS.

17 MR. MAXWELL: There's no --

18 (Simultaneous speaking.)

19 MR. MAXWELL: Right, but you're submerged.
20 Now you're just in the ultimate heat sink. Now you
21 have the entire capacity of the ultimate heat sink.

22 MEMBER MARCH-LEUBA: Not when you lower
23 the level past the top of the head. Or did you lower
24 the level past the top of the open head?

25 MR. MAXWELL: Well we, the modules flooded

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 up, all the way up to the baffle plates. Now we put
2 it in the C tool, remove the bottom head of the
3 containment. It's still flooded within --

4 MEMBER MARCH-LEUBA: And the opening is at
5 what elevation? That top opening?

6 MR. MAXWELL: I don't know that number.

7 MEMBER MARCH-LEUBA: Is it greater or
8 lower than 45?

9 MR. MAXWELL: Lower, much, much lower than
10 45 feet.

11 MEMBER MARCH-LEUBA: Much lower.

12 MR. MAXWELL: Yes, sir.

13 MEMBER MARCH-LEUBA: Okay.

14 MR. MAXWELL: All right, so now that we've
15 established these boundary conditions, we'll, we took
16 a look. We evaluated to determine if the design met
17 the coping criteria. So I want to describe the
18 NuScale power plant response to an extended loss of AC
19 power concurrent with the loss of normal access to the
20 normal heat sink. And without any operator action and
21 without use of any offsite resources.

22 So within the first minute of the event,
23 you receive a reactor trip. Decay heat removal system
24 initiation and containment isolation for all 12
25 modules. That makes all the reactors sub-critical and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 places in service the decay heat removal sufficient to
2 establish safe shutdown conditions.

3 Twenty-four hours into the event, at the
4 24-hour mark, the module protection system de-
5 energizes the trip solenoids for the ECCS valves,
6 allowing the ECCS valves to open and place ECCS into
7 service.

8 Yes, sir. It floods it -- it partially
9 transfers reactor system to the containment vessel.
10 So it puts some coolant into the containment and some,
11 while some stays in the reactor above the top fuel.

12 At this condition, all 12 modules are in
13 safe shutdown with passive decay heat and containment
14 cooling. And the spent fuel in the spent fuel pool
15 remains passively cooled by the inventory of the
16 ultimate heat sink.

17 MEMBER MARCH-LEUBA: I mean, your analysis
18 at 24 hours, you remove the DHRS cooling. I mean you
19 drained it.

20 MR. MAXWELL: It becomes of significantly
21 reduced effectiveness because of ECCS in operation.

22 MEMBER MARCH-LEUBA: You're only in the
23 steam, DHRS is only in the steam area, it's not
24 condensing.

25 MR. MAXWELL: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: But that's assumed,
2 that is calculated in your modeling?

3 MR. MAXWELL: Yes. What we did was use
4 the station blackout analysis. The first 72 hours of
5 the station blackout is identical to an ELAP. And we
6 use that analysis to predict the response.

7 MEMBER MARCH-LEUBA: Because if I remember
8 correctly, the conductivity through the containment is
9 only like .5% nominal power. Certainly less than one
10 percent.

11 MR. MAXWELL: I don't know the answer to
12 that question.

13 MEMBER MARCH-LEUBA: That's the number of,
14 actually, 0.6% is the number that sticks to my head
15 and I've heard sometime. And that, it's awfully close
16 to decay heat.

17 MR. MAXWELL: Well, yeah --

18 MEMBER MARCH-LEUBA: If you've run the
19 calculation properly.

20 MR. MAXWELL: That's correct.

21 MEMBER MARCH-LEUBA: I'm not in the
22 business of arguing with computer codes if you've done
23 it.

24 MR. MAXWELL: We have a calculation that
25 did consider this. You know, if DHRS is in service

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for the first 24 hours, and then transferring over to
2 Emergency Core Cooling System at 24 hours.

3 Okay, again, like I said now so we're in
4 safe shutdown on the 12 modules and the spent fuel in
5 the spent fuel pool just continues to be passively
6 cooled by the ultimate heat sink inventory. During
7 all this period, the ultimate heat sink is heating up,
8 and it begins to boil after more than five days.

9 When the pool begins to boil in our
10 analysis we assume that none of the inventory returns
11 back to the pool. Level begins decreasing. Again --

12 MEMBER MARCH-LEUBA: Well before that you
13 will start evaporating.

14 MR. MAXWELL: Right.

15 MEMBER MARCH-LEUBA: Which will mean the
16 containment level building around the pool, and we'll
17 have an environment similar to Florida yesterday. And
18 everything will be condensing, any instrumentation,
19 anything that has -- everything in building survives
20 condensing moisture?

21 MR. MAXWELL: All the safety-related
22 equipment necessary is qualified to the pool
23 environment that's in that area --

24 MEMBER MARCH-LEUBA: Is it qualified for
25 99% humidity and condensing?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAXWELL: Correct.

2 MEMBER MARCH-LEUBA: What happens to the
3 steam when you start boiling it? Because that
4 building is closed.

5 MR. MAXWELL: There are pressure,
6 overpressure reliefs in the reactor building, safety-
7 related overpressure reliefs.

8 MEMBER MARCH-LEUBA: Like a safety relief
9 valve? Cooling down service, same function.

10 MR. MAXWELL: That's correct. Like again,
11 after more than five days the pool begins to boil and
12 it just, again to point out, so you know operator
13 action. The level in the pool would begin to
14 decrease, and it would reach 45 feet, which we said
15 earlier was just below the top of the DHRS passive
16 condensers, after more than 50 days.

17 MEMBER CORRADINI: So can I ask a
18 question? Jose asked it, and maybe I misunderstood.
19 So there is pressure relief from the building to the
20 environment?

21 MR. MAXWELL: That's correct.

22 MEMBER CORRADINI: If I then go through a
23 change of conditions where there's a negative
24 pressure, is there pressure relief from the
25 environment back into the containment -- into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor building?

2 MR. MAXWELL: I don't know the answer to
3 that, I'll have to take --

4 MEMBER CORRADINI: Does somebody know that
5 in the design? Does it go, does it swing both ways?
6 In other words, if I have an overpressure does that go
7 out? If it starts breathing, will it allow it to come
8 back in if I start condensing steam too much? Because
9 I'm going to essentially flush all the air out of the
10 system, right?

11 MR. MAXWELL: Right.

12 MEMBER CORRADINI: As I approach boiling,
13 the partial pressure of steam is going to essentially
14 take over. So I'm curious if I then get a lower
15 pressure, will there be an inflow?

16 MR. MAXWELL: I understand the question,
17 unfortunately I don't know the answer to that.

18 MEMBER CORRADINI: Can you take it down
19 and get back to us?

20 MR. MAXWELL: Yes, we can.

21 MEMBER CORRADINI: Thank you.

22 MEMBER BLEY: My memory from work that was
23 done on cylindrical containments --

24 MEMBER CORRADINI: Well, this is a
25 building, it's not a cylindrical --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: No, if you get into that
2 condition though so that you've got a few inches of
3 reverse pressure. You aren't built for that kind of
4 strength.

5 MEMBER CORRADINI: Well, but --

6 MEMBER BLEY: Weird things can happen.

7 MEMBER CORRADINI: But as long as they've
8 got a, I expect you're going to tell me they had a
9 damper, like a door. The door opens, the door closes,
10 it swings both ways.

11 MR. MAXWELL: I think we're going to find
12 this more along the lines of a rupture.

13 MEMBER CORRADINI: Because where I'm going
14 with this essentially is -- I'm in -- well, I'll stop.

15 MR. MAXWELL: I'll get the official
16 answer for you.

17 MEMBER CORRADINI: That's fine, that's
18 fine. Okay, thank you.

19 MR. MAXWELL: So now we've got, like I
20 said, the pool level has dropped down to 45 feet.
21 Again, that takes more than 50 days for that to
22 occur. During that period, passive core cooling and
23 containment cooling are assured.

24 And just, again, I'm pointing out that the
25 45 feet is not significant in any regard to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ability to cool the fuel or containment. It's just
2 where the long-term cooling calculation analysis
3 terminated.

4 Regarding the spent fuel pool cooling
5 safety function itself, it continues to be maintained,
6 even if the level in the ultimate heat sink is allowed
7 to lower. And after more than four months, the
8 ultimate heat sink level would reach the bottom of the
9 opening in the weir wall that separates the spent fuel
10 pool from the rest of the ultimate heat sink pools.

11 And that level's significant. Before that
12 point, pools are in communication with one another and
13 the reactor pool and the refuel pool act as a makeup
14 source to the spent fuel pool for that period. And
15 once the walls, once the pools are separated and we're
16 just looking at the spent fuel pool for cooling of the
17 spent fuel, it still requires another month, up to
18 five months before the level would reach the top of
19 the spent fuel rack.

20 CHAIR REMPE: This is my ignorance of the
21 regulations, but the fact that you've separated out
22 the fact that operators have, some plant person has to
23 replace the battery, it's not included in the
24 requirements to meet this particular aspect.

25 MR. MAXWELL: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: So your subtitle about plant
2 response without operator action or offsite resources
3 applies for this particular criterion. But later with
4 the spent fuel and then is where you hit up about the
5 batteries might have to be replaced.

6 MR. MAXWELL: Right, this condition would
7 still exist, because this isn't level monitoring, it's
8 just the pool passively lowering and the safety
9 functions continuing to be maintained during this
10 period. Then yes, you're right that we separate.
11 Then there's the paragraph E requirement specific to
12 spent fuel pool level indication.

13 CHAIR REMPE: Okay. Well, I go further.
14 Then the staff though has applied broadly. We're not
15 going to do anything beyond 72 hours in the response
16 that they, what they have in their draft SE. And they
17 went ahead and because they don't have analysis beyond
18 72 hours is why they stopped on this, when it wasn't
19 because they needed an operator action or anything
20 like that?

21 Is there a primary reason plus, or is that
22 your understanding of why they stopped on 72 hours for
23 this?

24 MR. MAXWELL: Let, they would like to
25 speak to that.

1 CHAIR REMPE: Okay, well, I'll let them
2 speak to it later. Are you still strong that you want
3 50 days or whatever? Or that's your, the NuScale
4 stance here still?

5 MR. BERGMAN: Hi, Tom Bergman, NuScale,
6 again. Yes, we would like to have the coping period
7 of 14 days approved and the recognition that 14 days
8 represents indefinite given the resources required at
9 that point. So we're calculating it to 14 days. The
10 50 days shows we have plenty of margin for 14 days.

11 PARTICIPANT: Yeah, I think the 50 days is
12 just a calculation.

13 MR. MAXWELL: Right, that's what we, you
14 know --

15 CHAIR REMPE: And you believe you have
16 adequate documentation to support that with what
17 you've provided with this Rev. 1 technical report.

18 MR. BERGMAN: Correct. It was also -- I
19 can't remember the day but it was a March 2019 letter
20 to NRO where we laid out the rationale for what we're
21 doing as well.

22 The DCA has now been brought in, the
23 technical reports have been brought up to date. That
24 letter, which is referenced in the Staff SECY paper,
25 provides that basis for the 14 days.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Okay, thank you.

2 MR. MAXWELL: So, now with the pipe
3 response being covered, we're going to remove two of
4 the individual key safety functions, beginning with
5 core cooling.

6 The success criteria we looked at and the
7 criteria are for the equipment relied upon to provide
8 satisfactory fuel cooling performance and to maintain
9 the fuel covered at all times.

10 With the containment isolation that occurs
11 in that first minute, within the first minute of the
12 event initiation, the reactor coolant system inventory
13 required to meet these criteria is preserved for the
14 duration of the event.

15 The core cooling itself is provided as
16 we've established in the first 24 hours by the decay
17 heat removal system and then the remainder of the ELAP
18 via the emergency core cooling system.

19 Also essential for core cooling is the
20 ultimate heat sink inventory.

21 Core cooling, again, occurs initially
22 through transfer of heat to the ultimate heat sink to
23 the DHRS passive condensers, which are submerged in
24 the ultimate heat sink and then transfers to heat
25 transfer from the containment vessel with ECCS in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operation.

2 The passive heat removal to the ultimate
3 heat sink is capable of maintaining core cooling for
4 more than 50 days without pull inventory makeup or
5 operator action.

6 Next safety function is containment. The
7 containment function is provided by the containment
8 isolation valves and the containment vessel.

9 As we just mentioned, there's containment
10 isolation that occurs within the first minute of the
11 event by a module protection system automatic
12 response.

13 The containment vessel temperature and
14 pressure are passively controlled by heat removal of
15 the ultimate heat sink.

16 And the parameters reach their peak value
17 during ELAP immediately following opening of the ECCS
18 valves, again, which happens after DHRS has been in
19 operation for 24 hours, reducing RCS temperature.

20 And pressure over that period and the
21 opening of the ECCS valves itself does not represent
22 a challenge to the containment integrity.

23 So, with the ultimate heat sink inventory
24 -- without any addition or any other operator actions,
25 the containment cooling is maintained for more than 50

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 days.

2 The third key safety function is spent
3 fuel pool cooling.

4 Just a couple minutes ago we discussed the
5 pools of the ultimate heat sink and in this figure we
6 can see the rear wall itself that separates the spent
7 fuel pool from the refuel pool and the opening in the
8 wall, the weir that allows the movement of fuel
9 between the two pools using the refuel machine.

10 And that opening is significant because
11 it's what allows the spent fuel pool to communicate
12 with the other pools and initially causes the ultimate
13 heat sink to respond as a single volume to the event
14 until level lowers below or to that point.

15 And again, as described earlier, at that
16 point it's just the inventory in the spent fuel pool
17 that's providing cooling to spent fuel. It still
18 would require more than 150 days for the level to
19 passively boil down to the top of the spent fuel rack.

20 The last topic I'll talk about, with
21 respect to again just to the mitigation strategy and
22 monitoring and with respect to that, just to the
23 mitigation strategy, pipe monitoring is not necessary
24 because there are no operator actions to establish and
25 maintain the three key safety functions for more than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 50 days following the initiation of an ELAP.

2 However, the instrumentation is
3 instrumentation DC electrical power provided in the
4 design that allows the control room operators to
5 observe the response of the installed plant equipment
6 to verify the conditions necessary for coping had been
7 established.

8 These indications remain available for a
9 minimum of 72 hours.

10 MEMBER MARCH-LEUBA: You're saying that
11 the batteries share the load, drop an unnecessary load
12 but keep the control room alive for 72 hours?

13 MR. MAXWELL: That's correct.

14 MEMBER MARCH-LEUBA: Is that what you're
15 saying?

16 MR. MAXWELL: Yes.

17 MEMBER CORRADINI: So, you said something
18 earlier and I wanted to kind of return back to it.

19 So, as you said, the philosophy is that
20 this essentially is, to put it in terms, is a
21 hands-off response where the operators are free to
22 then address the initiators and cure or reestablish.

23

24 So, what would be in the emergency
25 operating procedure realm, not this realm, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reestablish battery charging to get the batteries so
2 they'd go beyond 72 hours? Can you remind me what
3 that is?

4 MR. MAXWELL: They're not --

5 MEMBER CORRADINI: I assume it's EOPs that
6 they would be following?

7 MR. MAXWELL: Right, and forgive me, it's
8 not my area of expertise. I can't remember the name
9 of --

10 MEMBER CORRADINI: It's not mine either so
11 just take us down the path.

12 MR. MAXWELL: If you look at the displays
13 for the operator, it's the three key safety functions
14 that they evaluate.

15 And I'm a visual thinker, I'm looking at
16 the panel in my head here, but there's the three key
17 safety functions and then, essentially, they're the
18 backup functions. So, once the three key safety
19 functions are established and maintained, here are the
20 other areas that you need to address.

21 And one of them is electrical distribution
22 and entering that procedure will direct the operators
23 to restore power, to start the backup diesel
24 generators, to get the auxiliary AC power source
25 running and ready for electrical loading.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, there are procedures for those
2 defense-in-depth components, if you will, that will
3 direct the operators to take those actions.

4 MEMBER CORRADINI: And those would, based
5 on EOPs and even with the stylized accent, those would
6 occur simultaneously?

7 MR. MAXWELL: That's correct.

8 MEMBER CORRADINI: Thank you.

9 MEMBER RICCARDELLA: So, going back to
10 your picture with the rear wall?

11 MR. MAXWELL: Yes, sir.

12 MEMBER RICCARDELLA: There's nothing that
13 causes circulation, natural or otherwise, between the
14 main side and -- so one could get considerably warmer
15 than the other.

16 It's just that if it boils off, the level
17 will stay the same, right?

18 MR. MAXWELL: That's exactly right. The
19 heat load in the spent fuel pool -- the pool boil-off
20 calculation was very conservative. It assumes 18
21 years' worth of spent fuel in the pool including a
22 fresh full-core offload.

23 So, the heat load being more significant
24 than the reactor and refuel pool and the volume being
25 smaller, the spent fuel pool boils off faster. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again, the refuel pool make up, essentially acts as a
2 makeup source.

3 MEMBER RICCARDELLA: It's like the hot tub
4 in a swimming pool?

5 MR. MAXWELL: That's correct. So, now
6 with the discussion of the mitigation strategies
7 complete, we move into the spent fuel pool monitoring
8 portion of the rule, which is covered by Paragraph
9 Echo.

10 The objective of this part of the rule is
11 to provide a reliable means to remotely monitor
12 wide-range spent fuel pool water level until five
13 years have elapsed since all of the fuel within the
14 spent fuel pool was last used in the reactor vessel
15 for power operation.

16 And the intent is that the operators have
17 the information necessary to prioritize event
18 response. The NuScale ultimate heat sink system
19 includes remote level indication for the following.

20 It's got reactor pool, refuel pool, and
21 two dedicated indicators for the spent fuel pool.

22 These indicators are seismically qualified
23 as well as qualified for the environment of the pool
24 area during an ELAP, and are normally powered by our
25 highly reliable DC power system via the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protection system.

2 MEMBER MARCH-LEUBA: Would you go back to
3 the cartoon and show where the refueling pool is?

4 MR. MAXWELL: Yes, sir.

5 MEMBER MARCH-LEUBA: Where is the third
6 pool? Because I only see two.

7 MR. MAXWELL: What this isn't showing you
8 in this mimic is that the elevation of this floor is
9 below the reactor pool.

10 MEMBER MARCH-LEUBA: It's a continuous
11 mass of water?

12 MR. MAXWELL: It is.

13 MEMBER MARCH-LEUBA: There is no rear wall
14 there?

15 MR. MAXWELL: That's correct, no wall.
16 The difference is just the --

17 (Simultaneous speaking.)

18 MEMBER MARCH-LEUBA: It's still the pool,
19 you just call it Section A, Section B?

20 MR. MAXWELL: That's correct. It could be
21 thought of another way as two indications for spent
22 fuel pool level indication on this side of the rear
23 wall and two indicators for pool level on the other
24 side of the rear wall.

25 In addition to the 72 hours of battery

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power from the highly reliable DC power system, the
2 design would include for these level indicators a
3 replaceable battery power source that's independent
4 from the plant AC and DC power systems.

5 And those batteries will have a minimum
6 capacity of 14 days.

7 MEMBER MARCH-LEUBA: Capacity to provide
8 what?

9 MR. MAXWELL: To provide indication for
10 these spent fuel pool level indicators.

11 MEMBER MARCH-LEUBA: It will power the
12 instrumentation? Where is the display, the control
13 room?

14 MR. MAXWELL: The location of the display,
15 final location, hasn't been determined but what is
16 required is that it's remote from the pool area.

17 MEMBER MARCH-LEUBA: It has to be in an
18 accessible location.

19 MR. MAXWELL: That's correct.

20 MEMBER MARCH-LEUBA: The USS is not
21 accessible.

22 MR. MAXWELL: That's exactly right.

23 MEMBER BLEY: What keeps this replaceable
24 battery from supplying power to other things?

25 MR. MAXWELL: It's divorced, it's capable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of being completely divorced from the AC and DC power
2 system. It's independent of and divorced from the AC
3 and DC distribution system.

4 MEMBER BLEY: I don't remember seeing
5 details of this. Are they available somewhere?

6 MR. MAXWELL: The final instrument hasn't
7 been selected, just we're implementing the requirement
8 for --

9 MEMBER BLEY: The electrical side isn't
10 laid out anywhere.

11 MR. MAXWELL: No, sir, not at this time.
12 I just want to point out that it's specific to the
13 instrument.

14 This is not part of our electrical
15 distribution system at all, it's going to be specific
16 to the spent fuel pool level instrument.

17 MEMBER BLEY: So, you would have to
18 disconnect a normal power source and then insert this
19 replaceable battery source?

20 MR. MAXWELL: Again, we haven't selected
21 our --

22 MEMBER BLEY: You don't know exactly?

23 MR. MAXWELL: I can tell you that at my
24 old plant ours divorced itself and a loss of power
25 relay dropped out and just put the replaceable battery

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in service.

2 MEMBER BLEY: So, there will be one there
3 permanently?

4 MR. MAXWELL: That's correct, a permanent
5 install.

6 MEMBER BLEY: And it will be charged
7 permanently but it will somehow disconnect when you
8 get to this point?

9 MR. MAXWELL: That's correct.

10 MEMBER BLEY: And when you say
11 replaceable, is there the intent that at some point
12 when it starts running down, you could stick a new one
13 in there so you'll keep these instruments?

14 MR. MAXWELL: That's the intent. Again,
15 without having selected the permanent design, I can
16 tell you that there's designs that are capable of the
17 batteries.

18 MEMBER BLEY: It will be for all of these
19 level instruments, not just one?

20 MR. MAXWELL: All four.

21 MEMBER BLEY: Have you done that for any
22 other instruments that you know of?

23 MR. MAXWELL: Not that I'm aware of.

24 MR. SCHULTZ: Chris, is this then the
25 system that is time-limiting in terms of the 14 days?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In other words, you're putting this into place so that
2 you can support a 14-day timeframe?

3 MR. MAXWELL: I would say that the
4 mitigation strategy, again, keeping it separate from
5 the spent fuel pool level indication, worked on
6 require spent fuel pool level indication to mitigate
7 the beyond-design-basis event.

8 So, this is separate, the 14-day battery
9 is separate, to the spent fuel pool level indication
10 requirement, Paragraph Echo, not to the B1
11 requirements.

12 Because we don't credit or need the spent
13 fuel pool level indicators as part of our mitigation
14 strategy.

15 MR. SCHULTZ: But you're putting the
16 replaceable battery power source in place so that you
17 can support 14 days as it relates to this requirement?

18 MR. MAXWELL: Correct, Paragraph Echo
19 requirement.

20 MR. SHULTZ: Okay.

21 MEMBER RICCARDELLA: But if they're
22 constantly charging during normal operation, wouldn't
23 you expect them to last 14 days?

24 MR. MAXWELL: I expect them to last 17
25 days because the first 3 days they'll be supplied by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the highly reliable DC power system.

2 I'd actually expect it to be 20 days,
3 frankly, but once the EVS batteries are no longer
4 available, that's when these batteries would be placed
5 into service.

6 And their allowance is made in the rule
7 for intermittent operation but we haven't finalized
8 what instrument we're going to use.

9 MEMBER BLEY: That would be something you
10 do by procedure or it might even --

11 MR. MAXWELL: That's correct.

12 So, to summarize, the two different
13 portions with regards to the pipe mitigation strategy,
14 the NuScale strategy, is to rely on the automatic
15 response of the permanently installed safety-related
16 plant equipment to establish and maintain the three
17 key safety functions and to provide extended coping
18 capabilities of greater than 14 days.

19 And again, this strategy doesn't require
20 any AC or DC power, or any inventory addition, or any
21 operator action to be placed into service or to be
22 maintained.

23 And regarding the spent fuel pool level
24 indication strategy, they rely on the installed
25 instrumentation I've just described. And included in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that is a 14-day battery backup power supply.

2 MR. SCHULTZ: But you don't really need
3 that to satisfy the condition of the fuel? The fuel
4 is fine for 50 days, 50-plus days?

5 MR. MAXWELL: That's correct.

6 MR. SCHULTZ: So, you don't need to spend
7 this money, you could spend it on something else if
8 you didn't have to meet this requirement?

9 MR. MAXWELL: That's correct.

10 MR. SCHULTZ: But you can do it and do so.
11 Okay, thanks.

12 MR. MAXWELL: That's the end of the
13 Chapter 20 presentation if there's questions.

14 CHAIR REMPE: I'm going to delve a little
15 bit more about what I tried to ask earlier about what
16 would be required to get the Staff to go to a 14-day
17 approval.

18 If they were to decide to do this, they
19 probably would ask for a lot more analyses to be
20 submitted, which would require a lot more review on
21 their part as well as they'll be RAIs and all that
22 stuff.

23 And there's always pressure about oh, it
24 costs so much for a design certification but you guys
25 are willing to step up and say whatever it takes that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Staff think they need, you're willing to provide
2 it.

3 It does cost money to have this additional
4 work done, right?

5 MR. MAXWELL: I'll defer to the licensee
6 for the response.

7 MR. BERGMAN: Tom Bergman, NuScale. We
8 believe we've already done the work to provide that
9 information in our latest submittals.

10 CHAIR REMPE: I heard that earlier but you
11 realize there will be RAIs. The Staff had not
12 intended to do more than 72 hours. Is there a
13 response back?

14 And if they come back and say, okay, well,
15 you guys want it, we'll do it, and they start asking
16 a lot of RAIs and ask for additional analyses?

17 MR. BERGMAN: Then we can revisit our
18 decision but Chapter 20 is written as a substantial
19 investment. We'd like to get the maximum return on
20 that investment.

21 CHAIR REMPE: Sure, I bet. Okay, just
22 exploring the boundaries here. We're scheduled for a
23 break now, are there any other questions?

24 MEMBER SKILLMAN: I had one. Chris, I'm
25 in your mitigation strategy in your Section 522

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactivity control and just let me make two points.

2 I'm going to read from your document so
3 you understand why I'm saying what I'm saying. For
4 Boundary Condition 3 in Section 313, when reactor trip
5 occurs in the ELAP event, all control rods fully
6 insert.

7 This action achieves initial
8 subcriticality, however, depending on the time and
9 core life, for some currently licensed designs the
10 control rods alone may not provide sufficient negative
11 reactivity to compensate for the positive reactivity
12 added as the core cools.

13 I'm interpreting that as a rhetorical
14 reference to other plant designs, not the NuScale
15 design. Then you say to account for this the NuScale
16 plant design includes a unique core design limit.

17 I'm assuming that unique in that context
18 means it's unique to the way the NuScale license is
19 written.

20 MR. MAXWELL: Unique in that it's not
21 typical of designs.

22 MEMBER SKILLMAN: Okay, so it's back to
23 the former, more general discussion. Unique meaning
24 all those other PWRs out there and not necessarily
25 ours?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAXWELL: Correct.

2 MEMBER SKILLMAN: Okay, because what you
3 go on to say then or what this document then says is
4 the hot full-power critical boron concentration is
5 such that a cold zero power with all rods inserted K
6 effective is less than one.

7 I've operated a 508 percent, a 2791
8 cooler, a 24-month fuel cycle and I've been out 690
9 days at 18 PPM. And we push the scram button, it goes
10 subcritical.

11 So, I think that the limit that you're
12 talking about is at the end of core life with a 508
13 percent core, 690, because you're in a 24-month fuel
14 cycle, you're out 690, 700 days.

15 And even at that very low boron
16 concentration, whether it's 10 or 30, at least the way
17 you're writing your license, you will be 5 percent
18 subcritical or 1 percent subcritical, you're simply
19 saying you're subcritical.

20 MR. MAXWELL: Unfortunately, I don't know
21 that I'm smart enough to answer your question fully.

22 MEMBER SKILLMAN: I think you're saying
23 the end of life, no matter what the boron
24 concentration is, it shuts down.

25 MR. MAXWELL: That's correct. We operate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with sufficient boron concentration with all rods in
2 to be subcritical.

3 MEMBER SKILLMAN: And even as it cools
4 from there, you still remain subcritical?

5 MR. MAXWELL: That's correct.

6 MEMBER SKILLMAN: Gotcha. Thank you.

7 CHAIR REMPE: Mike, did you have a
8 question?

9 MEMBER CORRADINI: I'm good.

10 CHAIR REMPE: So, if there aren't any
11 other questions --

12 MS. JOERGENSEN: I'd like to make a
13 comment. There was a question on the negative
14 pressure in the building, whether the vents would
15 allow it to relieve overpressure and also allow air to
16 come back into the building.

17 So, the answer is the reactor building
18 ventilation system maintains a negative pressure by
19 design. If boiling occurs, the overprotection is a
20 ruptured disc and steam goes out.

21 It would not reclose and if there is a
22 later negative differential due to steam condensation,
23 air would be pulled back in.

24 MEMBER CORRADINI: Thank you.

25 CHAIR REMPE: So, since we are now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scheduled for our break, let's take it and come back
2 until 2:40 p.m. by this clock, okay? Thank you.

3 (Whereupon, the above-entitled matter went
4 off the record at 2:24 p.m. and resumed at 2:41 p.m.)

5 MR. TABATABAI: Okay, good afternoon,
6 everyone. My name is Omid Tabatabai, I'm a Senior
7 Project Manager in the Office of New Reactors.

8 And we're here to present the Staff's
9 evaluation of NuScale's Chapter 20 safety evaluation
10 application and the design certification application.

11 But before we get started, I would like
12 for Kevin Coyne who's here and he's the Director of
13 our Division of Safety Assessment, Risk Analysis, and
14 Engineering.

15 So, Kevin will be making some introductory
16 remarks on behalf of the Staff. Kevin?

17 MR. COYNE: Thanks, Omid. Kevin Coyne,
18 Acting Director, Division of Engineering, Safety
19 Systems, and Risk Assessment. And thank you for the
20 opportunity to greet the Subcommittee today.

21 Needless to say, the ACRS reviews are very
22 valuable to the Staff and provide good feedback that
23 we then incorporate into our reviews. And in
24 particular, thank you for the flexibility and
25 scheduling of a full Committee Meeting tomorrow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I know that's unusual but it was important
2 to NuScale, important to the Staff to try to get to
3 the full committee as soon as we could.

4 So, the mitigation of beyond-design-basis
5 event review that the Staff has been doing has evolved
6 since NuScale first submitted their application.

7 It's worth noting that the MBDBE orders
8 and the rule are not applicable to a design
9 certification.

10 But to the extent an Applicant chooses to
11 describe certain design aspects of the SSCs used to
12 provide the mitigation strategies in their FSAR, the
13 Staff can review that and provide some level of
14 finality based on that review.

15 Looking to our OGC, I just wanted to make
16 sure I got that part right. So, legitimate to review
17 but it's not required for the design cert.

18 NuScale has asked for the reviews so the
19 Staff is going through the review. We've briefed ACRS
20 on our MBDBE reviews and the past HMP was obviously
21 the most recent one.

22 That review criteria was against the
23 orders that were issued after the accident at
24 Fukushima Daiichi. Since that time, the Commission
25 has approved the new rule, 5150(5).

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So that was another driver for the
2 evolution of how the review is going to proceed in
3 this case. So, the Staff will brief on the SE that
4 we've generated but it should note that that SE is
5 largely based on Rev 2 of the FSAR.

6 Subsequent to us receiving Rev 2 to
7 Chapter 20, NuScale has significantly changed the
8 approach for their mitigation and beyond-design-basis
9 event strategies and has submitted a markup to the
10 Staff describing those changes.

11 So, we expect our SE to change based on
12 our review of the markup, however, we will describe
13 today the review criteria that we intend to use to
14 apply to the NuScale review.

15 So, I just wanted to let everyone know
16 it's a bit of a review in motion here. We will go
17 through the review criteria that we intend to use and
18 then answer any questions you guys have on that.

19 MEMBER RICCARDELLA: But the presentation
20 material that we just saw, was that per the markup or
21 per the original Rev 2?

22 MR. COYNE: I believe that reflects
23 NuScale's current position on their compliance with --

24 MEMBER RICCARDELLA: Which is what you
25 referred as the markup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TABATABAI: Yes.

2 MEMBER CORRADINI: So, is the markup then
3 connected with the Revision 1 of the technical report
4 that supports the chapter?

5 MR. COYNE: Yes.

6 CHAIR REMPE: My understanding is the
7 Staff will not be doing anything to reflect the
8 revised information that we saw today and the Rev 1 of
9 the technical report.

10 You're going to issue the SE pretty much
11 as is without accommodating this additional
12 information.

13 What we're trying to get to is, is this
14 the right time for us to be writing a letter or should
15 we wait if you're going to do an update in the next --

16 MR. COYNE: so, that's not a question I
17 can answer but I can tell you that we have different
18 phases in the review. So, what you have is the Phase
19 2 SE. It is what it is.

20 We will generate a Phase 4 SE, we have a
21 milestone date of mid-December to make that publicly
22 available.

23 And so that Phase 4 SE would definitely
24 reflect the current NuScale approach and our review
25 approach for that information.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: But if we were to
2 write a letter now we could comment on the criteria
3 that you're going to use for that evaluation. So,
4 that's what you said you're going to present today,
5 correct?

6 MR. COYNE: Correct. So, we will cover
7 the criteria that we intend to apply to the review
8 today.

9 MEMBER CORRADINI: Okay, maybe we'll just
10 ask the questions at the end instead of the beginning
11 because we'll take you on all sort of what-ifs.

12 So, once we see the criteria -- but the
13 criteria are not going to be any different than what
14 you would have applied to any other -- they're
15 design-specific for the NuScale design.

16 MR. COYNE: Ryan will cover that.

17 MEMBER CORRADINI: Okay, fine.

18 CHAIR REMPE: I'd like to also point out
19 that the SECY paper is not public yet but it will be
20 within a few weeks.

21 But I know one Member has already
22 approached me and said they'd like to have a closed
23 session to discuss this a little bit more.

24 And so we might want to also have some of
25 these questions after we get through the public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 portion of today's meeting. Okay?

2 MR. NOLAN: It should be publicly released
3 Friday.

4 CHAIR REMPE: Unfortunately, we've got to
5 do this now but yes, we'll discuss it a little bit
6 more.

7 MEMBER RICCARDELLA: If we're going to
8 write a letter it will be written by Friday.

9 CHAIR REMPE: Go ahead.

10 MR. TABATABAI: Thank you, Kevin. This
11 afternoon, we will be talking about some background
12 information.

13 As Kevin mentioned, this review has been
14 kind of dynamic in terms of information that we have
15 received and also the regulations that have been
16 operated and issued lately.

17 We will describe the Staff's review
18 approach and we will share with you some of the
19 preliminary findings that we have made in terms of our
20 evaluations.

21 The word preliminary here is because as
22 you know, these findings are based on kind of an older
23 version of information and review criteria. So, we
24 will be updating those in Phase 4.

25 We will describe our review of NuScale's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mitigating strategy and that is basically the topic of
2 the SECY paper that you mentioned. And Ryan will be
3 talking in detail about that.

4 And then we will describe our Phase 4
5 review strategy and plans. Before starting our
6 presentation, I'd like to recognize our team of
7 reviewers.

8 As you see, we have quite a few reviewers
9 who contributed to this review and preparing the SER
10 from various offices, NRR, NSER, and NRO. This slide
11 basically summarizes what Kevin mentioned during his
12 introductory remarks.

13 We received Rev 2 of Chapter 20 or design
14 certification application in October 2018. In January
15 the Commission approved the final MBDBE rule which
16 will be codified in 10 CFR Part 50S 50.155.

17 NuScale informed the Commission, the NRC
18 Staff, in March of 2019 that now that the rule has
19 been finalized they will revise their Chapter 20 to
20 make confirming changes to the information.

21 We received NuScale's Revision 3 or draft
22 Revision 3 markups on June 10th of this year and then
23 on June 14th, we received Revision 1 to the ELAP
24 topical report, extended loss of AC power.

25 One June 26th the Staff issued their SECY

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 paper which kind of describes how we plan to complete
2 the review of NuScale's Chapter 20 and the title of
3 the SECY paper is Staff Review of NuScale Power's
4 Mitigation Strategy for Beyond-design-basis External
5 Events.

6 And we are expecting for the rule to be
7 publicly available around September 2019.

8 MEMBER BLEY: I'm sorry, say that again?

9 MR. TABATABAI: In 2019 10 CFR 50.155 will
10 be published in the Federal Register.

11 MEMBER BLEY: Okay.

12 MR. NOLAN: Yes, it will be published and
13 final at that point.

14 MEMBER BLEY: So back in March -- Rev 2 of
15 Chapter 20 is up on your public website?

16 MR. TABATABAI: That's correct.

17 MEMBER BLEY: Did you say you now have Rev
18 3?

19 MR. TABATABAI: Yes, it was submitted on
20 June 10th.

21 MEMBER BLEY: You haven't really looked at
22 that yet or have you?

23 MR. TABATABAI: It is a markup, it is not
24 part of an entire DCA package. The entire DCA package
25 will arrived late August.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Okay.

2 MR. TABATABAI: But it is publicly
3 available.

4 MEMBER BLEY: Oh, it is?

5 MR. TABATABAI: It is.

6 MEMBER BLEY: Okay, are there substantial
7 changes?

8 MR. TABATABAI: Yes.

9 MEMBER BLEY: From 2 to 3?

10 MR. TABATABAI: Yes.

11 MEMBER BLEY: There are. And
12 they're consistent with Rev 1 of the tech report?

13 MR. TABATABAI: I will have to -- these
14 documents have been submitted very recently. We have
15 not completed detailed --

16 MR. NOLAN: Yes, but I think they were
17 revised together. So, Rev 3 of the FSAR and I think
18 Rev 2 of the tech report will be consistent.

19 MR. TABATABAI: NuScale wants ELAP to
20 support Revision 3 but, again, from the Staff's
21 perspective, we have not reviewed --

22 (Simultaneous speaking.)

23 MEMBER CORRADINI: Sure, but I think Ryan
24 said something I want to make sure of. So what is in
25 theory consistent? Rev 3 and TR-1? Or Rev 2 and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 TR-1?

2 MR. TABATABAI: Rev 3 and TR-1.

3 CHAIR REMPE: Is Rev 3 on the NRC's
4 website? Where is it?

5 MR. NOLAN: We've received a draft markup
6 and then when the entire FSAR is submitted as part of
7 Rev 3, which is expected at the end of August
8 timeframe.

9 CHAIR REMPE: So we cannot see Rev 3 right
10 now?

11 MR. TABATABAI: I can provide the ML
12 number. You can search it. It is not on the website
13 but it is in ADAMS, publicly available.

14 MEMBER BLEY: Well, if you can give us the
15 ML that would be good. Thank you.

16 CHAIR REMPE: While we're asking for
17 things, I saw that the SECY does refer to this March,
18 whatever, 19 letter that was mentioned earlier today.

19 And it's a publicly available ML number or
20 do I have to go to the private one?

21 MR. TABATABAI: No, it's publicly
22 available.

23 Staff's Phase 2 review approach, as I
24 mentioned, because of the timing of different
25 submittals and availability of Staff's review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance, the latest final rule is not reflected in
2 that.

3 Although, it's part of SRM SECY which was
4 issued in January. That's the latest publicly
5 available guidance document that we have.

6 But most of our, I mean all of our,
7 evaluation findings in the SER are based on Revision
8 2 of the NuScale DCA.

9 These are the lists of all of the
10 regulatory documents or guidance documents that we
11 used to evaluate NuScale's DCA Rev 2.

12 And based on the documented information,
13 our findings currently are only for the first 72 hours
14 after initiation of a beyond-design-basis event.

15 MEMBER CORRADINI: I want to make sure, so
16 the SECY gives the rationale as to why you're stopping
17 at three days?

18 MR. TABATABAI: That's correct. The SECY
19 is not public yet but --

20 MEMBER CORRADINI: I understand. When it
21 is, the reasoning for that bullet is there?

22 MR. TABATABAI: That's correct. The last
23 part of the SECY discusses why the Staff is going only
24 up to 72 hours.

25 MEMBER CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOLAN: And we'll touch on it.

2 MEMBER BLEY: It talks about how you're
3 doing the review as well, which you can tell us now?

4 MR. TABATABAI: Yes.

5 MEMBER BLEY: Go ahead.

6 MEMBER SKILLMAN: Omid, on that slide,
7 please, you identify it as NEI 1206 Rev 2 but in the
8 safety evaluation you identify that the key safety
9 functions are identified in NEI 0612 Subsection 423.

10 You also communicate it's NEI 0612
11 Revision 3. So, is there a disconnect between this
12 slide and what is in your safety evaluation?

13 MR. TABATABAI: No, there were actually
14 different revisions. It depends whether or not the
15 NRC proved or endorsed any of those NEI guidance
16 documents.

17 I think in the SER for different
18 subsections in Chapter 20, you might notice various
19 NEI revisions or various guidance. But on this slide
20 I have kind of listed those major recurring themes
21 that you see in the SER.

22 It doesn't really include every single
23 revision of the NEI or 1206 or 1202. It doesn't list
24 all of that. This is what the main, basically the
25 main, guidance documents that we have used.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Well, then I mean
2 confused because it seems that this is referring to --
3 it's on Page 34 of the PDF.

4 It is technical evaluation 20.2.4 and this
5 sets out what the Staff has identified as the key
6 safety functions. So, this is the heart of your
7 review.

8 MR. TABATABAI: Right. Under LOLA --

9 MR. ASHLEY: Hi, this is Clint Ashley from
10 the Staff. I think the confusion is these numbers are
11 NEI 1206 and NEI 60612.

12 One of them, the first one, is for
13 mitigation strategies. The second one is for loss of
14 large areas. And so that's why you'll see those two
15 numbers in the safety evaluation, because Chapter 20
16 of NuScale covers both topics.

17 MEMBER SKILLMAN: Fair enough, thank you.

18 MR. TABATABAI: Next slide. So, on this
19 slide we have summarized our preliminary findings of
20 NuScale Chapter 20 information.

21 There are four subsections in Chapter 20.
22 Section 20.1 talks about mitigation strategies. This
23 is basically what NuScale presented to the Members
24 before us and that is the subject of Ryan's
25 presentation later on during this presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We also reviewed Subsection 20.2, which is
2 LOLA, loss of large area, and 20.3, emergency
3 procedures, and 20.4, enhanced emergency response
4 capabilities.

5 With respect to loss of large area, the
6 Staff used SRP guidance in Section 19.4 and that
7 section basically talks about how to review to make
8 sure information or design complies with regulatory
9 requirements in 50.54 HH2.

10 In that section, the Staff specifically
11 looked at five different criteria with respect to RCS
12 reactor cooling system inventory or RCS heat removal,
13 containment isolation and containment integrity, and
14 released mitigation.

15 I just don't want to get into details of
16 the review but we looked at the SRP guidance and
17 looked at the information that NuScale had provided.

18 And we confirmed that the information in
19 the design meets the regulation. We have no open
20 items on this topic, we won't have any issues.

21 MEMBER BLEY: Something still isn't
22 completely clear to me. I thought when I read their
23 Chapter 20, NuScale's Chapter 20, that they based it
24 on the draft mitigation beyond-design-basis event
25 rule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Is that true, number one? And then number
2 two, the final rule you said will come out later in
3 the year and the revision will essentially be against
4 that.

5 Are those two statements both correct?

6 MR. TABATABAI: Yes.

7 MEMBER BLEY: Okay, thank you.

8 MEMBER DIMITRIJEVIC: Well, I have one
9 really basic question. I'm not sure, how did you take
10 out considering damage to ultimate heat sink?

11 Because ultimate heat sink is always part
12 of the beyond-design-basis events and here something
13 says, okay, they have this big pool and this is not
14 any, I mean, I don't know, seismic size or whatever,
15 sink opening like in CAD, the damage done.

16 MR. NOLAN: Yes, so the 5150(5) rule techs
17 addresses this specifically for passive plants and
18 that is loss of access to the normal heat sink, not
19 the ultimate heat sink for passive designs.

20 MEMBER DIMITRIJEVIC: So, it does
21 specifically say that?

22 MR. NOLAN: Yes.

23 MEMBER DIMITRIJEVIC: Interesting, based
24 on what?

25 MEMBER CORRADINI: I think you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 connecting what Charlie asked and what we were talking
2 about actually at break, which is they're using the
3 same terminology, whether it be an active plant or a
4 passive plant.

5 MEMBER DIMITRIJEVIC: I understand the
6 difference in terminology. I'm just sort of surprised
7 that damage to this big pool through the big seismic
8 event, was not considered.

9 That's what I am sort of -- it's not a
10 part of beyond-design-basis events, that's why I'm
11 surprised.

12 MR. NOLAN: So, if it's being relied on
13 for mitigation strategies of the beyond-design-basis
14 external event, it would still need to be reasonably
15 protected.

16 And the NEI guidance steps through -- I
17 think they use the phrase robustly protected. And so
18 we would still ensure that any SSC that's relied on
19 for the mitigation strategies is appropriately
20 protected for that event.

21 MEMBER DIMITRIJEVIC: For which event?

22 MR. NOLAN: Beyond-design-basis external
23 event.

24 MEMBER DIMITRIJEVIC: Yes, but that can be
25 anything. A seismic event in magnitude, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. NOLAN: So, the guidance specifies
2 it's designed to the design basis SSC.

3 MEMBER DIMITRIJEVIC: Of the design basis?

4 MR. NOLAN: Yes.

5 MEMBER DIMITRIJEVIC: But this is
6 beyond-design-basis?

7 MR. NOLAN: That's correct.

8 MEMBER RICCARDELLA: Yes, but as I
9 understand it that's no different than the operating
10 plants with their FLEX equipment, right? Their FLEX
11 equipment is not designed for a beyond-design-basis
12 earthquake.

13 (Simultaneous speaking.)

14 MEMBER BLEY: That is true, Pete.

15 MEMBER RICCARDELLA: That is true. But
16 again, considering seismic, what it's designed for is
17 different, I think, than what it's ultimate capacity
18 really is.

19 So, it's designed for maybe -- the SSC is
20 like a ten to the minus four event but the containment
21 or any of this equipment could probably survive a ten
22 to the minus six event without actually failing.

23 Because there's margins and safety factors
24 in the design. As we've seen this morning, we've seen
25 plants survive earthquakes that are significantly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 above their SSC.

2 MEMBER BLEY: But you can't assume that
3 it's --

4 MEMBER RICCARDELLA: No, you can't assume.
5 (Simultaneous speaking.)

6 MEMBER BLEY: -- the magnitude. I think
7 the one thing you can say is all the cases where
8 people have really looked hard, it's not a cliff.

9 If you go a little bit beyond, you aren't
10 all of the sudden in trouble. It drops off.

11 MEMBER RICCARDELLA: Well, I guess the key
12 is that should probably be part of the seismic PRA for
13 this plant.

14 MEMBER BLEY: It certainly should be, yes.

15 MEMBER DIMITRIJEVIC: This is a different
16 situation.

17 I mean this is beyond-design-basis event
18 and in this case if we consider just damage, let's
19 say, leak or spillover or something due to a seismic
20 event, they have to prove they have makeup capability
21 within the timeframe, right?

22 Which is not part of the discussion.

23 MR. NOLAN: So, for the purposes of this
24 discussion, we are just implementing the rule as
25 written.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so if you take a look at the rule
2 text, I think it's 5150(5)(C)(2), it says that the
3 equipment must be reasonably protected from the
4 effects of natural phenomena that are equivalent in
5 magnitude to the phenomena assumed for developing the
6 design basis of the facility.

7 So, that's what the rule specifies.

8 MEMBER BROWN: I want to understand just
9 one more time here.

10 The extended loss of all AC and the loss
11 of the ultimate heat sink issue is fundamentally
12 assumed that 24 hours later the ECCS comes on?

13 Whenever it's triggered, it assumes that
14 the reactor pool remains intact through all of this?

15 MR. NOLAN: That's correct.

16 MEMBER BROWN: So, seismic event reactor
17 pool, that's really the loss of the ultimate heat sink
18 and that's assumed not to happen? The ultimate --

19 (Simultaneous speaking.)

20 MR. NOLAN: Right, that assumption goes
21 beyond what the rule specifies.

22 (Simultaneous speaking.)

23 MEMBER BROWN: Whether it's realistic or
24 not, it's beyond the point. That's what the rule
25 says.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: But Charlie I mean
2 has I think cracked the ultimate sink is probably
3 something that's not a big deal. Total destruction
4 would be a big deal.

5 MEMBER BROWN: I agree with you. If it
6 starts leaking, when do they start adding water back
7 in? 30 days when they statute replenishing? Or if
8 they have to from the boil, 45 days? 50 days?

9 Whatever it was, there was some number of
10 days when they would have to start making up inventory
11 in the reactor pool. So, if it cracks you're going to
12 lose some, I presume, 50 days.

13 Even if they could start doing at 30 days,
14 it's based on all the risks so it would probably be
15 okay. I'm being too generous right now.

16 All right, you answered my question, thank
17 you.

18 MR. TABATABAI: Okay, the last point I'd
19 like to make on this slide is that we understand that
20 Revision 3 to Chapter 20 will not have these Sections
21 20.3 and 20.4.

22 In the SER, because there are some COL
23 action items listed under 20.3 and 20.4 and we're
24 defining the findings on those COL items to the COL
25 application stage, not during the design certification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stage, but according to -- the new rule doesn't
2 require them and NuScale we understand will not list
3 any COL action items for these items, emergency
4 procedures or enhanced emergency response.

5 CHAIR REMPE: I know you said it clearly
6 but I just want to make sure because the current
7 version that I reviewed basically just says there's a
8 COL action and they're just going to have nothing on
9 those two sections.

10 MEMBER CORRADINI: Per the new rule?

11 MR. TABATABAI: Yes.

12 CHAIR REMPE: Because the new rule says
13 not to do that? Which hasn't been issued yet, the new
14 rule, because it's not coming out until September of
15 2019.

16 MR. TABATABAI: The Rev 3 to design
17 certification application comes in August, last
18 August, and that will be available publicly. But the
19 rule will be published in September some time.

20 CHAIR REMPE: Interesting.

21 MR. SCHULTZ: Right now it's really just
22 a placeholder for these and they're going to take out
23 the placeholders?

24 MR. TABATABAI: That's correct.

25 MR. SCHULTZ: And you're going to accept

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that these items can be discussed at the COL stage and
2 that review will be done in detail then?

3 MR. TABATABAI: That's correct.

4 And I think when Ryan goes through his
5 presentation, one of the reasons we're talking about
6 72 hours is responsibility of COL Applicants versus
7 design certification.

8 So, with that, my portion of the
9 presentation is finished and I'll turn it over to
10 Ryan.

11 MR. NOLAN: All right, thanks Omid. The
12 first few bullets here is kind of an overview.

13 We've discussed a lot of this already but
14 from a regulatory framework perspective the recently
15 approved regulation, 5150(5), for mitigation for
16 beyond-design-basis events does not apply to
17 Applicants for design certification.

18 So, it would be applicable to the COL but
19 not to the design certification Applicant. And as was
20 stated previously, NuScale is voluntarily seeking the
21 NRC to approve the use of its installed design
22 features for the mitigation strategies.

23 As many of you are already aware, the
24 NuScale design incorporates several unique design
25 features that provide enhanced coping capability for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 extended losses --

2 MEMBER BLEY: I've been trying to parse
3 your opening statement and I thought I understood that
4 it does not apply to Applicants for a design cert. I
5 thought it had COL up there.

6 But you said it will apply to COL?

7 MR. NOLAN: It does apply to the COL.

8 MEMBER BLEY: Okay.

9 MR. NOLAN: And so NuScale is seeking
10 finality to the extent -- yes.

11 CHAIR REMPE: I know this kind of goes
12 between both of you but earlier today we heard, well,
13 other Applicants have done something like KHMP did.

14 Did they do more than just the mitigation
15 and beyond-design-basis events? Did they also do the
16 LOLA?

17 And I know I participated in the letter,
18 I'm just trying to remember did they do the thing
19 about emergency procedures and integration of
20 procedures and emergency response?

21 Or did they focus just on LOLL and
22 mitigation of beyond-design-basis events?

23 MR. NOLAN: I can't recall the specifics.

24 Is there anyone out there who can speak to
25 the procedure side of -- from a LOLA perspective, they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 address the design features, which is typical of what
2 most design cert Applicants have done.

3 So, they've addressed the design feature
4 piece of the LOLA requirements.

5 CHAIR REMPE: Do they have to do it?

6 MR. NOLAN: No.

7 CHAIR REMPE: It's a --

8 (Simultaneous speaking.)

9 MR. NOLAN: Yes, 5054(h)(h)(2) is similar
10 in that it's only applicable to the licensee. In this
11 case it would be the COL.

12 MR. TABATABAI: Bob Vettori is our lead
13 reviewer for that area.

14 MR. VETTORI: Okay, for LOLA all the
15 operational stuff's going to go in the COL. That's
16 what KHMP did also.

17 CHAIR REMPE: Okay. You have to say who
18 you are, I'm sorry.

19 MR. VETTORI: I'm sorry, Bob Vettori, NRO.

20 MR. NOLAN: And I guess since we were
21 talking about LOLA just now, I'll just make the point
22 that the 5054(h)(h) requirements are getting absorbed
23 into 5150(5).

24 And so once 5150(5) is published,
25 50549(h)(h) will kind of transfer over.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You can go to the next slide. I just put
2 this up here for reference since it's probably been a
3 little while since some of you have seen the rule
4 text. Maybe it's new to a lot of you as well.

5 And these are just the pertinent portions
6 of 5150(5) just for your reference.

7 MR. SCHULTZ: Ryan, I don't see 72 hours
8 mentioned anywhere here. You've got lots of
9 dot-dot-dots. I didn't think it was.

10 MR. NOLAN: Yes, it actually says
11 indefinitely, the rule says indefinitely.

12 And I'll talk a little bit more about the
13 criteria we're using but the main goal is to remain
14 consistent with what was done for the operating fleet
15 as well as the previous design cert Applicants.

16 MR. SCHULTZ: Thank you.

17 MR. NOLAN: So, as a brief overview,
18 NuScale already went over a lot of this, but their
19 approach, because of the uniqueness of their design,
20 they rely mostly on safety-related SSCs, their AC and
21 DC independent systems.

22 And I think many of you have seen what
23 that event progression looks like. They're requesting
24 a minimum coping duration of 14 days with the
25 justification that 14 days provides sufficient time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for a licensee to establish an alternate means of heat
2 removal.

3 And then the last point here is the
4 position that there's no reliance on monitoring for
5 mitigation strategies.

6 And there was a few notes in their March
7 28th letter and I think in the technical report, I
8 haven't looked at the FSAR too closely, but there's a
9 couple points that say instrumentation is expected to
10 be available in the near term and that monitoring is
11 there as a supplementary capability.

12 CHAIR REMPE: So, I know it's in a later
13 slide but it has your plans to document that it's not
14 relied on unless but it's expected. And I think
15 that's in the SE also.

16 How are you planning to make sure your
17 expectations are met with respect to qualification of
18 the instrumentation?

19 MR. NOLAN: Sure, I think we looked at it
20 from a robustness, to make sure that it's robustly
21 protected.

22 It's designed for the SSC, it's located
23 inside protected areas, not susceptible to wind or
24 flooding hazards. It's protected to the external
25 event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: So, protection from external
2 events is your way of making sure that -- you've heard
3 me whine about I want to make sure that it will be
4 qualified for the fluence levels it may experience.

5 And is that going to be codified somehow,
6 like in the ITAC, for qualifying the instrumentation?

7 MR. TABATABAI: I believe it's already a
8 design commitment. Dinesh Taneja is walking to the
9 microphone to explain it.

10 MR. TANEJA: This is Dinesh from NRO, NRC
11 Technical Reviewer. So, a lot of these instruments
12 that are relied on upon are part of their normal
13 instrumentation.

14 If you look at Chapter 3, your EQ
15 requirements, for example, containment level, right
16 now is required to be operational for 100 days, to
17 qualify for 100 days of operation. So, that is a
18 design commitment.

19 Seismic, radiation, and temperature so the
20 EQ qualifications.

21 CHAIR REMPE: And the radiation will be
22 for the flux levels or fluence that it experiences?

23 MR. TANEJA: 100 days post-accident. So,
24 whatever that total integrated dose is, that's what
25 needs to be qualified.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: And that's actually in
2 Chapter 3?

3 MEMBER DIMITRIJEVIC: Chapter 3, 3.10.
4 2.10. There's a table for the instruments and what
5 the requirements are.

6 CHAIR REMPE: Okay, I'll check again.
7 Thank you for reminding me.

8 MEMBER BLEY: I know you guys have used
9 robust a lot and it jumped off the page at me reading
10 their Chapter 20, Robust Makeup Line with External
11 Connection Point.

12 I take it robust is defined in one of the
13 NEI documents or both of them, and is it defined in a
14 qualitative way? And can you explain that?

15 Or is it defined in some kind of
16 quantitative way?

17 MR. NOLAN: I don't have that information
18 in front of me right now.

19 MEMBER BLEY: Whoever's decided you agree
20 that these things are robust, what does that mean?

21 MR. HERNANDEZ: Hello, my name is Raul
22 Hernandez from Bottle Supply. You're talking about
23 the makeup line to the spent fuel pool?

24 MEMBER BLEY: That was the one that jumped
25 off the page at me but it's used over and over and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 over again and I heard it referenced that it's the
2 NEI document that requires all of these things to be
3 robust.

4 And I want to know what that means, either
5 from your interpretation of the NEI document or how
6 you guys used it, not just for that line but for all
7 of these cases.

8 MEMBER RICCARDELLA: I want to
9 echo Dennis's question because the Applicant uses
10 that. And so the Staff have an agreement on what the
11 definition is.

12 MEMBER BLEY: Somebody told us earlier
13 it's as defined in one of the NEI documents, I forget
14 which one. But if you can tell us what it means --
15 (Simultaneous speaking.)

16 MR. HERNANDEZ: For the level instruments
17 of --

18 MEMBER BLEY: And why is that true? How
19 did you decide that or did you just --

20 MR. HERNANDEZ: It is described in Section
21 9.1.3, spent fuel pool design. It discloses the
22 makeup line and the NEI documents, if I'm not
23 mistaken, is 1206.

24 MEMBER BLEY: It's in 06?

25 MR. HERNANDEZ: That's for the level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instrument, that's the one that I'm responsible for.

2 MEMBER BLEY: So, it's not defined in a
3 general way?

4 MR. NOLAN: I think from a qualitative
5 sense it's protected to the applicable hazard, right?
6 And so it needs to be protected to wind and missiles,
7 to snow and ice, to the seismic event.

8 MEMBER BLEY: So you think that's the way
9 it's --

10 MR. NOLAN: Yes, so if it's being relied
11 on for mitigation strategy it needs to be protected to
12 those hazards.

13 MEMBER BLEY: In a qualitative sense it
14 converts to a quantitative sense in specific examples.

15 MR. TABATABAI: Dr. Bley, Peter Bamford is
16 from the Japan Lessons Learned so he can probably --

17 MR. BAMFORD: Peter Bamford, NRR. I
18 worked on a lot of the operating plant reviews.
19 Robust is defined in NEI 1206, there's a definition of
20 this action and it's defined there.

21 Specifically, what it means is you can be
22 robust in a couple of different ways. One is if it's
23 safety-related protected to all the plants, external
24 hazards, that would generally qualify as robust.

25 Because safety-related, it meets all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seismic, tornado, flooding, any of the postulated
2 external events.

3 In addition, a licensee could show by
4 analysis, let's just say they had a piece of equipment
5 that was not necessarily safety-related but they could
6 show by either analysis or test it would likely be
7 available after the postulated external events.

8 Those would be considered as robust also
9 and all that is encompassed in the definition in NEI
10 1206. I hope that helps.

11 MEMBER BLEY: That helps a lot, thank you.

12 MR. SCHULTZ: And NuScale puts those
13 prescriptions associated with the external events,
14 they list the conditions from Chapter 3 I believe it
15 is, that defines what the equipment will survive for
16 each of the events.

17 Cold, heat, seismic, and so forth.

18 MR. NOLAN: Right, and so it's short-hand
19 up here but most of the SSCs that NuScale's relying on
20 are safety-related.

21 One exception is the EDSS, the batteries,
22 however, they have unlimited quality, they are
23 designed to the SSC as specified in Chapter 3 as well
24 as those other requirements imposed on the battery
25 system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: The 14 days for alternative
2 heat removal, that means your ability to put water
3 into the spent fuel pool or into the reactor pool?
4 Which one is it?

5 (Simultaneous speaking.)

6 It's not totally the same thing. Don't
7 you have to overflow? I thought there was something
8 you had to overflow from the spent fuel pool to get
9 into the --

10 MR. NOLAN: Yes, the connection is to the
11 spent fuel pool.

12 MEMBER BROWN: I thought I read something
13 about something had to overflow into something, from
14 one part to -- I forgot which way it went.

15 MEMBER RICCARDELLA: Spent fuel over the
16 weir to the --

17 MEMBER BROWN: To the reactor pool. So,
18 if the reactor pool boiled up, you'd fill the spent
19 fuel and it would spill over into the reactor. My
20 memory is not as bad as I thought, thank you.

21 MR. NOLAN: And if you're only at decay
22 heat levels, I wouldn't expect the water level to be
23 below the weir within 14 days.

24 MEMBER BROWN: No, that's why based on the
25 other discussions I was assuming that boil-off would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 occur almost two times that much but I don't remember
2 the exact numbers.

3 PARTICIPANT: It looks like the weir is
4 uncovered at 130-something days.

5 PARTICIPANT: 150.

6 MEMBER BROWN: No, the top of the fuel,
7 not the weir.

8 PARTICIPANT: The weir comes before that.

9 MEMBER BROWN: That's right.

10 PARTICIPANT: It's ten feet above.

11 MEMBER BROWN: Thank you.

12 MR. NOLAN: Okay, so the next few slides
13 I'm going to go over the Staff's review approach.

14 MR. SCHULTZ: Ryan, before you leave that
15 slide, that's the last time you mentioned 14 days.

16 MR. NOLAN: Right, that's what NuScale is
17 proposing.

18 MR. SCHULTZ: That's what they've
19 proposed?

20 MR. NOLAN: Correct.

21 MR. SCHULTZ: Let's wait until you're
22 finished then.

23 MR. NOLAN: So, like I mentioned before,
24 one of the most important things for our review
25 approach is to maintain consistent with what we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done for the operating plants as well as previous
2 design certifications.

3 We've received several SRMs from the
4 Commission reiterating consistency with the operating
5 reactors and implementing this rule.

6 MEMBER CORRADINI: So, by saying it that
7 way, can I translate that?

8 MR. NOLAN: Sure.

9 MEMBER CORRADINI: So, you don't feel that
10 you have the ability to go beyond three days to make
11 a judgment because it's not in the regulation or what?

12 MR. NOLAN: It's not necessary.

13 MEMBER CORRADINI: Not necessary?

14 MR. NOLAN: To go beyond 72 hours.

15 MEMBER CORRADINI: Because technically --

16 MR. NOLAN: At the design cert level. And
17 so for the operating plants what we did is -- the
18 focus of the staff's review is on the initial
19 response.

20 This is where the most critical and
21 time-sensitive actions are projected to occur. And
22 there wasn't a lot of review that was performed once
23 you get our far in time.

24 MEMBER CORRADINI: So, this is the one
25 part I guess I and to investigate for me at least.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, the 72 hours in some sense is the
2 equivalent of Phase 3 of the current plants in terms
3 of Phase 1 install, Phase 2 FLEX, Phase 3 beyond FLEX
4 to safer?

5 Approximately.

6 MR. NOLAN: There's variations, yes.

7 MEMBER CORRADINI: Okay, so I'm still
8 trying to understand the technical reason.

9 The technical reason you're saying is
10 because all the crucial stuff occurs in the first
11 three days and after that things should be stable and
12 therefore there's no need to look at it?

13 MR. NOLAN: At the design certification
14 level.

15 MEMBER CORRADINI: So, because NuScale is
16 going beyond that to help the potential
17 owner/operator, Staff doesn't feel compelled to
18 analyze it yet?

19 MR. NOLAN: Right, we'll take a look at
20 the post-72-hour strategy during the COL review.
21 That's discussed on the next slide.

22 MEMBER CORRADINI: Okay, all right, but
23 I'm trying to formulate this correctly. If it's
24 obvious that they can make it past 72 days, you don't
25 feel compelled to note that in the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certification analysis?

2 MR. SCHULTZ: That's what I was going to
3 get to later, that question.

4 MEMBER CORRADINI: Sorry.

5 MR. SCHULTZ: No, that's fine.

6 MR. NOLAN: We don't feel it's necessary
7 for us to make a regulatory finding beyond the 72
8 hours. It's not required for us to make any
9 regulatory finding.

10 This rule is not applicable to the design
11 cert Applicant, right? It's applicable to the COL.
12 And so right now where we are with the review, we can
13 make a 72-hour reasonable finding and then beyond
14 that, it will be the responsibility of the COL.

15 And like I said, it's consistent with what
16 we did for the operating reactors. That's where the
17 focus of the Staff review was, was there.

18 We did not spend a lot of resources
19 looking out two weeks, three weeks, four weeks. But
20 it's consistent with what we did for --

21 MR. SCHULTZ: But the operating reactors
22 have invested a lot to demonstrate what would happen
23 at 72 hours and beyond. That's the industry response
24 that's associated with it.

25 I don't want to speak for NuScale but I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thought they were trying to get some understanding
2 that the design of this facility is such that one
3 would not have to do something at 72 hours.

4 And if we could get some determination
5 that 14 days is a reasonable time to paint the picture
6 of what needs to be done when, rather than 72 hours,
7 it would make the COL, the potential COL Applicants,
8 more excited about this design than hearing that it's
9 a 72-hour stopping point where they've got to do
10 something more, including analysis or whatever else it
11 might be.

12 So, they're asking for 14 days as opposed
13 to 72 hours, getting an agreement up above but you
14 don't necessarily have to make a determination as part
15 of your design cert agreement, right?

16 MR. NOLAN: Yes.

17 MR. SCHULTZ: Have you decided not to give
18 them that or are you --

19 MEMBER BROWN: That's what the SECY's all
20 about.

21 MEMBER BLEY: And that part of it I think
22 isn't a public discussion at this time. We can have
23 a session later.

24 MEMBER BROWN: It isn't, you're probably
25 right. I didn't think about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: But in the public
2 discussion, though, you can say that -- do you have
3 enough information? Do they give enough out?

4 Or have you just not looked at anything
5 beyond three days? Do you think there's enough
6 information or you think it would -- they're going to
7 have to --

8 MR. NOLAN: It would require more work
9 most likely on both sides.

10 CHAIR REMPE: You've looked at it enough
11 to say this is going to take a lot more?

12 MR. NOLAN: Right, so as you're aware,
13 during the Chapter 15 presentation there's a few
14 transient phenomena that we're evaluating and we
15 expect to resolve that for the 72-hour timeframe.

16 But it would probably take a closer look
17 to make findings that go beyond 72 hours.

18 CHAIR REMPE: Such as recriticality?

19 MR. NOLAN: Correct.

20 MEMBER CORRADINI: But I thought
21 criticality doesn't apply to this event? It applies
22 when you're missing a rod.

23 (Simultaneous speaking.)

24 MR. NOLAN: It doesn't apply to this.

25 MEMBER DIMITRIJEVIC: It doesn't apply to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this event. Actually, you don't have any difference.

2 (Simultaneous speaking.)

3 MR. SCHULTZ: Based on the stylized
4 assumptions, it doesn't apply.

5 MR. NOLAN: Well, it depends on what event
6 and phenomena you're talking about. If you're talking
7 about boron redistribution, that's just a transient
8 phenomena that is potentially going to occur.

9 The difference here is we would assume all
10 rods in so that buys a lot of margin. In Chapter 15
11 we would assume one rod out.

12 MEMBER CORRADINI: I know we're not
13 allowing you to go down your normal path but such is
14 life.

15 In the draft SE, the identification of
16 boron dilution is one of the things that is
17 renumbered as an open item but is unresolved in this
18 regard?

19 MR. NOLAN: Right, and so following this
20 approach that we're laying out here, we would not
21 expect that to be an issue for Chapter 20 review.

22 We would take another look at that during
23 the COL and as part of the COL review we would look to
24 make sure there isn't any credible transient phenomena
25 that can affect recriticality or anything else for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that matter.

2 MEMBER CORRADINI: You got me there
3 because I thought you were going to say something
4 different. So, what I read in the draft SE, in
5 essence, doesn't apply now because of the 72-hour
6 consideration?

7 MR. NOLAN: That's with the assumption
8 that Chapter 15 will resolve the issue.

9 MEMBER CORRADINI: Ah, okay, sorry. It's
10 still tied back to 50?

11 MR. NOLAN: Yes.

12 MEMBER CORRADINI: Okay, excuse me, sorry,
13 I misunderstood. Thank you.

14 MEMBER DIMITRIJEVIC: I don't see the real
15 logic here. I don't see why -- why when you pass 24
16 hours would this analyze this? Everything is the same
17 up to -- I mean, there is not any reason for you to
18 stop at 72.

19 Even in the earlier discussion, this rule
20 doesn't apply for this situation. You don't really
21 have any reason to stop at 72 logically. If you give
22 them 72, the 14 days are completely the same.

23 So, I don't really see. I heard your
24 discussion about this Chapter 15 72 hours but that
25 doesn't apply. You have rules which are applicable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here.

2 MR. SCHULTZ: I took it from the
3 Applicant's response to the question about the spent
4 fuel pool instrumentation and the DC power required
5 for that, that that is their conclusion.

6 That if they can provide that power for
7 that instrumentation, then 72 hours and 14 days are
8 the same, if you will. That was the only piece that
9 they see is required to demonstrate 14 days.

10 MR. COYNE: Kevin Coyne, NRO.

11 So, in Ryan's next slide he's going to
12 talk a little bit more about the expectations for the
13 COL relative to some of the discussion.

14 But going beyond 72 hours, one of the
15 considerations the Staff had is given NuScale's unique
16 features and enhanced capability to deal with the
17 damaged state that's assumed in 5150(5), we didn't
18 want to create a de facto, more restrictive standard
19 for the review than what we applied to the operating
20 reactors.

21 And so having to make a regulatory finding
22 after 14 days for NuScale could be viewed as imposing
23 a more restrictive criteria for the review for Chapter
24 20 than what we would apply to the operating fleet.

25 CHAIR REMPE: Could you elaborate why you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think it's going to be more restrictive?

2 Yes, you went two more hours but what's
3 going to be more restrictive than for the operating
4 reactors, other than you're going to be doing
5 something more in depth for a longer period of time?

6 MR. COYNE: So, I think just that, that we
7 would be doing a more in-depth review for a longer
8 time period.

9 MEMBER RICCARDELLA: But I thought I heard
10 someone say you will be doing that at the COL stage?
11 Did I hear that?

12 MR. NOLAN: And I'll talk about that on
13 the next slide. The last point I'd like to make on
14 this slide is that what we're reviewing are the design
15 aspects.

16 It's the installed SSCs, that's what, if
17 granted, the Commission would be providing finality
18 on. The operational aspects or procedures training,
19 that's all deferred to the COL, which is typically
20 what we'd expect for procedural development.

21 MEMBER CORRADINI: So, let me say it a
22 different way just so I'm clear.

23 So, the 72 hours at this stage, even
24 though it's not necessary for the DCD, going beyond 72
25 hours could set up a precedent for going in the past

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and I assume into the future?

2 MR. NOLAN: Right, yes, it's not necessary
3 for us to make a finding beyond 72 hours.

4 MEMBER CORRADINI: And the SECY is
5 informational, it's not a vote?

6 MR. NOLAN: Correct.

7 MEMBER CORRADINI: Yet.

8 MR. NOLAN: Correct.

9 MEMBER BLEY: Procedural question since
10 Mike brought that up.

11 I remember vaguely that when you send up
12 an information paper, if there's no voter, no SRM, at
13 some point in time it's assumed the Commission agrees
14 with you. Is that not true?

15 And what is that point in time?

16 (Simultaneous speaking.)

17 MR. NOLAN: That's a great question. I'm
18 not sure I want to be the one to step up to answer it.

19 MR. COYNE: Kevin Coyne, NRO. I don't
20 think that's a question that NRO can answer. We can
21 do a little research for you and try to get back to
22 you.

23 MEMBER BLEY: Okay, somebody's told you
24 about that in the past and I was just trying to get
25 that fixed. But, yes, do a little research and let us

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know.

2 CHAIR REMPE: So, at the beginning of this
3 meeting today we discussed about how we might have a
4 letter this week, we might have a letter in September.

5 Any feelers or senses that the Commission
6 is going to act on this before September that you'd be
7 willing to put on the record?

8 MR. TABATABAI: I think consistent with
9 the other Chapters that you have written letters, your
10 letters are preliminary I think, or interim reports?

11 PARTICIPANT: Interim letters.

12 MR. TABATABAI: I think interim reports is
13 appropriate in this case. I think so. I think during
14 Phase 5 you might have the final letter.

15 CHAIR REMPE: For example, if the
16 Commission decided to do more than just take the
17 information, if they did decide to respond back, no
18 one has given you any clues that's going to come
19 before September?

20 MR. TABATABAI: No, we can't predict that.
21 We can't stop the review either.

22 MR. NOLAN: So, like I mentioned on the
23 previous slide, what the Staff is reviewing for the
24 design certification is the capabilities and
25 capacities of the installed SSCs to basically satisfy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the required safety functions.

2 For the COL review, if there is no
3 transient phenomena that's identified or applicable,
4 then no additional information would be needed. There
5 would be nothing else needed from a COL at that point.

6 And the basis here, well, I guess the
7 second bullet is level of detail that we expect from
8 the COL would be commensurate with the time available
9 to implement.

10 What that means is we would have to
11 understand the site, where it's located, and any
12 required operator actions.

13 And so if there's a required action to
14 refill the spent fuel pool, we wouldn't expect to have
15 detailed contracts in place to acquire that inventory
16 but we would expect to see some plan of where it's
17 coming from, what the general procedure would be.

18 MR. SCHULTZ: Are you expecting that a COL
19 is going to somehow come up with a design feature that
20 has got a spent fuel pool requirement there that's not
21 50 or 60 hours?

22 But rather somewhere between 72 hours and
23 14 days? I don't know if that example fits, the
24 example you just gave.

25 MR. NOLAN: Well, I mean right now we know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that water will have to be added into the pool
2 eventually. The requirement is indefinite coping and
3 so eventually water will have to be added.

4 We just have a long time constant here to
5 take those actions. And so because there's a lot of
6 time to take the action, we wouldn't expect contracts
7 in place for this design.

8 But we would expect to see some plan on
9 where's that water coming from.

10 MR. SCHULTZ: Okay, I was probably just
11 quibbling with the selection of spent fuel pool level
12 for that but I could understand it for other
13 applications perhaps.

14 I got your concept so thank you.

15 MR. NOLAN: And with respect to
16 instrumentation, our plan is to document that their
17 instrumentation is not relied on to support the
18 mitigation strategies, that instrumentation is not
19 needed to take operator action.

20 However, it is expected to be available
21 and meets the robust protection requirements, and it's
22 just an added assurance.

23 MR. SCHULTZ: Again, this is all aligned
24 to demonstrate that the design under the design
25 certification process meets the requirements of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 new rule?

2 MR. NOLAN: That's correct.

3 MR. TABATABAI: That concludes Ryan's
4 presentation. So, where do we go from here?

5 Our plan for completing the review is to
6 follow what we have outlined in SECY 19-0066 to
7 complete the review of NuScale application when we
8 receive Revision 3 of Chapter 20 to make sure
9 information meets the requirements in 10 CFR 5150(5).

10 As I mentioned earlier, we are expecting
11 Revision 3 to be submitted in late August of this
12 year.

13 And last but not least, our full committee
14 presentation is scheduled for tomorrow and we would
15 like to receive your feedback as to what your
16 expectations are for us to present to you tomorrow.

17 If there are any specific areas that you'd
18 like us to focus on or you would like to repeat the
19 same information to the full committee, Just please
20 let us know.

21 MEMBER CORRADINI: For a practice nature
22 you're going to have one more attendee I think, unless
23 I did my math wrong. And so I think that's probably
24 the only difference in the audience.

25 But I guess I have questions I'm still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 struggling with. The SECY is a process SECY, that is
2 shall I or shall I not ask the Applicant for more
3 information at this juncture to decide if I go beyond
4 72 hours.

5 And the essence of the Staff's suggestion
6 not to go beyond 72 hours is a precedent-setting
7 reason as far as I can tell. Correct me if I'm wrong
8 but the way I heard the discussion was it's a
9 precedent.

10 Past plants, we looked at 72 hours, future
11 plants, you might not want to look beyond 72 hours so
12 there's no reason to do this one beyond 72 hours.
13 That's the essence of what I'm hearing.

14 Is that an appropriate --

15 MR. NOLAN: Consistency.

16 MEMBER CORRADINI: Okay, fine.

17 MR. SCHULTZ: Is there more analysis,
18 evaluation that the Staff needs to do to support a
19 finding of 72 hours?

20 MEMBER RICCARDELLA: 72 or 14 days?

21 MEMBER CORRADINI: No, 72 hours.

22 MR. TABATABAI: I think for us to make a
23 finding for up to 72 hours based on Revision 3
24 information and the SECY approach, I think the review
25 will not require a lot more requests for additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information or interactions with --

2 (Simultaneous speaking.)

3 MEMBER RICCARDELLA: A lot more or any?

4 MR. NOLAN: We would not expect any more
5 information from NuScale.

6 MR. TABATABAI: For clarification.

7 MEMBER CORRADINI: But if I take Steve's
8 question a little bit further, that would imply,
9 though, the assumption -- the but is but the connected
10 open items in Chapter 15 have to be resolved?

11 MR. NOLAN: Yes.

12 MEMBER CORRADINI: In Phase whatever?
13 Okay.

14 MR. NOLAN: Soon.

15 MEMBER DIMITRIJEVIC: What benefit would
16 it be if you approve 14 days for COL Applicant?

17 Because if they have to go infinite, it's
18 much easier for them to start in 14 days, right,
19 instead of 3?

20 MR. NOLAN: If there's no operator action
21 needed --

22 MEMBER DIMITRIJEVIC: Why is NuScale
23 asking for 14 days? What is the benefit?

24 (Simultaneous speaking.)

25 MR. TABATABAI: I think Tom Bergman

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 explained that it's more time for the --

2 PARTICIPANT: Pardon me?

3 MR. TABATABAI: I guess marketing.

4 MEMBER RICCARDELLA: Well, then the
5 natural question is, following up to Steve, how much
6 more effort would be required to approve it for 14
7 days?

8 MEMBER DIMITRIJEVIC: None because it's
9 the same.

10 MR. NOLAN: Yes, I don't want to speculate
11 too much here but we're working these transient
12 phenomena issues in Chapter 15.

13 There's thermohydraulic analyses that
14 NuScale's performed that ends at 72 hours, it doesn't
15 go beyond that.

16 We would have to take a closer look at
17 what would actually be needed to go beyond that.

18 MR. SCHULTZ: But Chapter 15 has a
19 different set of assumptions.

20 MR. NOLAN: That's certainly true, this is
21 definitely unique here.

22 MR. SCHULTZ: You're talking about certain
23 phenomena that you would like to understand better
24 given the NuScale design, is that stated about right?

25 MR. NOLAN: And the reason I'm pointing to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Chapter 15 for a lot of it is because of the
2 uniqueness of the design in that a loss of all AC is
3 basically a design basis event. And so there's a lot
4 of reliance on that existing analysis.

5 You certainly don't have to rely on
6 Chapter 15 assumptions here but when we start looking
7 at boron redistribution and other phenomena, that's
8 where those issues are being looked at and addressed.

9 MEMBER DIMITRIJEVIC: Why I ask how much
10 work is required because in this part of the
11 transformation process, you're now hanging to the old
12 rule, 72 hours.

13 If you can do something with minimal work,
14 say, in 14 days that will save you a lot of review and
15 time and process. For a future COL Applicant, it
16 makes perfect sense to do that.

17 Why we are hanging to this old rules? We
18 don't have to hang to old rules all the time. They
19 are not applicable for every case, you know?

20 MR. NOLAN: So, yes, going back to my
21 points on what we would review during the COLA phase,
22 if the phenomena that we're looking at as part of
23 Chapter 15, if that turns out to not be an issue,
24 there wouldn't be any additional review work needed
25 because we've already reviewed the capabilities and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 capacities of those systems to perform under the
2 currently realistic assumptions.

3 MEMBER DIMITRIJEVIC: But you said in COLA
4 they have to prove it to infinite period, right? In
5 the COLA phase they have to prove, that's what you
6 said, right?

7 MR. NOLAN: Well, they wouldn't have to
8 perform an analysis out that far. They have to have
9 a strategy to address the safety functions.

10 MEMBER DIMITRIJEVIC: Infinite, right?

11 MR. NOLAN: Yes, or until sufficient site
12 capabilities have been restored.

13 MEMBER DIMITRIJEVIC: But this is a
14 difference in they can bring some equipment after 14
15 days is different than after 3 days. That's what I
16 want to say.

17 So, from that point of view, it would be
18 more complicated reviews if this is stopped at 3.
19 That's how I --

20 MR. COYNE: Kevin Coyne, NRO. So, just to
21 be clear, there's nothing magic about 14 days either.

22 As Ryan pointed out, the 5150(5) wording
23 is indefinite and so the 72 hours is predicated on
24 what we need to do to review the design aspects of the
25 SSCs that were added in for the mitigating strategies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that NuScale described in the FSAR.

2 And so it's not necessary for us to go
3 beyond 72 hours for that review provided there's no
4 credible transient phenomenon that we would have to
5 disposition at the COL stage.

6 There's also a thought that some of this
7 would be potentially site-specific and so at the
8 design cert stage we don't have site-specific
9 information obviously.

10 And so from a practical consideration,
11 72 hours is as far as we need to go to make the
12 finding that we need to make for the design cert given
13 that NuScale has asked for the review. That's what
14 establishes the criteria.

15 But there's nothing special about 14 days
16 either from NuScale since the criteria would
17 ultimately be indefinite or until sufficient site
18 capability exists.

19 MEMBER MARCH-LEUBA: So, from a technical
20 point of view, the only difference I see is the boron
21 redistribution, concentration of boron. Once you open
22 ECCS, you're boiling water and condensing the steel.

23 So boron is not uniformly. So maybe you
24 can make an argument for 72 hours that it has not been
25 enough cause a problem but when you go for five months

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in that condition, you need to resolve that in Chapter
2 15.

3 MEMBER CORRADINI: I agree with what Jose
4 is saying but I think the stylized accident they work
5 under here is different than in 15.

6 MR. NOLAN: Well, you have more margin to
7 work with because we assume all rods in.

8 MEMBER MARCH-LEUBA: Correct.

9 MR. NOLAN: But that's the only
10 difference.

11 MEMBER CORRADINI: That's a big
12 difference.

13 MR. NOLAN: It has a lot of margin.

14 MEMBER MARCH-LEUBA: If you are distilling
15 water, concentrated boron is somewhere, hopefully in
16 the core, somewhere else maybe.

17 Just what they need to resolve in Chapter
18 15, if you are in the process where you are distilling
19 water and changing the concentration, the longer you
20 are in that condition, the worse you are.

21 MEMBER CORRADINI: But the assumption is
22 one case is the worst rod is stuck out and the other
23 assumption is all rods in.

24 MEMBER MARCH-LEUBA: With the worst rod
25 stuck out you don't need to dilute boron. You go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 critical.

2 MEMBER CORRADINI: But the boron dilution

3 --

4 MEMBER MARCH-LEUBA: Boron dilution helps
5 you when you have all rods in.

6 MEMBER CORRADINI: Right, but in the
7 Chapter 15 analysis the worst rod stuck out was part
8 of the assumptions of the boron dilution question.

9 MEMBER MARCH-LEUBA: No, it was
10 --

11 MEMBER CORRADINI: I'm looking at the
12 Staff, I'm sure that's the case.

13 MEMBER MARCH-LEUBA: Worst rod is stuck
14 out, you go critical without diluting boron.

15 MS. KARAS: This is Becky Karas from
16 Reactor Systems. We are looking at all those
17 scenarios, you're right.

18 In Chapter 15 you would assume the worst
19 rod is stuck out and then we're looking at both end of
20 cycle with no boron conditions.

21 We're also looking to see if it's
22 potentially more limiting for a beginning-of-cycle or
23 minimal cycle condition with boron redistribution and
24 one rod stock out.

25 But as Ryan's explained, those are all to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 72 hours at this point, right? So, when you take an
2 all rods in condition and you want to go out for
3 extended periods of time, that hasn't been looked at
4 yet.

5 And you would get a lot of margin with the
6 one rod and you're using things like more nominal
7 assumptions, but that's one of the hurdles that we're
8 talking about.

9 MEMBER CORRADINI: But that's what I
10 thought Ryan was suggesting is requiring more analysis
11 potentially on both parts, on both sides.

12 MR. NOLAN: Yes, we would have to take a
13 closer look to go beyond 72 hours.

14 MEMBER BLEY: And no one's willing to say
15 how much effort that is without looking at it.

16 MEMBER MARCH-LEUBA: To me the biggest
17 argument of what the Staff is saying is you don't want
18 to create a precedent that will then backfit all the
19 plans and they have to take longer.

20 MEMBER BLEY: You're already setting a bit
21 of a precedent in that you're analyzing something
22 that's not required at this stage.

23 MR. NOLAN: Yes, so let me add that I
24 believe every PWR has mitigating strategies for
25 reactivity control for adding borated water.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So this is one of the first PWRs we're
2 seeing that does not have a strategy to do so, which
3 is why we're discussing the issue.

4 CHAIR REMPE: So, if I think about it,
5 they have a lot of NuScale-specific things but there's
6 also the fact that there's a philosophy about that if
7 you go to 14 days you don't have to have onsite FLEX,
8 which is more generic and hasn't really been discussed
9 very much.

10 Have you thought much about that part?
11 Because if you do that Phase 1, Phase 2, Phase 3,
12 that's what they're going for, they're going to still
13 have the safer stuff maybe with the COL Applicant.
14 But is that cast in concrete or what's your thoughts
15 on that?

16 MR. NOLAN: I guess for the operating
17 reactors it was more of a Phase 1 plus Phase 2 should
18 be at least 24 hours, right? And then the assumption
19 is Phase 3, you'd get the offsite resources at 24
20 hours.

21 And so if your Phase 1 strategy is
22 sufficiently long, you don't need onsite portable
23 equipment. I think South Texas is a good example of
24 the three and four.

25 It doesn't have necessarily Phase 2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment.

2 (Simultaneous speaking.)

3 CHAIR REMPE: Okay, so --

4 MR. NOLAN: But Phase 1 is sufficiently
5 long enough.

6 CHAIR REMPE: Okay, so basically this
7 isn't that unique that they're saying no flux on site.

8 MR. NOLAN: It would certainly be unique
9 for operating plants. It's probably more common than
10 not for new reactors.

11 MEMBER BLEY: I'm still stewing over your
12 precedent issue. I mean the whole Chapter 20 is
13 something that, as you said, isn't required for a
14 design cert.

15 The Applicant's asked you to review it and
16 you have. The Applicant's asked you to review it
17 beyond 72 hours, which doesn't seem any more
18 precedent-setting than coming into do it for 72 hours
19 when you don't need to.

20 So, that argument seems a little fuzzy to
21 me. Think it over tonight and tell us more tomorrow.

22 MR. COYNE: Kevin Coyne, NRO. One thought
23 is we review against the regulatory requirement, not
24 against the criteria that an Applicant is giving us to
25 review against.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, we reviewed at 72 hours because we
2 believe that's what's necessary to meet the regulatory
3 requirement for the design features that are described
4 for the SSCs in the FSAR or will be.

5 So, going beyond that isn't necessary to
6 support the regulatory finding we need to make against
7 5150(5) for those portions that would get finality
8 with the design certification.

9 MEMBER CORRADINI: But what I heard you
10 say, Kevin, then is you were willing to take the first
11 step but the second step goes outside of the
12 regulatory requirements as stated.

13 That's what I'm -- in other words, you
14 reviewed what you eventually would have to review
15 anyway, you just did it earlier in the phasing.

16 But to go beyond 72 hours goes beyond what
17 the regulation requires.

18 MR. NOLAN: Goes beyond what we believe is
19 needed to satisfy the review that the design aspects
20 satisfy the regulation.

21 And reviewing a design cert application to
22 72 hours is not precedent-setting, it's what we did
23 for APR 1400.

24 MEMBER BLEY: But at the time we thought
25 you'd need to do it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: I'll just point out that
2 the advanced reactor policy statement expects better
3 performance out of these advanced plants.

4 So, you could actually use the
5 Commission's policy as a justification for looking out
6 further.

7 MEMBER BLEY: Let me just ask you where
8 you're headed. You've set the SECY up.

9 If the SECY doesn't generate an SRM or
10 it's what I was saying earlier, at some point it's by
11 default considered accepted, then that would agree
12 with your interpretation on the 72 hours.

13 If the Commission finds that you ought to
14 look beyond that, they would issue an SRM I suppose.
15 So, you've kind of left it in the Commission's lap as
16 far as I understand what you've done with the SECY.

17 MEMBER KIRCHNER: That's a possibility.

18 CHAIR REMPE: Steve, did you want to say
19 something? We kept interrupting you.

20 MR. SCHULTZ: No, I got my question and
21 statements in, thank you.

22 CHAIR REMPE: Okay, so we may have a
23 closed meeting still. You don't want to talk anymore
24 in private?

25 Okay, so do any Members have any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 statements? But not your final ones. I'll go to
2 public comments unless you guys have any more
3 questions.

4 MEMBER BLEY: We just went around and
5 around on this but there's only, essentially, one open
6 item, right in your SER?

7 You didn't specifically talk open items
8 but I think there's only one and that has to do with
9 the boron dilution.

10 MEMBER CORRADINI: There is another one
11 formally which is the SECY.

12 CHAIR REMPE: The SECY is what I was
13 thinking of.

14 MEMBER CORRADINI: There's a process open
15 item

16 MEMBER BLEY: Yes, it does have it in
17 there. You're right, it's there.

18 CHAIR REMPE: Okay, so with that, could
19 you get the phone lines open and I'll ask if there are
20 any public comments in the audience while we're
21 waiting for the phone lines to be opened?

22 Seeing no one trying to talk on the mic,
23 we'll just wait. I heard a beep that implies to me
24 the phone lines are open.

25 Is anyone out there that could confirm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that? I know we're not supposed to have to do that
2 anymore but it seems prudent.

3 Not hearing any comments and I'll wait for
4 Mike.

5 MEMBER CORRADINI: Is anyone out on the
6 open line, please?

7 CHAIR REMPE: Yes, but wait until after we
8 get through this line thing. Let's worked for Mike to
9 come back just to make sure I don't preclude someone
10 from the public wanting to --

11 MEMBER CORRADINI: If somebody's on the
12 public line could you please speak up?

13 CHAIR REMPE: I think I heard a voice so
14 I'm going to assume that there are no comments from
15 anyone on the phone line and we'll let the phone line
16 get back closed.

17 And I think I saw somebody who decided
18 they wanted to talk. Please state your name and
19 provide your comment.

20 MR. BERGMAN: Tom Bergman with NuScale.

21 So, I wasn't sure I was really considered
22 a member of the public but listening to the Staff's
23 discussion, I do agree they've taken an approach that
24 is sort of very efficient at getting to a finding.

25 As far as the 14 days, we would have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 preferred this paper, hearing that it's an info paper,
2 that it would be an actual vote paper because the
3 Commission stopped doing negative consent papers like
4 decades ago.

5 And whether or not it needs Commission
6 engagement is a Staff decision, but to me this is
7 unlike what we did with 5054(M), the licensed
8 operators rule, which only applies to licensees but we
9 chose to address it in the DC.

10 And we addressed it in a very different
11 way than it's done. And that has gone very well.
12 Obviously nothing's approved.

13 So we think they can go beyond 14 days but
14 the policy issue, potential policy issue, we saw is if
15 you can get to 14 days, that constitutes the word
16 indefinite.

17 That's what we are really proposing based
18 on the resources we need at 14 days, which we don't
19 need at 14 days, we really need much later, is a
20 gravity feedwater supply in the spent fuel pool.

21 But that's the hard question we're asking,
22 is if we can show we can get to 14 days, does that
23 constitute indefinite under the definition of a rule?

24 That's what we were seeking from the
25 Staff, not just a 14-day capacity because we show 50

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 days. And the other question is why 14 days? And we
2 debated.

3 You want a technically defensible number,
4 right, you just don't want to pick 30 days or whatever
5 because why did you pick 30 days? And there were two
6 obvious technically defensible numbers to us.

7 One was 14 days which was based on the
8 ability for ad hoc response at Fukushima that grossly
9 exceeds what we need in our plant, and then 50 days.

10 The problem with 50 days is that sets a
11 very high bar for everybody else trying to come in.
12 And 50 days really wouldn't leave us any margin
13 because you always erode margin during construction in
14 operation.

15 But those were the two sort of technically
16 defensible days and we felt 14 represented a
17 reasonable number, not just for us but potentially for
18 other advanced reactors coming down the road.

19 MEMBER BLEY: Tom, would you restate -- if
20 we can get to 14 days, does that constitute --

21 (Simultaneous speaking.)

22 MR. BERGMAN: Basically indefinite coping.

23 MEMBER BLEY: Indefinite coping, right.

24 MR. BERGMAN: In terms of indefinite means
25 you're confident you can get supplies from off site to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 keep the plant in a safe condition indefinitely.
2 Because if you don't pick a day, then indefinite means
3 forever.

4 CHAIR REMPE: So, before I go around the
5 table, I want Mike to confirm the lines were open and
6 he closed them, right?

7 We heard someone mumble something but
8 there weren't any comments, but I'll give the public
9 one more time here on the phone line.

10 So, again I'll ask does anyone on the
11 phone line that's a member of the public want to make
12 a comment? And this time I'm still not hearing
13 everything.

14 I'm going to ask you to go ahead and close
15 them and we're going to go around the table and I'd
16 like the Members and our consultant to chime in about
17 their thoughts again to confirm they're comfortable
18 with trying to have a letter discussed this month at
19 the full Committee Meeting.

20 Again, our schedule, we've got a lot of
21 other letters that are in the queue so it may not
22 happen but my workload in the next couple of days will
23 depend on your response back.

24 And then if you have some comments you'd
25 like to have emphasized, state them here and then I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably will say send me an email with them written
2 down too.

3 Because I'm trying to update a very drafty
4 letter. And I'm going to start with Steve, our
5 consultant, and then I'll go around the table, okay?

6 MR. SCHULTZ: I appreciate all the
7 comments in the discussions that we had today from
8 both the Applicant and the Staff.

9 My understanding has gone back and forth
10 even through the discussion period here.

11 I feel that based on the comments, based
12 on all the work that the Staff has done to prepare the
13 SECY as well as the documentation associated with
14 staging what I think their findings will be, I think
15 we have enough, I think the Committee has enough, to
16 write an interim letter.

17 I'm not sure what the final thoughts will
18 be from the Committee but I think based on what we've
19 heard today we can formulate a statement of where the
20 progress stands and where we expect it to go forward.

21 I think I got the timeframe right, the
22 next six months, associated with the Chapter 15
23 evaluations and so forth that need to be completed.

24 It's got to be interim because of the need
25 to determine whether the findings for Chapter 15 are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to influence this.

2 CHAIR REMPE: I think definitely the
3 Chapter 15 findings are important.

4 I guess the other thing is if there's
5 anything during our discussions today that ACRS
6 identified that the Staff has not already identified,
7 those are that kind of points too that I'd really like
8 to have.

9 I can I hope summarize the status of
10 things but if there's some gaps in what they're
11 reviewing that are not being adequately addressed, let
12 me know or send me some thoughts, okay?

13 MR. SCHULTZ: I think based on what we're
14 doing on this topic, the difficulty is this topic has
15 got constraints that are different from the Chapter 15
16 analysis and constraints.

17 But the Staff has spoken to that today so
18 that needs to be done. But given the combination of
19 letters that are going to be written for this meeting,
20 I think we have several positions to put forward.

21 CHAIR REMPE: Thank you. Dick?

22 MEMBER SKILLMAN: I think we can write a
23 letter that agrees with NuScale and the Staff that the
24 concept of 14 days is sufficient to be described as
25 indefinite. I'm comfortable with that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There are some features of the NuScale
2 design that I'm not comfortable with but on this
3 particular one, I can concur that 14 days is a
4 timespan that can be defended as indefinite.

5 Just two things based on the Fukushima
6 experience, like the team that presented. After about
7 9, 10, 11 days in spite of the horrible infrastructure
8 challenges, the teams at Fukushima were able to add
9 water and do a lot of things.

10 14 days after TMI-2 would have put that
11 event in April 11th of '79. By that time we were
12 cooling down. We had a mess but the containment was
13 intact, we were adding water, we were steaming using
14 bypasses on the feedwater isolation valves.

15 Clearly we were in the middle of a
16 catastrophe. The aggregate intellect and ingenuity of
17 the team, even without procedures and no emergency
18 planning, pulled it together.

19 This design is so much more advanced with
20 so much more defense in depth, I think we can say yes,
21 14 days constitutes the front end of indefinite and
22 after that they can keep on going.

23 So, I'm comfortable with that.

24 CHAIR REMPE: You're basically also then
25 implying you think the Staff should go a bit further

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in their review than 72 hours.

2 MEMBER SKILLMAN: Yes.

3 CHAIR REMPE: Okay, that kind of input is
4 also helpful on how I write this letter since it's a
5 group letter and I don't want to have a minority
6 opinion when I present.

7 Mike, go ahead?

8 MEMBER CORRADINI: So, I guess I agree
9 with Dick and I think Steve but I'm going to go a
10 little bit further. It seems to me we've got to take
11 a holistic approach to this.

12 So, if we're going to go beyond three
13 days, then I need some action after three days to
14 settle other issues that I'm worried about. And that
15 issue is that I want to make sure that I'm subcritical
16 after a few days.

17 So, I'm going to pretend that I'm in
18 charge. If I were in charge and I would say NuScale,
19 I'll grant you 14 days but at 3 days I want you to go
20 make sure you're subcritical somehow -- I don't care
21 how, you figure it out -- that's got to be in the
22 letter.

23 Otherwise we stop at 72 hours. That's it.

24 CHAIR REMPE: Matt? Okay.

25 MEMBER SUNSERI: I don't have anything

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 else to add technically and I would support an interim
2 letter.

3 CHAIR REMPE: Pete?

4 MEMBER RICCARDELLA: Ditto exactly what
5 Matt said.

6 CHAIR REMPE: Okay, Walt?

7 MEMBER KIRCHNER: Again, I'll just repeat
8 myself. There is an advanced reactor policy statement
9 and the expectation is that these advanced designs do
10 have significant margin beyond the current fleet.

11 So, going back and just falling back on
12 the existing fleet, I'm in the camp of both Dick and
13 Mike. Yes, you need to look at assurances about the
14 subcriticality, so that gets into boron kind of
15 issues.

16 But that aside, when you think of the
17 Chapter 15 analysis and the complexity of doing that
18 versus just looking at this massive heat sink, I'm
19 pretty confident this is like a first law of
20 thermodynamics calculation.

21 This is not a dynamic complicated systems
22 code kind of analysis of a LOCA or something very
23 difficult and challenging. So, I'm pretty confident
24 that they can go out to 14 days with what information
25 we've seen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the caveat would, again, be in my mind
2 whether we have too many to control.

3 So, thank you.

4 MEMBER SKILLMAN: Can I just take my note
5 back? I'm so glad Walt used that word.

6 I'm surprised at critical safety function,
7 and this goes back to NEI 0612, why reactivity control
8 isn't one of the critical safety functions.

9 Why isn't reactivity control one of the
10 critical safety functions? That's the reservation I
11 had and Mike nipped it in the bud.

12 I just don't understand why those words
13 don't show up. They're kind of the fundamental law we
14 all hang onto for respecting the technology.

15 You can really shut one of these things
16 down and keep it down.

17 CHAIR REMPE: And as you pointed out
18 earlier, you need some instrumentation to assure that.
19 Go ahead, Jose.

20 MEMBER MARCH-LEUBA: I was going to say I
21 agree with Mike that reactivity control is a key issue
22 because the very difficult problem that we still have
23 to solve is the boron call it dilution or
24 redistribution.

25 Once you open ECCS, you will distill. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are distilling water and filling up the containment
2 with cold, unborated water, which eventually makes it
3 into the downcomer and the downcomer is going to be
4 cold, unborated water.

5 Because technically the boron inside the
6 core or maybe on the rise and you're feeding cold,
7 unborated water through the bottom of the vessel.

8 Now, the probability that that happens and
9 goes critical is 10 to the minus 25 because something
10 would happen that would prevent it. But you have to
11 analyze it and you have to ensure that does happen.

12 And one thing is doing a normal ECCS
13 actuation after an accident where you will be in that
14 operation for two or three hours and then you flag the
15 containment.

16 And another thing is, well, I want to stay
17 five months in this condition. It's stealing my boron
18 away and this obsession with passive operation and
19 hands-off is leading us into the wrong direction.

20 I think we should be reviewing emergency
21 operating guidelines, not the procedures, but
22 guidelines that direct the operators to flood the
23 containment with 2000 PPM water and then nothing
24 happens.

25 But this obsession, and every time I talk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to an operator or an engineer from NuScale it's
2 nothing would happen, nothing would happen, that
3 cannot happen. And it's going into the same
4 direction.

5 You guys should be thinking what could
6 possibly go wrong? And I don't see the NuScale Staff
7 thinking what could possibly go wrong. What can my
8 operators do to make it better?

9 Instead of, yes, obsession with passive
10 thinking is marketing. But it's not safe. The only
11 thing saving us is that this is an extremely safe
12 reactor.

13 CHAIR REMPE: Okay, thank you. Dennis?

14 MEMBER BLEY: I think we can write a
15 letter. I think I'd like to us to have a little
16 private time to talk about the 14 days, although I
17 don't see any problem with it.

18 But I think we want to hash that out
19 because I think the Commission will -- that will be
20 the main thing they look at in this letter.

21 CHAIR REMPE: Let me explore, you mean
22 today? You'd like to have us stay and talk a bit
23 more?

24 MEMBER BLEY: We can go into letter
25 writing but a closed session first to talk about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: That can be worked on.
2 Vesna?

3 MEMBER DIMITRIJEVIC: I express the same
4 sentiment. We should be look at those 14 days and
5 does that mean indefinite? And that's it basically.

6 I think we should write the letter, maybe
7 we can even have a private session now because we're
8 finishing.

9 CHAIR REMPE: Okay, so I agree with what
10 everyone said but I'd like to still elaborate both
11 with this thing about criticality as well as the
12 guides for the operators requires assurance that the
13 instrumentation is there.

14 And that really is the only thing I could
15 add to what's been said. I was going to suggest and
16 I was trying to draft this letter up, half of it is
17 the standard boilerplate that you put on every single
18 NuScale letter, Mike.

19 And so why don't we just stick the stuff
20 on Chapter 20 in with the other parts of this NuScale
21 we're going to be reviewing and writing on this month.
22 I know Mike's saying no, he still wants it separate.

23 If we have to have the separate session,
24 Dennis, then that would be a reason to having the
25 separate letter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But I'd also, because I'm trying to draft
2 the thing, I sure would like to have that session
3 today and have us discuss it before we go to the full
4 Committee just so that I'll have more time to digest
5 it.

6 And so I think that I would like to
7 request the Members to stay here after we close.

8 MEMBER MARCH-LEUBA: Can we go around the
9 table and see if anybody wants a closed session?

10 CHAIR REMPE: For right now?

11 MR. SNODDERLY: This is Mike Snodderly
12 from ACRS Staff. So, please recall our letter-writing
13 we want to have in open session.

14 I think the basis we have for going closed
15 is the OUO aspect of the SECY paper and the fact that
16 it is not being released publicly until July 12th.

17 So, what I would suggest is that we do go
18 into a closed session here at this time to discuss the
19 OUO aspect, the aspect that was set. And any
20 deliberations you want to have concerning that and
21 possible response to that.

22 CHAIR REMPE: Okay, so if we do that,
23 again, I'm not ready to do that because there's one
24 other thing I want to talk -- before we go to closed
25 session, I just want to answer something with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Staff.

2 MR. SNODDERLY: That's if we're going to
3 closed for the letter-writing.

4 CHAIR REMPE: Okay, and then we would not
5 have the transcriber stay or they should stay and
6 record it? What should happen on that?

7 MR. SNODDERLY: If you do it and the
8 transcriber's here we should go closed and it should
9 be transcribed. If you don't want to do it today
10 then, yes, we can do it tomorrow.

11 CHAIR REMPE: Okay, so we'll do that. The
12 other thing that the Staff brought up is what do you
13 want us to talk about?

14 And there will be limited time and I think
15 it might be good for us to comment on that too. I
16 think the Staff's slides I didn't see any big changes
17 but clearly, NuScale will not have time to go through
18 as much depth tomorrow as they've done today.

19 MEMBER CORRADINI: Well, I mean my opinion
20 is given the fact that we can educate our lone Member,
21 they can essentially shrink it down but we'll get to
22 the key points.

23 We've now asked them everything we can so
24 if we're quiet, they can get through it in 15 minutes
25 in both cases.

1 CHAIR REMPE: Okay, so they have, what is
2 it, 25, 28 slides? They still need to reduce it a
3 bit.

4 MEMBER CORRADINI: But they're smart, they
5 can figure it out. I think we clarified a whole bunch
6 of things today that we won't necessarily need to
7 reclarify tomorrow, assuming we can remember.

8 That's my way of looking at it.

9 CHAIR REMPE: From my viewpoint, I think
10 our letter will be focusing on the mitigation of
11 beyond-design-basis rule and how it's being met.

12 The LOLA is of less controversial -- I
13 don't think it's a big deal other than it's there
14 right now. Frankly, the other two sections are going
15 to be going away so I don't see any reason for us to
16 comment much on those too.

17 So, they could clearly focus on that too
18 and eliminate the other discussion. So, with that,
19 we're going to go into closed session. You want to
20 take a break too? Let's say for ten minutes. Okay,
21 thank you.

22 (Whereupon, the above-entitled matter went
23 off the record at 4:00 p.m.)

24

25

July 3, 2019

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Entitled “ACRS Subcommittee Presentation, NuScale FSAR Chapter 20, Mitigation of Beyond-Design-Basis Events,” PM-0719-66189, Revision 0

The purpose of this submittal is to provide presentation materials for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Subcommittee meeting on July 9, 2019. The materials support NuScale’s presentation of Chapter 20, “Mitigation of Beyond-Design-Basis Events,” of the NuScale Design Certification Application.

The enclosure to this letter is the nonproprietary presentation entitled “ACRS Subcommittee Presentation, NuScale FSAR Chapter 20, Mitigation of Beyond-Design-Basis Events,” PM-0719-66189, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Nadja Joergensen at 541-452-7338 or at njoergensen@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-7H4
Michael Snodderly, NRC, TWFN-2E26
Gregory Cranston, NRC, OWFN-8H12
Samuel Lee, NRC, OWFN-8H12
Omid Tabatabai, NRC, OWFN-8H12


Enclosure: “ACRS Subcommittee Presentation, NuScale FSAR Chapter 20, Mitigation of Beyond-Design-Basis Events,” PM-0719-66189, Revision 0

Enclosure:

“ACRS Subcommittee Presentation, NuScale FSAR Chapter 20, Mitigation of Beyond-Design-Basis Events,” PM-0719-66189, Revision 0

NuScale Nonproprietary

ACRS Subcommittee Presentation



NuScale FSAR Chapter 20

Mitigation of Beyond-Design- Basis Events

July 9, 2019

PM-0719-66189
Revision: 0

Copyright 2019 by NuScale Power, LLC.



Template #: 0000-21727-F01 R5

Presenters

Chris Maxwell

Senior Reactor Operator

Zack Rad

Director, Regulatory Affairs

Nadja Joergensen

Licensing Specialist

Mitigation Strategies for Beyond- Design-Basis External Events 10 CFR 50.155(b)(1)

Objective of MBDBE Rule

- Establish coping capabilities to prevent damage to fuel in any NPM and the SFP, and to maintain containment function by using plant and mitigating equipment during an extended loss of AC power (ELAP) concurrent with a loss of normal access to the normal heat sink (LUHS).
- Key safety functions (core cooling, containment, spent fuel pool cooling) are established and maintained indefinitely, or until sufficient site functional capabilities can be maintained without the need for mitigation strategies.

Indefinite Coping

- “...indefinitely, or until sufficient site functional capabilities can be maintained without the need for mitigation strategies”
 - Means to plan for obtaining sufficient resources to maintain the three key safety functions until an alternate means of removing heat is established
 - Allows new reactors to “establish different approaches from those of operating reactors” including using only “installed plant equipment for both the initial and long-term response”
- “Alternate means of removing heat” may be provided by installed plant equipment.

Indefinite Coping

- NuScale considers a minimum coping period of 14 days using only installed plant equipment to be sufficient time to establish “alternate means of removing heat.”
 - In the Fukushima Daiichi accident, without pre-planning or a hardened pool makeup connection, and with limited access to off-site resources, personnel began
 - adding water to the Unit 4 SFP with fire and concrete pump trucks after 9 days; and
 - injecting water via the fuel pool cooling system at 14 days.
- Beyond minimum installed equipment coping period, the continued use of installed plant equipment, ad hoc resources, and equipment repairs can be used to continue coping indefinitely.

NuScale Coping Capability

NuScale Power Plant Design

- The NuScale Power Plant was designed to provide coping during an ELAP concurrent with a LUHS without:
 - AC or DC electrical power
 - Inventory addition
 - Supplemental equipment
 - Off-site resources
 - Operator action (monitoring)
- Extended coping duration is provided by the automatic response of installed plant equipment alone.
- This strategy permits plant staff to focus on addressing the initiating event and restoring normal functional capabilities.

Baseline Coping Capability Criteria, Conditions, and Assumptions


1. Plant equipment that is designed to be robust with respect to design basis external events is assumed to be fully available.
2. Plant equipment that is not robust is assumed to be unavailable.
3. Procedures and equipment relied upon should ensure that satisfactory performance of necessary fuel cooling and containment functions are maintained.
4. The fuel in the modules is required to remain covered at all times.
5. The fuel in the SFP is required to remain covered at all times.

Boundary Conditions

1. Beyond-design-basis external event occurs impacting all modules at the site.
2. All modules on-site initially operating at power, unless site has procedural direction to shut down due to the impending event.
3. Each module is successfully shut down when required (i.e., all rods inserted, no anticipated transient without scram).
4. On-site staff is at site administrative minimum shift staffing levels.
5. No independent, concurrent events, e.g., no active security threat.
6. All personnel on-site are available to support site response.
7. Spent fuel in dry storage is outside the scope of the event.

NuScale Power Plant Response

Plant response without operator action or off-site resources



Core Cooling


- Reactor coolant system inventory is preserved by containment isolation.
- DHRS passively removes decay heat for the first 24 hours.
- The ECCS cools the core for the remainder of an ELAP.
- Modules are partially immersed in the reactor pool, which is part of the UHS.
- Passive heat removal to the UHS maintains core cooling for more than 50 days without pool inventory makeup or operator action.

Containment

- Containment isolation valves (CIVs) and the CNV provide passive containment function. Without operator action or electrical power, the safety-related CIVs close to isolate the CNV.
- Heat removal to the UHS passively controls temperature and pressure to ensure containment integrity. Peak pressure and temperature conditions for the CNV occur early in the event when the ECCS valves open and do not challenge containment integrity.
- Containment cooling is maintained for more than 50 days without pool inventory makeup or operator action.

Spent Fuel Pool Cooling

- The Spent Fuel Pool is part of the UHS.
- The Spent Fuel Pool is partially separated from the Refuel and Reactor Pools by the Weir Wall.



Spent Fuel Pool Cooling

- The SFP, as part of the UHS, communicates with the refueling pool and reactor pool above the SFP weir wall. As such, the pools respond as a single volume during an ELAP until UHS level lowers below the opening in the weir wall.
- The UHS inventory maintains passive cooling of the spent fuel in the SFP for more than 150 days following initiation of an ELAP without pool inventory makeup or operator action.

Monitoring

- No operator action is required to establish or maintain the required safety functions for more than 50 days following the onset of an ELAP. Therefore, no instrumentation is necessary to support operator actions.
- However, instrumentation and DC electrical power are provided to allow the Control Room Operators to observe the response of installed plant equipment and verify the conditions necessary for coping have been established.
- Indications remain available for a minimum of 72 hours.

Spent Fuel Pool Monitoring 10 CFR 50.155(e)

Objective of SFPLI Rule

- Provide a reliable means to remotely monitor wide-range SFP water level until 5 years have elapsed since all of the fuel within that SFP was last used in a reactor vessel for power operation.

Spent Fuel Pool Level Indication

- The UHS system includes remote level indication for the following:
 - Reactor Pool
 - Refueling Pool
 - Spent Fuel Pool (2)
- Normally powered by the highly reliable DC power system via the plant protection system.
- Include a replaceable battery power source, independent from the plant AC and DC power systems, with a minimum capacity of 14 days.

Conclusion

- NuScale Power Plant Mitigation Strategy
 - Rely on the automatic response of permanently installed, safety-related plant equipment to establish and maintain the three key safety functions and provide extended coping capabilities of greater than 14 days.
- The NuScale Power Plant mitigation strategy does not require:
 - AC or DC electrical power
 - Inventory addition
 - Operator action
- NuScale SFPLI Strategy
 - Installed instrumentation with 14 day battery backup power supply.

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804

Richland Office

1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Arlington Office

2300 Clarendon Blvd., Suite 1110
Arlington, VA 22201

London Office

1st Floor Portland House
Bressenden Place
London SW1E 5BH
United Kingdom
+44 (0) 2079 321700

<http://www.nuscalepower.com>

 [Twitter: @NuScale_Power](https://twitter.com/NuScale_Power)



Supplemental Slides

(Description of slide 10)


NuScale Power Plant Response

- NuScale Power Module response within the first minute of the loss of all AC power and without operator action:
 - Reactor trip
 - Decay Heat Removal System initiation
 - Containment isolation
- ECCS automatically initiates after 24 hours.
- With the reactor shutdown and passive decay heat removal established, safe shutdown conditions are established.
- Decay heat passively transferred to the UHS.

NuScale Power Plant Response

- After more than 5 days, the UHS begins to boil and SFP level begins to lower.
- With UHS level greater than or equal to 45', core cooling and the containment function are maintained. It requires more than 50 days for UHS level to lower to this point.
- Without any addition of inventory, Spent Fuel Pool level would:
 - Fall below the UHS weir after more than **4 months**.
 - Reach the top of spent fuel after more than **5 months**.

NuScale Power Plant Response





United States Nuclear Regulatory Commission

Protecting People and the Environment

Preliminary Safety Evaluation with Open Items: Chapter 20, “Mitigation of Beyond- Design-Basis Events”

NuScale Design Certification Application

ACRS Subcommittee Meeting
July 9, 2019

Agenda

- NRC Staff Review Team
- Background
- Staff's Review Approach
- Summary of the Staff's (Preliminary) Findings
- Staff Review of NuScale's MBDBE strategy
- Phase 4 Review Plan
- Abbreviations

NRC Staff Review Team

- Key Technical Reviewers
 - Clint Ashley, NRO
 - Robert Vettori, NRO
 - Ryan Nolan, NRO
 - Michelle Hart, NRO
 - Nan (Danny) Chien, NRO
 - Nick Hansing, NRO
 - Raul Hernandez, NRO
 - John Budzynski, NRO
 - Chang Li, NRO
 - BP Jain, NRO
 - Don Palmrose, NRO
 - Matt McConnell, NRR
 - Sheila Ray, NRR
 - Dinesh Taneja, NRR
 - Joe Ashcraft, NRR
 - Amanda Marshall, NSIR
 - Dan Barss, NSIR
- Project Management
 - Omid Tabatabai, NRO

Background

- 10/30/2018: NuScale submitted its DCA, Rev 2
- 01/24/2019: NRC approved Final MBDBE Rule (10 CFR 50.155)
- 03/28/2019: NuScale informed the staff that it was revising its Ch. 20
- 06/10/2019: NuScale submitted revised Ch. 20
- 06/14/2019: NuScale submitted Rev. 1 to ELAP Technical Report
- 06/26/2019: NRC issued Information SECY 19-0066¹
- 07/12/2019: SECY 19-0066 will be publicly available (ML19148A443)
- September 2019: 10 CFR 50.155 is expected to be publicly available

¹SECY 19-0066: “Staff Review of NuScale Power’s Mitigation Strategy for Beyond-Design-Basis External Events”

Staff's Phase 2 Review Approach

- Staff's (preliminary) Phase 2 SER for Chapter 20 is based on Rev. 2 of NuScale's DCA
- Staff's regulatory bases for the review consisted of:
 - Commission Orders EA-12-049 and EA-12-051
 - JLD-ISG-2012-01, Rev. 1
 - NEI 12-02, Rev. 1,
 - NEI 12-06, Rev. 2
 - SRM-SECY-12-0025
 - SRM-SECY-16-0142
- Based on the docketed information, the Staff's findings in Phase 2 SER are limited to the first 72 hours after initiation of a BDBE.

Summary of the Staff's (Preliminary) Findings

- 20.1: Mitigation Strategies for BDBE – detailed discussions in the upcoming slides
- 20.2: Loss of Large Area (LOLA)
 - Staff used SRP Section 19.4 as the guidance document
 - Use of NEI 06-12 acceptable to staff to show compliance with 50.54(hh)(2)
 - Key safety functions for evaluation:
 - RCS inventory/heat removal
 - Containment isolation/integrity
 - Release mitigation
 - Staff finds NuScale design meets requirements of 50.54(hh)(2)
- 20.3: Emergency Procedures
 - This Section will be reviewed during a combined license application review
- 20.4: Enhanced Emergency response capabilities for BDBE
 - This Section will be reviewed during a combined license application review

Staff Review of NuScale's MBDBE strategy

Regulatory Framework

- The recently approved regulation, 10 CFR 50.155, for mitigation of beyond-design-basis events (MBDBE) does not apply to applicants for a design certification.
- NuScale is voluntarily seeking the NRC's approval of its proposal to use installed design features to mitigate beyond-design-basis external events.
- NuScale design incorporates several design features that provide enhanced capabilities for mitigating an extended loss of ac power compared to currently operating reactors.

Regulatory Framework (Cont'd)

TEXT OF 10 C.F.R. § 50.155(b), (c), and (e) APPROVED BY THE COMMISSION

(b) Strategies and guidelines. Each applicant or licensee shall develop, implement, and maintain:

(1) Mitigation strategies for beyond-design-basis external events. Strategies and guidelines to mitigate beyond-design-basis external events from natural phenomena that are developed assuming a loss of all ac power concurrent with either a loss of normal access to the ultimate heat sink or, for passive reactor designs, a loss of normal access to the normal heat sink. These strategies and guidelines must be capable of being implemented site-wide and must include the following:

(i) Maintaining or restoring core cooling, containment, and spent fuel pool cooling capabilities; and

(ii) The acquisition and use of offsite assistance and resources to support the functions required by paragraph (b)(1)(i) of this section indefinitely, or until sufficient site functional capabilities can be maintained without the need for the mitigation strategies.

....

(c) Equipment. (1) The equipment relied on for the mitigation strategies and guidelines required by paragraph (b)(1) of this section must have sufficient capacity and capability to perform the functions required by paragraph (b)(1) of this section.

(2) The equipment relied on for the mitigation strategies and guidelines required by paragraph (b)(1) of this section must be reasonably protected from the effects of natural phenomena that are equivalent in magnitude to the phenomena assumed for developing the design basis of the facility.

....

(e) Spent fuel pool monitoring. In order to support effective prioritization of event mitigation and recovery actions, each licensee shall provide reliable means to remotely monitor wide-range water level for each spent fuel pool at its site until 5 years have elapsed since all of the fuel within that spent fuel pool was last used in a reactor vessel for power generation.

SRM-M190124A, Enclosure 1, Federal Register Notice at 140-41.

Staff's Review of NuScale MBDBE Approach (Cont'd)

NuScale MBDBE Approach

- Core cooling, containment, and spent fuel pool cooling is maintained by permanently installed SSCs
 - MPS, DHRS, EDSS, ECCS, CNV, UHS, etc.
- Minimum coping duration of 14 days
 - Provides sufficient time for the licensee to establish an alternate means of removing heat
- No reliance on monitoring for the mitigation strategies
 - Although instrumentation powered by the EDSS is expected to remain available in the near-term, module and reactor pool monitoring is a supplementary capability.

Staff's Review of NuScale MBDBE Approach (Cont'd)

Staff's Review Approach

- Maintain consistency with scope of review performed for operating reactors and other design certifications.
 - Focus on the initial response coping period (first 72 hours) where the most critical and time-sensitive actions are projected to occur.
- Verify the design capabilities and capacities of the permanently installed SSCs satisfy the required safety functions, including the effects of credible transient phenomena, for 72 hours following initiating event.
 - Review will focus on design aspects of SSCs as described in the FSAR.
 - Operational aspects (e.g., procedures, training) deferred to COL stage.

Staff's Review Approach (Cont'd)

- COL applicant would need to describe how mitigating strategies (or sufficient site functional capabilities) are maintained for an indefinite time period.
 - SSC design aspects would only need to be addressed if there are credible transient phenomena (e.g., return to power) that could challenge core cooling, containment, or SFP cooling beyond 72 hours
 - Level of detail expected is commensurate with time available to implement actions.
- Staff plans to document that instrumentation is not relied on to support the mitigation strategies; however:
 - Instrumentation is expected to be available for the initial 72 hours,
 - Pool level instrumentation is provided with batteries, for an additional 72 hours of level monitoring, and
 - Provides additional assurance that systems have responded as designed.

Phase 4 Review Plan

- The staff will follow its plans, as described in SECY 19-0066, to complete its review of NuScale's Ch. 20 in Phase 4 of the DCA review.
- The Staff will evaluate NuScale's DCA, Rev. 3, information for compliance with the requirements of 10 CFR 50.155
- NuScale DCA, Rev. 3, is expected to be submitted in late August 2019
- Staff's ACRS Full Committee presentation is scheduled for July 10, 2019.

Abbreviations

ACRS	Advisory Committee on Reactor Safeguards
CFR	Code of Federal Regulations
CNV	Containment Vessel
COL	Combined License
BDBA	Beyond-Design-Basis Accident
CNV	Containment Vessel
DCA	Design Certification Application
DHRS	Decay Heat Removal System
ECCS	Emergency Core Cooling System
EDSS	Highly Reliable Electrical System
ELAP	Extended Loss of AC Power
FSAR	Final Safety Analysis Report
JLD	NRC Japan Lessons Learned Directorate
MBDBE	Mitigation of Beyond-Design-Basis Events
MPS	Module Protection System
NEI	Nuclear Energy Institute
NRC	Nuclear Regulatory Commission
NRR	NRC Office of Nuclear Reactor Regulation
NSIR	NRC Office of Nuclear Security and Incident Response
NRO	NRC Office of New Reactors
SER	Safety Evaluation Report
SRM	Staff Requirement Memorandum
UHS	Ultimate Heat Sink