



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION II - SUITE 818
270 PEACHTREE STREET, NORTHWEST
ATLANTA, GEORGIA 30303

TELEPHONE 404-526-4500

July 15, 1974

H. D. Thornburg, Chief, Field Support and Enforcement Branch
Directorate of Regulatory Operations, Headquarters

DUKE POWER COMPANY (OCONEE 1 and 2), LICENSE NOS. DPR-38, AND DPR-47,
DOCKET NOS. 50-269 AND 50-270, INTENT OF TECHNICAL SPECIFICATION 3.2.2

Headquarters evaluation is requested on the intent of Technical
Specification 3.2.2 for a dual unit facility (see attachment)

This specification requires one source per unit of concentrated
soluble boric acid in addition to the borated water storage tank to
be available and operable.

If there is a connecting pipe between these boric acid systems for
Unit 1 and Unit 2, is it the intent of the technical specification
that the Unit 2 concentrated boric acid storage tank can act as the
additional source of concentrated boric acid for Unit 1 if Unit 2
is shut down and vice versa?

Please provide us with your evaluation as soon as possible.

C. M. Upright
C. M. Upright, Acting Chief
Facilities Operations Branch

Transmitted Via Facsimile
7/15/74 4:20 P.M. ih

8001070 695