

MAY 24 1972

50-269

J. M. Hendrie, Deputy Director for Technical Review, L

TECHNICAL SPECIFICATIONS FOR DUKE POWER COMPANY, OCONEE POWER STATION
UNIT NO. 1

We have reviewed the technical specifications for Oconee Unit No. 1 transmitted by memo of May 22, 1972. We recommend that the specifications be revised to conform to the versions which incorporate Appendix I requirements. Two additional recommended changes are noted below:

Page 3.1-11 line 16, indicate that the E determination is at operating temperature and pressure conditions.

Page 4.4-6. Line 1 does not agree with line 11 on the leakage through penetrations. Line No. 1 should be revised to indicate that 50% or more of the total containment leakage will be to the penetration room.

Harold R. Denton, Assistant Director
for Site Safety
Directorate of Licensing

Enclosures:

1. Memo to JMHendrie from
AGIambusso dtd 5/22/72 w/encls.
2. Duke Power Co., Oconee Nuclear
Station Unit No. 1, Doc. No. 50-269

DISTRIBUTION:

L-Suppl
L-Rdg
AD/SS-Rdg
SAB-Rdg

OFFICE ▶	SAB:L	AD/SS:L					
SURNAME ▶	WPGammill:ej	HRDenton					
DATE ▶	5/24/72	5/ /72					