

95

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-270

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

Mr N C Moseley

FROM: Duke Power Company
Charlotte, NC
W O Parker JrDATE OF DOCUMENT
1-26-77

DATE RECEIVED 2-7-77

NUMBER OF COPIES RECEIVED

one signed

☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

DESCRIPTION

Ltr trans the following:

1p

PLANT NAME: Oconee #2

ENCLOSURE

Licensee Event Report (RO# 76-16) on 12-27-76
concerning exceeding error adjustment power
imbalance limit for reactor operation due to
software lockup on Unit #2 computer.....

DO NOT REMOVE

2p

ACKNOWLEDGED

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION 2-8-77 ehf

BRANCH CHIEF:

W/3 CYS FOR ACTION

LIC. ASST.:

W/1 CYS

ACRS 16 CYS HOLDING/SENT AS CAT B 2/8/77

Schwencer

Sheppard

INTERNAL DISTRIBUTION

REG FILE

NRC PDR

I & E (2)

MIPC

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES

CAS

BUTLER

HANAUER

TEDESCO/MACCARY

EISENHUT

BAER

SHAO

VOLLMER/BUNCH

KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

LPDR: Watkins, SC

TIC:

NSIC:

CONTROL NUMBER

8001140653

1338 5

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 26, 1977

TELEPHONE: AREA 704
373-4083

Regulatory Docket File


Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 2
Docket No. 50-270

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report RO-270/76-16.

Very truly yours,


William O. Parker, Jr.

LJB:ge
Attachment

cc: Director, Office of Management Information
and Program Control



1338