

50-270

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER  
INCIDENT REPORT

TO: Mr Moseley

FROM: Duke Power Co  
Charlotte, NC  
W O Parker Jr

DATE OF DOCUMENT  
12-20-76

DATE RECEIVED 1-14-77

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
one signed

DESCRIPTION  
Ltr trans the following:  
  
**ACKNOWLEDGED  
DO NOT REMOVE**  
  
PLANT NAME: Oconee #2

ENCLOSURE  
Licensee Event Report (RO# 76-13) on 12-~~20~~-76 concerning primary-to-secondary system leakage in "2B" once-through steam generator due to leaking tube #23 in row #77....  
  
NOTE: IF PERSONNEL EXPOSURE IS INVOLVED SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION 1-18-77 ehf

BRANCH CHIEF: Schwencer  
W/3 CYS FOR ACTION  
LIC. ASST.: Sheppard  
W/1 CYS  
ACRS 16 CYS HOLDING/SENT AS CAT B 1-18-77

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE			
NRC PDR			
I & E (2)			
MIPC			
SCHROEDER/IPPOLITO			
HOUSTON			
NOVAK/CHECK			
GRIMES			
CASE			
BUTLER			
HANAUER			
TEDESCO/MACCARY			
EISENHUT			
BAER			
SHAO			
VOLLMER/BUNCH			
KREGER/J. COLLINS			

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Walhalla, SC  
TIC:  
NSIC:

8001140660  
469  
S  
270  
DADY

DUKE POWER COMPANY


POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

TELEPHONE: AREA 704  
373-4083

December 20, 1976



Mr. Norman C. Moseley, Director  
U. S. Nuclear Regulatory Commission  
Suite 818  
230 Peachtree Street, Nor. hwest  
Atlanta, Georgia 30303

Re: Oconee Unit 2  
Docket No. 50-270

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station  
Technical Specifications, please find attached Reportable Occurrence  
Report RO-270/76-15.

Very truly yours,

*William O. Parker, Jr.* *WOP*

William O. Parker, Jr.

LJB:vr  
Attachment

cc: Director, Office of Management Information  
and Program Control