

NRC DISSEMINATION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 436

FILE: INCIDENT FILE

FROM: Duke Power Co. Charlotte, N.C. W.O. Parker, Jr.		DATE OF DOC 1-13-76	DATE REC'D 1-20-76	LTR XXX	TWX	RPT	OTHER
TO: N.C. Moseley		ORIG 1 Signed	CC 0	OTHER	SENT REG PDR SENT LOCAL PDR		XXX XXX
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-270		

DESCRIPTION:
Supplement Unusual Event Report # 75-17,
Concerning the inadvertent isolation of letdown
flow....

(1 Cy. Received)

PLANT NAME: Oconee # 2

ENCLOSURES:

**DO NOT REMOVE
ACKNOWLEDGED**

FOR ACTION/INFORMATION

SAB 1-23-76

BRANCH CHIEF Purple

LIC. ASST. Sheppard W/16 cys AGRS

INTERNAL DISTRIBUTION

REG FILE
NRC PDR
ICE (2)
MFC (3)
SCHRODER/IPPOLITO
HOUSTON
ROVAK/CHECK
GRIMES/SCHLENGER
CASE
F. WILLIAMS
HANAUER
TEDESCO/MACCARY
EISENHUT
BAER
SHAO

VOLLMER/BUNCH
KREGER/J. COLLINS

NOTE: IF PERSONEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

LOCAL PDR Walhalla, S.C.
YIC
NSIC

POOR ORIGINAL

DISTRIBUTION REVISED 1-19-76 by D. CRUTCHFIELD, TECH REVIEW COORDINATOR

8001140747 5

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION



TELEPHONE AREA 704
373-4083

January 13, 1976

Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303



Re: Oconee Unit 2
Docket No. 50-270

Dear Mr. Moseley:

The following information is submitted to supplement Unusual Event Report UE-270/75-17 concerning an incident involving the inadvertent isolation of letdown flow:

Originally, this incident was reported to have resulted from a misunderstanding between personnel involved. A contributing cause, however, was the lack of adequate procedural control to prevent unauthorized personnel from performing functions which may affect unit or station operation. To prevent future incidents of this type, Oconee Administrative Procedure Number 5 has been revised to assure more accurate communication between operating and maintenance personnel and in particular to delineate responsibilities for the operation of station valves. The procedure requires that the Control Operator be notified prior to the performance of any function affecting operation or Control Room indications, and that the Shift Supervisor be notified prior to removing an instrument or component from service or returning it to service. Also, with certain exceptions as listed in the procedure, no personnel other than operators shall be allowed to operate station valves without permission from the Shift Supervisor.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr.

EDB:mmb

CC Mr. Benard C. Rusche