

AUG 19 1976

Dis bution

Docket Files	L. Hulman
NRC PDR	W. Kregar
Local PDR	G. Knighton
LWR 1 File	E. Markee
R. C. DeYoung	P. Cota
F. J. Williams	W. Burke
J. Stolz	F. Cardile
L. Engle	ACRS (16)
E. Hylton	
R. Heineman, SS	
D. Ross, SS	
J. Knight, SS	
R. Tedesco, SS	
H. Denton, DSE	
V. A. Moore, DSE	
R. H. Vollmer, DSE	
M. L. ERnst, DSE	
W. P. Gammill, DSE	
ELD	
IE (3)	

Docket No. 50-346

Toledo Edison Company
 ATTN: Mr. Lowell E. Roe
 Vice President, Facilities Development
 Edison Plaza
 300 Madison Avenue
 Toledo, Ohio 43652

Gentlemen:

REQUEST FOR INFORMATION REQUIRED BY APPENDIX I
 (DAVIS BESSE NUCLEAR POWER STATION, UNIT 1)

bcc: J. R. Buchanan, NSIC
 T. B. Abernathy, TIC

We have completed our acceptance review of your submittal for meeting the requirements of Section V.B of Appendix I; 10 CFR 50. We find that additional information is required in order that we may complete our evaluation of Appendix I for the Davis Besse Nuclear Power Station, Unit 1.

A list of the requests for additional information is enclosed.

In order for the staff to complete its review in a timely manner, we request that your response be submitted no later than 15 days after receipt of this letter. If you are unable to meet this schedule, please inform us as soon as possible.

Please contact us if you have any questions regarding the enclosed requests for information.

POOR ORIGINAL

Sincerely,

Original Signed by
 John F. Stolz
 John F. Stolz, Chief
 Light Water Reactors Branch No. 1
 Division of Project Management

Enclosure:
 Request for Additional
 Information

cc: See page 2

OFFICE →	LWR 1	LWR 1				
SURNAME →	LEngle/red	JStolz				
DATE →	8/19/76	8/19/76				

8001150 870 A

Toledo Edison Company

- 2 -

AUG 19 1976

cc: Mr. Donald H. Hauser, Esq.
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Gerald Charnoff
Shaw, Pittman, Potts and Trowbridge
910 17th Street, N. W.
Washington, D. C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

POOR
ORIGINAL

OFFICE →						
SURNAME →						
DATE →						

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION
TOLEDO EDISON COMPANY
APPENDIX I ANALYSIS FOR
DAVIS BESSE NUCLEAR STATION, UNIT 1
DOCKET NO. 50-346

1. Item 6.3 of Table A6 indicates that there will be 4 purges per year at 50,000 cfm for 16 hours and ventilation for 504 hours/yr at 50,000 cfm during refueling. Justify these parameters in light of the fact that NUREG-0017, Section 2.2.10, states that operating experience at plants similar to Davis Besse indicates a need to vent the containment approximately 20 times per year during power operation.
2. Do the release points indicated in Table A3 have deflectors or diffusers associated with them?