MAY 2 7 1977

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Lowell E. Roe
Vice President, Facilities
Development

Edison Plaza 300 Madison Avenue Toledo, Ohio 43652 POOR ORIGINAL

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NO. 1 TO FACILITY OPERATING LICENSE NO. NPF-3 FOR DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 1 to Facility Operating License No. NPF-3 which is effective as of the date of issuance. Amendment No. 1 revises the Technical Specifications, Appendix A to the Facility Operating License to allow decay heat removal train pump switching operations for the purpose of testing in facility operational Modes 3, 4 and 5. The license is amended by making the appropriate changes to Specification 3.4.1 on page 3/4 4-2 of Appendix A to the license.

We have determined that Amendment No. I does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR Section 51.5(d)(4), that an environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

8001230588

const.

OFFICE >	 · · · · · · · · · · · · · · · · · · ·	***************************************		
SURNAME				
DATE	 		\$40000 \$10000\$	

A copy of the Federal Register Notice of Issuance of Amendment No. 1 and the related Safety Evaluation supporting Amendment No. 1 to License No. NPF-3 are also enclosed.

Sincerely.

Original Signed by

D. B. Vassallo, Assistant Director for Light Water Reactors Division of Project Management

Enclosures:

 Amendment No. 1 to License No. NPF-3

2. Federal Register Notice

 Safety Evaluation Supporting Amendment No. 1 to License No. NPF-3

cc w/enclosures: See page 3

> POOR ORIGINAL

OFFICE >	LWR 1	LWR 1 0	OELD ST	LIVR	/	21.20cc
SURNAME >	EHoldon/red	LENGTON P	SA Miby	DBVassallo		
DATE	5/20/77	5/25/77	5/.2/77	5/27/77	· · · · · · · · · · · · · · · · · · ·	1 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1

cc w/enclosures: Mr. Donald H. Hauser, Esq. The Cleveland Electric Illuminating Company P. O. Box 5000 Cleveland, Ohio 44101

Gerald Charnoff, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, N. W. Washington, D. C. 20036

Leslie Henry, Esq. Fuller, Seney, Henry and Hodge 300 Madison Avenue Toledo, Ohio 43604

Mr. Harry R. Johnson Ottawa County Courthouse Port Clinton, Ohio 43452

Ohio Department of Health ATTN: Director of Health 450 East Town Street Columbus, Ohio 43216

Atomic Energy Control Board P. O. Box 1046 Ottawa, Ontario, Canada

Harond Kahn, Staff Scientist Power Siting Commission 361 East Broad Street Columbus, Ohio 43216

Mr. Bruce Blanchard Environmental Projects Review Department of the Interior Room 5321 13th and C Street, M. W. Washington, D. C. 20240 POOR ORIGINAL

			1	1
OFFICE-	 	 		
SURNAME		 		
DATE	 	 		