

306/2/48

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-346

REC: STOLZ J F
NRC

ORG: ROE L E
TOLEDO EDISON

DOCDATE: 06/13/78
DATE RCVD: 06/19/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED
LTR 1 ENCL 0

SUBJECT:
FURNISHING APPLICANT'S AGREEMENT TO DO A MEASUREMENT TO DETERMINE THE
MODERATOR TEMPERATURE COEFFICIENT WHEN CONTROL ROD GROUP 7 IS WITHDRAWN AT
145 PLUS-MINUS 5 EFFECTIVE FULL PWR DAYS & CHANGE SECTION 8.2.3 OF 05/18/78
PROPOSED TECH SPEC CHANGE RE BURNABLE POISON ROD ASSEMBLIES.

PLANT NAME: DAVIS BESSE - UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *KL*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

1. SEND ALL AMENDMENTS TO J. ROE

PSAR/FSAR AMDTS AND RELATED CORRESPONDENCE
(DISTRIBUTION CODE B001)

FOR ACTION: ASST DIR VASSALLO**LTR ONLY(1) BR CHIEF LWR#1 BC**LTR ONLY(1)
PROJ MGR ENGLE**LTR ONLY(1) LIC ASST LWR#1 LA**LTR ONLY(1)

INTERNAL: REG FILE**LTR ONLY(1) NRC PDR**LTR ONLY(1)
I & C**LTR ONLY(2) OELD**LTR ONLY(1)
OPERATOR LIC BR**LTR ONLY(1) EMERGENCY PLAN BR**LTR ONLY(1)
QAB**LTR ONLY(1) DIRECTOR NRR**LTR ONLY(1)
MIPC**LTR ONLY(1) AD FOR ENG**LTR ONLY(1)
MECH ENG BR**LTR ONLY(1) STRUCTURAL ENG BR**LTR ONLY(1)
MATERIAL ENG BR**LTR ONLY(2) AD FOR REAC SFTY**LTR ONLY(1)
REACTOR SYSTEMS BR**LTR ONLY(1) ANALYSIS BR**LTR ONLY(1)
CORE PERFORMANCE BR**LTR ONLY(1) AD FOR PLANT SYSTEMS**LTR ONLY
AUXILIARY SYS BR**LTR ONLY(1) CONTAINMENT SYSTEMS**LTR ONLY
I & C SYSTEMS BR**LTR ONLY(1) POWER SYS BR**LTR ONLY(1)
AD FOR SITE TECH**LTR ONLY(4) AD FOR SITE ANALYS**LTR ONLY(1)
ACCIDENT ANALYSIS**LTR ONLY(1) EFFLUENT TREAT SYS**LTR ONLY(1)
RAD ASSESSMENT BR**LTR ONLY(1) KIRKWOOD**LTR ONLY(1)

EXTERNAL: LPDR'S
PT. CLINTON, OH**LTR ONLY(1)
TIC**LTR ONLY(1)
NSIC**LTR ONLY(1)
ACRS CAT B**LTR ONLY(16)

HANAUER
STELLO
EISENHUT
ENGINEERING BR
REACTOR SAFETY BR
PLANT SYS BR.
EEB
LEAR 1

DISTRIBUTION: LTR 56 ENCL 0
SIZE: 1P

CONTROL NBR: 781729012

***** THE END *****

8001230648

REGULATORY DOCKET FILE COPY



Docket No. 50-346

License No. NPF-3

June 13, 1978

Serial No. 446

LOWELL E. ROE

Vice President
Facilities Development
(419) 259-5242

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Stolz:

As discussed on the telephone with your Licensing Project Manager (Mr. Leon Engle), Toledo Edison agrees to do a measurement to determine the moderator temperature coefficient when Control Rod Group 7 is withdrawn at 145 ± 5 effective full power days.

In addition, Toledo Edison agrees to change the last sentence of Section 8.2.3 of "Attachment 1 to Application to Amend Operating License for Removal of Burnable Poison Rod Assemblies", as originally given you in our letter dated May 18, 1978 (Serial No. 435). The revised sentence will read as follows: "The worth of control group 5 from the rod insertion limit to fully inserted and control group 4 will be measured, and acceptance criterion 2 will be applied to the sum of groups 7, 6, 5 and 4".

Yours very truly,

jh e/14

~~731720012~~

Boo1
S/O
ADD
HAWAIIER
STALO
EISENHUT
SHAO
KEM SAMPY
PLANTY
FEB