

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME		LICENSE NUMBER										LICENSE TYPE					EVENT TYPE							
01	C	A	R	S	S	1	0	0	-	0	0	0	0	-	0	0	4	1	1	1	1	0	3	
7	8	9				14	15										25	26				30	31	32

CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER					EVENT DATE					REPORT DATE											
01	CONT	M	I	0	L	0	5	0	-	0	3	1	2	0	7	0	3	7	5	0	7	1	4	7	5
7	8			57	58	59	60	61					68	69						74	75				80

EVENT DESCRIPTION

02	A sample of waste water at 1115 indicated a pH of 9.15, exceeding the Technical																							
7	8	9																						80
03	Specification limit, with exception permitted by California Regional Water Quality																							
7	8	9																						80
04	Control Board, of pH 8.95. The flow of waste water was not being diverted to the																							
7	8	9																						80
05	retention basins as required. (UE-75-7)																							
7	8	9																						80
06																								
7	8	9																						80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE					PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER					VIOLATION	
07	W	G	A	I	N	S	T	R	U	A	L	1	3	0	Y		
7	8	9	10	11	12				17	43	44			47	48		

CAUSE DESCRIPTION

08	Upper limit on pH meter set at 9.2, the limit allowed by the Regional Water																							
7	8	9																						80
09	Quality Control Board under the Technical Specifications on a previous occasion.																							
7	8	9																						80
10	To prevent reoccurrence limit will remain set at 8.5.																							
7	8	9																						80

FACILITY STATUS		% POWER		OTHER STATUS					METHOD OF DISCOVERY		DISCOVERY DESCRIPTION													
11	G	0	0	0	NA	NA	A	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7	8	9	10	12	13				44	45	46													80

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY					LOCATION OF RELEASE															
12	Z	Z	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7	8	9	10	11					44	45													80	

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION												
13	0	0	0	Z	NA											
7	8	9	11	12	13											80

PERSONNEL INJURIES

NUMBER		DESCRIPTION													
14	0	0	0	NA											
7	8	9	11	12											80

OFFSITE CONSEQUENCES

15	Minimal to none																							
7	8	9																						80

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION												
16	Z	NA												
7	8	9	10											80

PUBLICITY

17	Informed Sacramento Bee July 10, 1975. Informed Sacramento Union July 14, 1975.																							
7	8	9																						80

ADDITIONAL FACTORS

18	Limit may be changed upon approval of a temporary change to the Process Standards																							
7	8	9																						80
19	by the Plant Review Committee.																							
7	8	9																						80

NAME: Ronald Colombo/Frederick Eisenhuth

PHONE: 916-452-3211