

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME										LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	C	A	R	S	S	1	0	0	-	0	0	0	0	-	0	0	4	1	1	1	1	0	1			
7	8	9				14	15									25	26					30	31	32		

CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER							EVENT DATE					REPORT DATE									
01	CONT	M	I	L	L	0	5	0	-	0	3	1	2	1	2	0	9	7	4	0	1	0	9	7	5
7	8	57	58	59	60	61							68	69					74	75					80

[illegible]

02 The Final Safety Analysis Report, Section 14-C, limits the quantity of aluminum in
7 8 9 80

03 the Reactor Building to 500 lbs. This amount of aluminum was used in the calculations
7 8 9 80

04 for post LOCA hydrogen generation due to radiolytic reaction with NaOH. The building
7 8 9 80

05 normally contains 443 lbs. of exposed aluminum. One 24 ft. aluminum ladder was
7 8 9 80

06 discovered in the building on December 7, 1974, and another ladder and an aluminum *
7 8 9 80

SYSTEM CODE		CAUSE CODE	COMPONENT CODE						PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION		
0	7	Z	Z	Z	Z	Z	Z	Z	Z	Z	9	9	9	N		
7	8	9	10	11	12	13	14	15	16	17	43	44	45	46	47	48

CAUSE DESCRIPTION

09	These materials were left over from initial construction. The original discovery	80
7 8 9		
09	12/7/74 of the 36 lb. ladder put the R.B. aluminum at 476 lbs. The discoveries	80
7 8 9		
09	1/7/75 put the quantity over the 500 lb. limit prior to 12/7/74.	80
7 8 9		

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	B	0	7	0	N/A	B	N/A		
7	8	9	10	11	12	13	14	15	16

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	
1	2	Z		N/A		N/A	
7	8	9	10	11	44	45	80

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION
13	0	0	0	2	N/A

PERSONNEL INJURIES

NUMBER				DESCRIPTION
14	0	0	0	N/A

OFFSITE CONSEQUENCES

15	N/A
----	-----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION
15	Z	N/A

PUBLICITY

17	Sacramento Union and Sacramento Bee were notified	8002210634
----	---	------------

ADDITIONAL FACTORS

*chair were reported January 7, 1975. The original ladder was removed 12/10/74 and
the second ladder and chair were removed 1/7/75.

NAME: R. W. Colombo

PHONE: (916) 452-3211