



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
230 PEACHTREE STREET, N.W. SUITE 1217
ATLANTA, GEORGIA 30303

JUN 26 1978

In Reply Refer To:
RII:PTB
50-302/78-15

FILE COPY

Florida Power Corporation
Attn: Mr. W. P. Stewart, Director
Power Production
P. O. Box 14042, Mail Stop C-4
St. Petersburg, Florida 33733

Gentlemen:

This refers to the inspection conducted by Mr. P. T. Burnett of this office on May 22-26, 1978, of activities authorized by NRC License No. DPR-72 for the Crystal River Unit 3 facility, and to the discussion of our findings held with Mr. G. P. Beatty at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no items of noncompliance were disclosed.

One new unresolved item resulted from this inspection and is discussed in the enclosed report. This item will be examined during subsequent inspections.

In the course of the exit interview plant management made a commitment to add the missile shield crane to the preventive maintenance program for cranes. Management also made the commitment to review ANSI B30.2.0-1976 for applicability to all cranes engaged in handling radioactive material or in carrying loads over fuel. ANSI B30.2-1976 is a safety standard for overhead traveling cranes. The results of the review will be discussed with plant management during a forthcoming inspection.

In accordance with Section 2.790 of the NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you (or your contractor) believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold

8002280 805


Q

JUN 26 1978

such information from public disclosure. Any such application must include a full statement of the reasons on the basis of which it is claimed that the information is proprietary, and should be prepared so that proprietary information identified in the application is contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,



F. J. Long, Chief
Reactor Operations and
Nuclear Support Branch

Enclosure:
Inspection Report No. 50-302/78-15

cc w/encl:
Mr. G. P. Beatty, Jr.
Nuclear Plant Superintendent
P. O. Box 1228
Crystal River, Florida 32629