

*Docket File*

APR 30 1973

Docket No. 50-312

POOR ORIGINAL

Mr. E. K. Davis, General Manager  
Sacramento Municipal Utility District  
6201 S Street, P. O. Box 15830  
Sacramento, California 95813

Dear Mr. Davis:

To assure that adequate protection of the core is being provided during a postulated loss of coolant accident (LOCA) at the Rancho Seco Nuclear Generating Station, it is requested that you provide a reanalysis of the following items:

- (1) peak core cladding temperatures for the worst case large reactor coolant cold leg break using the REFLOOD code modified to include the carryover rate function to predict entrainment,
- (2) peak core cladding temperature for the worst case small reactor coolant pipe break, and
- (3) peak core cladding temperature for a double-ended break in the line that connects a core flooding tank (CFT) to the reactor vessel using the conservative thermal and hydraulic assumptions developed for the Oconee analysis. The location of this break should be between the reactor vessel nozzle and the first check valve leading to the CFT.

It is requested that you expedite your response to minimize impact on the licensing schedule review.

Sincerely,

Original Signed by  
Albert Schwencer

A. Schwencer, Chief  
Pressurized Water Reactors  
Branch No. 4  
Directorate of Licensing

cc: See next page

8003240 801 LB

A

Mr. E. K. Davis

-2-

cc: Mr. David S. Kaplan, Secretary  
and Attorney  
6201 S Street, P. O. Box 15839  
Sacramento, California 95813

DISTRIBUTION

AEC PDR

Local PDR

Docket File

PWR-4 Rdg

RCDeYoung

JHendrie

AKenneke

RWKlecker

OGC

RO (3)

BCBuckley

EIGoulbourne (2)

ASchwencer

POOR ORIGINAL

OFFICE ▶	PWR-4	L:C/PWR-4				
SURNAME ▶	BCBuckley:kmf	ASchwencer				
DATE ▶	4130173	4130173				