Docket No. 50-312

Sacramento Municipal Utility District ATTN: Mr. E. K. Davis General Manager 6201 S Street, P. O. Box 15830 Sacramento, California 95813

Gentlemen:

We have reviewed Administrative Procedure 25, dated April 17, 1974, and submitted April 29, 1974, which describes the Rancho Seco operator requalification program, and the revisions to the procedure dated June 21, 1974 and submitted June 24, 1974. Based on our review of the material submitted, we have determined the program meets the requirements of Sections 50.34(b)(8) and 50.54(1-1) of 10 CFR Part 50 and Appendix A of 10 CFR Part 55 and is acceptable.

The program adequately describes the following items:

- 1. The lecture series to be administered, including subject. and duration.
- 2. The specific manipulations of controls to meet the requirements of Section 3a of Appendix A.
- 3. The methods to be employed to assu _ individual review of design, procedure and license changes.
- 4. The methods to be employed to assure individual review of abnormal and emergency procedures.
- 5. The specific evaluation criteria for determining attendance at a specific lecture, required participation in an accelerated requalification program and other additional training, as applicable.
- 6. The records to be maintained to document each individual's participation in the program.

Sincerely,

Original Signed By A. Schwencer

OFFICE .	CHARLES OF CHARLES ENT.	ight Water Reactors Branch 2-3	135
	and the second s	irectorate of Licensing	
SURNAME	and applications are also as a second of the		
CC:	See next page	The second secon	Marine Santa

Mr. E. K. Davis

cc: David S. Kaplan, Secretary and General Counsel 6201 S Street P. O. Box 15830 Sacramento, California 95813

DISTRIBUTION: Docket Files AEC PDR LPDR LWR 2-3 Reading VAMoore JHendrie AKenneke DEisenhut RKlecker OGC RO (3) BBuckley EGoulbourne TR BCs LWR 1 & 2 BCs ACRS (16)

OFFICE	x7886/LWR 2-3 EGoulEdurne:cjb	L:LWR 2-3 BBuckley	L:CHER 2-3 ASchwencer	
DATE	7/8/74	7//0 /74	7/06/74	the state of the court of the c