


Alabama Power Company  
500 North 18th Street  
P.O. Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 323-5341

F. L. CLAYTON, JR.  
Senior Vice President

June 9, 1980



Docket No. 50-348

Director  
Office of Management Information and  
Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Sir:

RE: Joseph M. Farley Nuclear Plant  
Unit No. 1  
Monthly Operating Data Report

Attached are two (2) copies of the May, 1980 monthly operating report for Joseph M. Farley Nuclear Plant, Unit 1, as required by Section 6.9.1.6 of the Appendix A Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 1, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,

*F. L. Clayton, Jr.*  
F. L. Clayton, Jr.

FLCJr/JRC:aw

Attachments

cc: Mr. Ted Cintula (1 copy)  
✓ Director, IE (10 copies)  
Director, RII (1 copy)

A008  
S  
1/1

8006180440 R

JOSEPH M. FARLEY NUCLEAR PLANT  
UNIT 1

NARRATIVE SUMMARY OF OPERATIONS  
MAY, 1980

There were eight (8) power reductions in the month of May.

The following safety-related maintenance was performed in May:

1. Reworked the outlet, outlet check, inlet and bypass valves for the Gross Failed Fuel Detector.
2. Reworked the throttle stop lever on 1-2A, 2B and 1B Diesels.
3. Reworked B air compressor for 1-2A Diesel.
4. Replaced solenoid valve for mini purge discharge valve Q1P13V290.
5. Repaired DC power supply for Data Cabinet B Direct Rod Position Indication.