

REGULATORY DOCKET FILE COPY

MAY 30 1980

DISTRIBUTION:

✓ Docket Files
NRR Rdg
LB#1 Rdg
AWDromerick

Docket Nos. 50-443
and 50-444 ✓

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Mr. William C. Tallman
Chairman & Chief Executive Officer
Public Service Company of
New Hampshire
10000 Elm Street
Manchester, New Hampshire 03105

Dear Mr. Tallman:

SUBJECT: Use of ASME Code Cases N-237, N-218, and N-228 for the Seabrook Station, Docket Nos. 50-443 and 50-444.

In your letter of October 15, 1979, you requested authorization to use ASME Code Cases N-237, N-218, and N-228 in the construction of components for the Seabrook Station.

This is to advise you that Code Case N-237, dated July 9, 1979, "Hydrostatic Testing of Internal Piping Section III, Division 1," Code Case N-218, dated July 27, 1978, "Testing Lots of Carbon Steel Solid, Base Welding Electrode on Wire, Section III, Division 2," and Code Case N-228, dated March 19, 1979, "Alternate Rules for Sequence of Completion of Code Data Report Forms and Stamping for Section III, Class 1, 2, 3, and MC Construction," are acceptable and may be used in the construction of components for the Seabrook Station.

Use of these codes cases should be documented in the Final Safety Analysis Report.

Sincerely,

ORIGINAL SIGNED BY

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

8006180 688

OFFICE	DL:LB#1 AWDromerick:km	DL:LB#1A BJYoungblood			
SURNAME					
DATE	05/27/80 5/27/80	05/20/80			

Mr. W. C. Tallman

- 2 -

bcc: NSIC
TIC
ACRS (16)
NRC PDR
Local PDR
M. Rushbrook
D. Swanson, OELD
I&E (3)
B. Youngblood
R. Tedesco

MAY 30 1980

OFFICE ▶
SURNAME ▶
DATE ▶