

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ARAN 02 00 -0 00 00 -00 34 1111 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CONT

01 01 050003 1687 0603 8108 0617 8109

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During Mode 1 operation, Safety Injection Tanks (SIT) "C" and "D" were

03 found to have boron concentrations of 1711 ppm and 1620 ppm, which is

04 below the 1731 ppm boron concentration as per T.S. 3.5.1.c. The SIT "A"

05 and "B" boron concentrations were verified to be greater than 1731 ppm

06 boron. There have been no similar occurrences reportable per T.S. 3.9.1.8.b

07

08

09

SYSTEM CODE S F 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

LER-RO REPORT NUMBER 17 1810 EVENT YEAR 21 810 SEQUENTIAL REPORT NO. 24 037 OCCURRENCE CODE 28 01 REPORT TYPE 30 T REVISION NO. 32 0

ACTION TAKEN E 18 19 FUTURE ACTION 23 Z 20 EFFECT ON PLANT 25 Z 21 SHUTDOWN METHOD 27 0000 HOURS 22 0000 ATTACHMENT SUBMITTED 40 N 23 NRC-4 FORM SUB 42 N 24 PRIME COMP SUPPLIER 43 Z 25 COMPONENT MANUFACTURER 47 Z 26 9999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Cause of the occurrence is believed to be boron stratification in the

11 Safety Injection Tanks. A review of operations logs for SIT levels

12 discounted the possibility of inadvertent dilution as there were no level

13 changes. Sampling methods are being evaluated to assure representative

14 boron concentration sampling. The boron concentrations of "C" and "D"

15 SIT's were corrected to 1731 ppm within 3 hours.

16 E 18 19 11010 29 NA 30 A 31 Monthly Sampling 32

FACILITY STATUS 34 % POWER 35 OTHER STATUS 36 METHOD OF DISCOVERY 37 DISCOVERY DESCRIPTION 38

17 Z 33 Z 34 NA 35 NA 36

ACTIVITY CONTENT 39 RELEASED OF RELEASE 40 AMOUNT OF ACTIVITY 41 LOCATION OF RELEASE 42

18 0000 37 Z 38 NA 39

PERSONNEL EXPOSURES 40 TYPE 41 DESCRIPTION 42

19 0000 40 NA 41

PERSONNEL INJURIES 42 NUMBER 43 DESCRIPTION 44

20 0000 42 NA 43

LOSS OF OR DAMAGE TO FACILITY 44 TYPE 45 DESCRIPTION 46

21 Z 42 NA 43

PUBLICITY 46 DESCRIPTION 47

22 N 44 NA 45

ISSUED 48 DESCRIPTION 49

23 N 44 NA 45

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

NRC USE ONLY

8006200493