

Public Service Company of Colorado
Docket No. 50267/80-08

NOTICE OF VIOLATION

Based on the results of an NRC inspection conducted April 1-30, 1980, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below:

Technical Specification 4.6.1, Limiting Conditions for Operation, requires in part that "Both the diesel-generator sets are operable, including the following: . . . 500 gallons of fuel in each day tank"

Contrary to the above, on April 2, 1980, the diesel day tanks were observed to be at approximately 385 gallons each while the reactor was at power.

This is an infraction.

8 0062 40053