



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 • CLEVELAND, OHIO 44101 • TELEPHONE (216) 622-9800 • ILLUMINATING BLDG. • 55 PUBLIC SQUARE

Serving The Best Location in the Nation

Dalwyn R. Davidson
VICE PRESIDENT
SYSTEM ENGINEERING AND CONSTRUCTION

June 18, 1980

U. S. Nuclear Regulatory Commission
Director of Reactor Construction
Inspection, O.I.E.
Washington, D.C. 20555

Re: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Construction Permits Nos. CPPR-148;
CPPR-149
IE Bulletin No. 80-09

Gentlemen:

The following information is supplied in response to IE Bulletin No. 80-09 which addresses Hydramotor Actuator deficiencies.

A survey of the vendors supplying valve actuators to the Perry Nuclear Power Plant indicated that only Powers Regulator Co. is supplying ITT General Controls Model NH-90 Series Hydramotor Actuators. No Model AH-90 are being supplied to Perry.

ITT-GC has confirmed that the Powers Regulator Co. purchase order for Perry is not affected by the deficiencies noted in the IE Bulletin. Furthermore, ITT-GC has supplied Powers Regulator Co. with updated test data which shows ample spring force for the Perry damper operators.

If you require additional information, please let me know.

Very truly yours,

Dalwyn R. Davidson
Vice President
System Engineering and Construction

DRD/cmw

cc: Mr. James G. Keppler, Director
Region III Office of Inspection
and Enforcement
799 Roosevelt Road
Glen Ellyn, Illinois 60137

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

BOO1
S
1/0

8006240378