

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

June 18, 1980

TELEPHONE AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: Catawba Nuclear Station
Units 1 and 2
Docket Nos. 50-413 and 50-414

Dear Mr. O'Reilly:

As described in my letter of February 1, 1980, which transmitted Significant Deficiency Report SD 413-414/80-01, all Unit 1 safety-related motor control center equipment furnished by Nelson Electric has been inspected for proper power wire connections and the necessary modifications completed.

Inspection of Unit 2 safety-related motor control center equipment is scheduled for completion by December 31, 1980.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr.

RWO:scs

✓cc: Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

G. F. Maxwell
NRC - Catawba Nuclear Station

8019
5/10

S

8006240 411