

APR 24 1980

APPENDIX A

Sacramento Municipal Utility District  
P. O. Box 15830  
Sacramento, California 95813

Docket No. 50-312  
License No. DPR-54

Notice of Violation

Based on the results of the NRC inspection conducted between March 3 and 31, 1980, it appears that one of your activities was not in full compliance with applicable NRC regulations and conditions of your license as indicated below.

Technical Specification 6.5.1.6.a reads, in part, "The Plant Review Committee (PRC) shall be responsible for review of 1) all procedures required by Specification 6.8 and changes thereto,...."

Contrary to the above requirements, the procedures required for controlling certain uses of the polar crane had not been reviewed by the PRC prior to February 19, 1980, when the procedures were used to move a large 3,000 pound calibration block over the fuel transfer canal with the reactor vessel head removed and irradiated fuel in the reactor building.

This item is an infraction.

8006250760