LICENSEE EVENT REPORT

LICENSEE EVENT REPORT
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
TO 1: Q A D 2 2 O O O O O O O O
REPORT LL 6 0 5 0 0 2 6 5 7 0 5 1 7 8 0 3 0 6 1 0 8 0 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
While performing the quarterly MSIV closure timing surveillance, procedure QOS
250-4, MSIV AO 2-203-1C closed in 2.5 seconds and MSIV AO 2-203-2D closed in 9.1
seconds. These times exceed the Technical Specification Table 3.7-1 limits of
three seconds minimum and 5 seconds maximum closing times. The other 6 MSIVs were
within Technical Specification limits.
SYSTEM CODE SUBCODE SU
LER RO EVENT YEAR NO. CODE TYPE NO. NO.
ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER LET 18 2 19 2 20 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
The speed control valve adjustment on the hydraulic control cylinder for each
valve had varied. The speed control valves were adjusted, and the valves were
tested three times with a IC valve closure time of 3.4 seconds and a 2D valve
closure time of 3.6 seconds.
PACILITY STATUS OTHER STATUS OF DISCOVERY DESCRIPTION (32) B G (23) O O O O O O NA B O Routine Test
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA NA NA NA NA NA NA NA NA N
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA 11 12 13 13 80
PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA NA
LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA NA NA
PUBLICITY SSUED DESCRIPTION 45 80062702742 NRC USE ONLY NA N
NAME OF PREPARER C. Steffes PHONE: 309-654-2241, Ext. 170 0

1. LER NUMBER: LER/RO 80-10/03L-0

11. LICENSEE NAME: Common th Edison Company

Quad-Cities Nuclear Power Station

111. FACILITY NAME: Unit Two

IV. DOCKET NUMBER: 050-265

V. EVENT DESCRIPTION:

On May 17, 1980, during a Unit Two condenser maintenance outage, the quarterly MSIV closure timing surveillance procedure QOS 250-4, was performed. While performing this test, MSIV AO 2-203-1C closed in 2.5 seconds, and MSIV AO 2-203-2D closed in 9.1 seconds. These times exceed the limit of 3 seconds minimum and 5 seconds maximum closing time for any MSIV as stated in Technical Specification Table 3.7-1. The other 6 MSIVs were within the Technical Specification limits.

VI. PROBABLE CONSEQUENCES:

The main steam isolation valves are required to close in less than five seconds to prevent fuel rod rupture, and greater than three seconds to prevent abnormal transient in the event of a steam line break outside the containment. The 2D valve is the outboard primary containment isolation valve in the D steamline. The 1D inboard valve closed in less than five seconds to isolate the D steam line. The 1C inboard primary isolation valve closed in 2.5 seconds which would have caused a slight transient. This transient would be distributed across the other three main steam lines, subsequently safe reactor operation was not affected as a result of this occurrence.

VII. CAUSE:

The cause of this occurrence is designated as equipment failure. The speed control valve adjustment on the hydraulic control cylinder had varied, thus affecting the valve travel time. The control valve is a needle valve that regulates the speed of the hydraulic oil flowing from the bottom to the top of the piston. The piston is attached to the stem of the MSIV to regulate the travel speed of the valve.

The speed control unit is manufactured by Flick-Reedy Corp., Drawing No. File 4536.

VIII. CORRECTIVE ACTION:

The speed control valves were adjusted, and the valves were tested three times with a 2D valve closure time of 3.6 seconds and the 1C valve closure time of 3.4 seconds.