

- 1) Page 1, add to 1.3, ". . . with simulated loss of power conditions."
- 2) Page 2, Step 2.10, correct spelling of "Temporary".
- 3) Page 3, add to Step 2.11: "Set interval for a two minute trend."
- 4) Page 3, Step 2.12, change U0969" to "U0965".
- 5) Page 5, Step 3.14, correct spelling of "maximum".
- 6) Page 5, add 3.17: "_____ 3.17 During the conduct of this test, the Test Engineer will make determinations relating to the amount of data being recorded (i.e. speed records, collecting of data, etc.). This determination will be based on the ability of the collected data to adequately reproduce the natural circulation conditions. The Test Engineer will meet the qualifications of a Startup Test Engineer as defined in the FSAR."
- 7) Page 6, second note after Step 4.4, item b), change "increase" to "decrease".
- 8) Page 8, Step 4.13, change "4.11" to "4.13".
- 9) Page 10, add to Step 4.27: "Using the reactivity computer, verify the reactor is shutdown".
- 10) Attachment 6.7, page 1, change first sentence to read as follows: "During the performance of these tests, operation will be controlled by the following criteria."
- 11) Attachment 6.7, page 1, item A., change "For all tests" to "Operational guidelines for all tests".
- 12) Attachment 6.7, page 1, item A.c(1), change "21" to " \geq 22".