

TERA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUN 23 1980

Docket No. 50-327

Mr. H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

SUBJECT: REVISION TO SEQUOYAH TECHNICAL SPECIFICATIONS

This letter confirms the oral authorization that was given on June 20th to proceed with plant heatup with an inoperable hanger on the pressurizer relief line. A facsimile of your letter on this matter was provided on June 20, 1980. This change is similar to those described in your letter of May 28, 1980, and approved by NRC.

This new deficiency will also be corrected before initial criticality. Since no fission product inventory will exist in the primary system, no additional risk to the health and safety of the public is incurred for this change.

A formal amendment to your license will be processed in the near future.

Sincerely,

*for Donald E. Schwenter*  
Schwenter, Chief  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

8007020042 P

Mr. H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

JUN 23 1980

cc: Herbert S. Sanger, Jr., Esq.  
General Counsel  
Tennessee Valley Authority  
400 Commerce Avenue  
E 11B 33  
Knoxville, Tennessee 37902

Mr. H. N. Culver  
Tennessee Valley Authority  
400 Commerce Avenue, 249A HBB  
Knoxville, Tennessee 37902

Mr. Bob Faas  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. Mark Burzynski  
Tennessee Valley Authority  
400 Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Mr. J. F. Cox  
Tennessee Valley Authority  
400 Commerce Avenue, W10C131C  
Knoxville, Tennessee 37902

Resident Inspector/Sequoyah NPS  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 699  
Hixson, Tennessee 37343