

APPENDIX A
NOTICE OF VIOLATION

Georgia Power Company
(Hatch Units 1 and 2)

Docket Nos. 50-321 & 50-366
License Nos. DPR-57 & NPF-5
EA-80-32

Based on the results of the NRC inspection conducted on March 19, 1980 and April 29-30, 1980, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below. This item has been categorized as described in our correspondence to you dated December 3, 1979.

10 CFR 71.5 prohibits delivery of licensed material to a carrier for transport unless the licensee complies with the applicable regulations of the Department of Transportation in 49 CFR Parts 170-189. 49 CFR 173.393(j)(4) limits the radiation level to two millirem per hour in any normally occupied position of the car or vehicle.

Contrary to the above, on March 18, 1980, packages of licensed material were shipped from your facility in a transport vehicle (trailer #544104) with radiation levels in the normally occupied portions of the truck cab in excess of the regulatory limit as was evidenced by measured levels ranging from 2.6 to 3.7 mrem/hr upon its arrival at the Barnwell, South Carolina waste disposal site on March 19, 1980.

This is a Severity Level II Violation (Civil Penalty - \$4,000)

This Notice of Violation is sent to Georgia Power Company pursuant to the provisions of Section 2.201 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations. Georgia Power Company is hereby required to submit to this office within twenty-five (25) days of the date of this notice, a written statement or explanation in reply which includes: (1) admission or denial of the alleged item of noncompliance; (2) the reasons for the item of noncompliance if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further items of noncompliance; and (5) the date when full compliance will be achieved.