



**Nuclear Fuel Services, Inc.** P.O. Box 124 • West Valley, New York 14171

A Subsidiary of Getty Oil Company

(716) 942-3235

June 26, 1980  
1-80-066

Mr. Boyce H. Grier, Director  
US Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, PA 19406


Re: Docket 50-201  
IE Bulletin ~~80~~-15

Dear Mr. Grier:

In response to your IE Bulletin No. ~~80~~-15, we have determined by direct inspection with a representative of the Iroquois Telephone Company that the Emergency Notification System (ENS) telephone at our West Valley plant is supplied with power by the telephone company and does not receive any 120V AC from the plant power supply (confirming enclosure 1, Bulletin ~~80~~-15), and therefore does not require an on-site auxiliary power supply.

At our next scheduled power outage and test of the emergency diesel generator (EDG), we will conduct a test of the ENS to verify that it is independent of on-site power. This test will be conducted within the next thirty days.

Very truly yours,

  
J. P. Duckworth  
General Manager

JPD:bon

cc: NRC Office of Inspection & Enforcement  
Washington, DC 20555

NRC Document Management Branch  
Washington, DC 20555

R. W. Deuster, NFS/Rockville

*Noot  
5/10*

8007080246