

Cocket Nos. 50-269
50-270
and 50-287

MAR 5 1977

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President
Steam Production
Post Office Box 2179
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

RE: DODDREE NUCLEAR STATION, UNITS 1, 2 & 3

As you may be aware, the provision for "an individual qualified in radiation protection procedures to be on site when fuel is in the reactor" has been a technical specification requirement for the majority of operating facilities for the past several years. The intent of this requirement was to provide at least a minimum level of expertise in radiological protection at the operating shift crew level. It was intended that these radiation protection personnel would perform routine radiation monitoring activities and thereby supplement licensee efforts to maintain radiation exposure and release of radioactive effluents "as low as is reasonably achievable".

As a result of recent NRC staff discussions, we have formalized our position regarding the necessary activities "individuals qualified in radiation protection procedures" should be able to perform. These activities and related clarifying information are presented for your information in the attached enclosure.

The OIAE Inspector assigned to your facility will be using this same criteria in determining whether your designated individuals meet these requirements. We recommend you review the enclosed criteria promptly so that you may take any action necessary to meet the requirements.

OFFICE ➤						
SURNAME ➤						
DATE ➤						

We note that your facility technical specifications do not require that the individual performing the function of Radiation Protection Manager (RPM) meet the minimum qualification requirements of Regulatory Guide 1.8, September 1975. As stated in this guide, it is the NRC position that if the RPM is reassigned or the incumbent replaced, the new RPM should have qualifications equivalent to those stated in this guide.

To implement this provision, we request that you determine if the individual performing the function of Radiation Protection Manager meets the minimum qualifications of Regulatory Guide 1.8, September 1975. In the event the RPM is so qualified, you should propose a technical specification to be included in the Administrative Controls Section which states that "the RPM (or equivalent position title) shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975".

In the event you determine that the present incumbent does not meet the minimum requirements of the guide, you should advise us of this fact and provide a written commitment that the successor to the incumbent will be so qualified and that you will propose a technical specification to that effect at that time.

The above action should be completed within 60 days of receipt of this letter. In the event you should desire further discussion of this matter, please contact us.

Sincerely,

Original Signed By

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosure:
Criteria for "Individuals
Qualified in Radiation
Protection Procedures"

cc: See next page

DISTRIBUTION

- Dockets (3)
- NRC PDR (3)
- Local PDR
- ORB#1 Reading
- TJ Carter
- ASchwencer
- SMSheppard
- DNeighbors
- JMcGough
- OELD
- OIE (3)
- DEisenhut
- TBAbernathy
- JRBuchanan
- ACRS (16)

x27433:tsb	OFFICE →	ORB#1	ASG	ORB#1		
	SURNAME →	DNeighbors	JMcGough	ASchwencer		
	DATE →	3/3/77	3/9/77	3/9/77		

Duke Power Company

- 3 -

March 9, 1977

cc: Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
DeBevoise & Liberman
700 Shoreham Building
806-15th Street, NW.,
Washington, D.C. 20005

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691